

1 Q. Reference: ***Combustor Inspection Major and Overhaul, Holyrood Combustion***  
2 ***Turbine report, August 29, 2016, page 15***

3 *“Siemens has indicated that the majority of utilities that are operating this type of*  
4 *CT have adopted the recommended maintenance strategy based on total ES and*  
5 *EBH criteria outlined above in Section 2- Background.”*

6 Please provide a listing of Canadian and American utilities that operate this type of  
7 CT. For each utility listed, please indicate the type of fuel used to power their CT  
8 units.

9

10

11 A. Due to confidentiality reasons, a listing of specific utilities cannot be provided.  
12 There are 45 W501D5A combustion turbines in the US and Canada, many of which  
13 have the ability to operate on either natural gas or liquid fuel. Of these 45 units,  
14 two have their primary fuel type as oil, the remainder have natural gas as their  
15 primary fuel.