

1 Q. When did Hydro staff first recognize that it would have to advance the Holyrood CT
2 combustor inspection and overhaul?

3

4

5 A. In December 2015, analysis and forecasting of Equivalent Starts (ES) indicated that
6 there was a potential that the Holyrood CT combustor inspection and overhaul
7 would have to occur in the late fall of 2016, and may not be possible to delay until
8 the spring of 2017. By the end of November 2015, the calculated ES were 227.5, just
9 over half of the recommended 400 ES for combustor inspection and overhaul. The
10 final decision to submit the project as a supplementary capital budget application
11 occurred in July 2016. Please reference PUB-NLH-006 for additional detail.