

1 Q. Please provide Holyrood's Unit Availability Statistics for 2012 to 2015.

2

3

4 A. The statistics which provide an overview of Holyrood's availability are:

5

6 **Derated Adjusted Forced Outage Rate (DAFOR)** - measures the percentage of time
7 that a unit or group of units is unable to generate at its Maximum Continuous
8 Rating (MCR) due to forced outages. The plant rate is weighted to reflect
9 differences in generating unit sizes.

10

11 **Capability Factor (CF)** – measures the percentage of time that a unit or a group of
12 units is available to supply power at maximum continuous generating capacity. The
13 plant factor is weighted to reflect the difference in generating unit sizes, meaning
14 larger units have a greater impact on this measure.

15

16 The 2012 to 2015 statistics are:

17

Holyrood Availability (DAFOR)				
Year	HRD Unit 1	HRD Unit 2	HRD Unit 3	HRD Plant
2012	4.73	0.77	16.87	5.98
2013	75.70	6.44	12.77	38.58
2014	19.61	12.16	9.48	13.74
2015	4.94	1.89	9.37	5.03

Capability Factor				
Year	Unit 1	Unit 2	Unit 3	Plant
2012	70.15	82.97	75.13	76.11
2013	21.65	72.16	44.32	46.10
2014	60.17	61.27	69.35	63.42
2015	68.83	65.21	56.17	63.63

1

2

As shown in the tables above, there has been an improvement in both plant level

3

DAFOR and Capability Factor for 2014 and 2015 compared to 2013.