

1 Q. **Re 2011 Capital Plan - Individual Capital Projects:**

2 **Project C-44, Install Weatherhoods for Vent Fans-Holyrood:** What savings would
3 be achieved by eliminating two north side vents and four south side vents from the
4 project?

5

6

7 A. If two north side vents and four south side vents were eliminated from this project,
8 the savings achieved is estimated to be \$60,000. However, elimination of these
9 from the project would compromise the effectiveness of the plant ventilation
10 system.