

1    Q.    **Re: IC-NLH 26, B-15, Overhaul Gas Turbine, Holyrood, \$1,291,400**

2            When will NLH be in a position to file an application for an alternative source of  
3            power supply for the Holyrood Thermal generating Station to replace the capability  
4            of the gas turbine plant?

5

6

7    A.    Hydro continues to consider the available alternatives and is having difficulty  
8            securing temporary black start capability. An application filing date is therefore not  
9            yet determinable. As a result, this project will be removed from the 2011 Capital  
10          Budget Application. An unbudgeted capital project may be filed at a later date.