

- 1 Q. Re: Refurbishment of the Fuel Oil Storage Facility
- 2 At p. 7, it states that the plant consumes approximately 17,000 barrels per day
- 3 when operating at full load. What percentage of days over the period from 2002 to
- 4 2005 [i.e. January 1 to April 30] had consumption:
- 5 (a) at 17,000 barrels
- 6 (b) from 14,000 - 16,999 barrels
- 7 (c) from 10,000 - 13,999 barrels
- 8 (d) from 6,000 - 9,999 barrels
- 9 (e) from 3,000 - 5,999 barrels
- 10 (f) less than 3,000 barrels
- 11
- 12
- 13 A. As demonstrated in the table below, nearly 40% of the time, significant (over
- 14 14,000 barrels) daily consumption takes place. During these high consumption
- 15 periods, it is critical that the storage tanks are available to ensure the reliability of
- 16 the power supply for the Island Interconnected System.

2002 - 2005 Consumption	Number of Occurrences	Percentage
≥ 17,000	15	3.1%
14,000 - 16,999	177	36.8%
10,000 - 13,999	188	39.1%
6,000 - 9,999	82	17.0%
3,000 - 5,999	19	4.0%
< 3,000	0	0.0%
Total	481	100.0%