

1 Q. Refurbishment of the Fuel Oil Storage Facility, Holyrood Thermal Generating
2 Station

3 Over the period from 1990 to 2010, in which years has there been a concern with
4 regard to tanker traffic as a result of icing blocking the bay?

5

6

7 A. Each year the possibility of an ice blockage is a known concern and maintaining
8 near full tanks prior to this critical period is desired. Prudent planning would dictate
9 that tanks ought to be filled in such a fashion as to be able to meet anticipated fuel
10 consumption demands in the event of an ice blockage. Please also refer to the
11 response to IC-NLH-17.