

1 Q. Refurbishment of the Fuel Oil Storage Facility, Holyrood Thermal Generating
2 Station

3 Over the period from 1990 to 2010, on how many occasions, and for what periods
4 of time, has tanker supply actually been interrupted as a result of the blockage of
5 Conception Bay by ice?
6
7

8 A. Tanker supply has not been interrupted as a result of the blockage of Conception
9 Bay by ice over the period from 1990 to 2010. For a fuller discussion of the issues
10 related to ice blockage and tanker traffic, please refer to Hydro's response to IC-
11 NLH-17.