
Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Tuesday, June 06, 2023

Section 1 Island Interconnected System Supply, Demand & Exports Actual 24 Hour System Performance For Monday, June 05, 2023



Supply Notes For June 05, 2023

1,2

- As of 0701 hours, March 06, 2023, Upper Salmon Unit unavailable due to planned outage (84 MW).
- As of 0006 hours, April 09, 2023, Holyrood Unit 3 unavailable due to planned outage (150 MW).
- As of 1600 hours, May 15, 2023, Holyrood Unit 1 available but not operating (170 MW).
- As of 0800 hours, May 21, 2023, Holyrood Unit 2 unavailable due to planned outage (170 MW).
- As of 1751 hours, May 24, 2023, Bay d'Espoir Unit 5 unavailable due to planned outage (76.5 MW).
- F As of 1751 hours, May 24, 2023, Bay d'Espoir Unit 6 unavailable due to planned outage (76.5 MW).
- At 0800 hours, June 05, 2023, Stephenville Gas Turbine available at 25 MW (50 MW).
- At 1630 hours, June 05, 2023, Stephenville Gas Turbine available at full capacity (50 MW).

Section 2

Island Interconnected Supply and Demand

Tue, Jun 06, 2023	Island System Outlook ³		Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
				Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	1,525	MW	Tuesday, June 6, 2023	6	7	1,075	1,075
NLH Island Generation: ^{4,8}	965	MW	Wednesday, June 7, 2023	8	10	815	815
NLH Island Power Purchases: ⁶	155	MW	Thursday, June 8, 2023	12	11	795	795
Other Island Generation:	205	MW	Friday, June 9, 2023	8	8	845	845
ML/LIL Imports:	200	MW	Saturday, June 10, 2023	13	11	770	770
Current St. John's Temperature & Windchill:	6 °C N/A	°C	Sunday, June 11, 2023	11	11	780	780
7-Day Island Peak Demand Forecast:	1,075	MW	Monday, June 12, 2023	12	13	800	800

Supply Notes For June 06, 2023

Notes:

- 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
- 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
- 3. As of 0800 Hours.
- 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
- 5. Gross output from all Island sources (including Note 4).
- 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
- 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.
- 8. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak							
Mon, Jun 05, 2023	Actual Island Peak Demand ⁹	8:10	1,077 MW				
Tue, Jun 06, 2023	Forecast Island Peak Demand		1,075 MW				

Notes: 9. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).