
Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Friday, August 16, 2024

Section 1 Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Thursday, August 15, 2024



Island Supply Notes For August 15, 2024

- As of 2059 hours, July 13, 2023, Stephenville Gas Turbine unavailable due to forced outage (50 MW).
- B As of 1011 hours, April 12, 2024, Holyrood Unit 1 unavailable due to planned outage (170 MW).
- C As of 0700 hours, May 26, 2024, Holyrood Unit 3 unavailable due to planned outage (150 MW).
- As of 1856 hours, July 04, 2024, Bay d'Espoir Unit 6 unavailable due to planned outage (76.5 MW).
- As of 0652 hours, July 31, 2024, Labrador Island Link unavailable due to planned outage (700 MW).
- As of 10032 flours, July 31, 2024, Labrador Island Link dilavallable due to planned outage (700 MW).

 As of 1047 hours, August 02, 2024, Paradise River Unit unavailable due to forced outage (8 MW).
- As of 0800 hours, August 04, 2024, Holyrood Unit 2 unavailable due to planned outage (170 MW).
- H As of 0800 hours, August 11, 2024, Bay d'Espoir Unit 4 unavailable due to planned outage (76.5 MW).
 - At 1647 hours, August 15, 2024, Bay d'Espoir Unit 7 available (154.4 MW).

Section 2

Island Interconnected System - Supply, Demand & Outlook

Fri, Aug 16, 2024	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴	1,235 MW	Friday, August 16, 2024	755	705
NLH Island Generation: ^{3,7}	990 MW	Saturday, August 17, 2024	690	640
NLH Island Power Purchases:5	75 MW	Sunday, August 18, 2024	740	690
NP and CBPP Owned Generation:	170 MW	Monday, August 19, 2024	790	740
LIL Net Imports to Island: ⁹	- MW	Tuesday, August 20, 2024	800	750
		Wednesday, August 21, 2024	770	720
7-Day Island Peak Demand Forecast:	800 MW	Thursday, August 22, 2024	765	715

Island Supply Notes For August 16, 2024

otes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

- 2. As of 0800 Hours.
- 3. Gross continuous unit output.
- 4. Gross output from all Island sources (including Note 4).
- 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
- 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
- 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
- 8. Does not include ML Exports.
- 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak					
Thu, Aug 15, 2024	Island Peak Demand ¹⁰	16:55	732 MW		
	Exports at Peak		0 MW		
	LIL Net Imports to Island		0 MWh		
Fri, Aug 16, 2024	Forecast Island Peak Demand		755 MW		

Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).