


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, January 06, 2025

Section 1 Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Friday, January 03, 2025



Island Supply Notes For January 03, 2025

A As of 0000 hours, October 20, 2024, Holyrood Unit 1 unavailable due to forced extension to planned outage (170 MW).

Section 2 Island Interconnected System - Supply, Demand & Outlook

Sat, Jan 04, 2025	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴ NLH Island Generation: ^{3,7} NLH Island Power Purchases: ⁵ NP and CBPP Owned Generation: LIL/ML Net Imports to Island: ⁹	1,860 MW 1,525 MW 120 MW 210 MW 5 MW	Saturday, January 4, 2025	1,265	1,170
		Sunday, January 5, 2025	1,295	1,200
		Monday, January 6, 2025	1,330	1,235
		Tuesday, January 7, 2025	1,300	1,205
		Wednesday, January 8, 2025	1,315	1,220
		Thursday, January 9, 2025	1,365	1,269
		Friday, January 10, 2025	1,285	1,190
7-Day Island Peak Demand Forecast:	1,365 MW			

Island Supply Notes For January 04, 2025

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. As of 0800 Hours.
 3. Gross continuous unit output.
 4. Gross output from all Island sources (including Note 4).
 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
 8. Does not include ML Exports.
 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak

Fri, Jan 03, 2025	Island Peak Demand ¹⁰	17:40	1,222 MW
	Exports at Peak		276 MW
	LIL Net Imports to Island		4,322 MWh
Sat, Jan 04, 2025	Forecast Island Peak Demand		1,265 MW

Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).