


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, September 08, 2025

Section 1 Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Friday, September 05, 2025



Island Supply Notes For September 05, 2025 ¹

- A As of 0800 hours, March 30, 2025, Holyrood Unit 3 unavailable due to planned outage 130 MW (150 MW).
- B As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 1 unavailable due to planned outage (76.5 MW).
- C As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 2 unavailable due to planned outage (76.5 MW).
- D As of 0800 hours, May 04, 2025, Holyrood Unit 1 unavailable due to planned outage (170 MW).
- E As of 0800 hours, June 08, 2025, Holyrood Unit 2 unavailable due to planned outage 115 MW (170 MW).
- F As of 1400 hours, June 29, 2025, St. Anthony Diesel Plant available at 7.7 MW due to forced derating (9.7 MW).
- G As of 1439 hours, August 27, 2025, Upper Salmon Unit unavailable due to planned outage (84 MW).
- H As of 0751 hours, September 02, 2025, Stephenville Gas Turbine unavailable due to planned outage (50 MW).
- I **At 0519 hours, September 05, 2025, Bay d'Espoir Unit 6 unavailable due to planned outage (76.5 MW).**
- J **At 1458 hours, September 05, 2025, Cat Arm Unit 1 available (67 MW).**
- K **At 1813 hours, September 05, 2025, Bay d'Espoir Unit 6 available (76.5 MW).**

Section 2 Island Interconnected System - Supply, Demand & Outlook

Sat, Sep 06, 2025	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴	1,284 MW	Saturday, September 6, 2025	650	600
NLH Island Generation: ^{3,7}	915 MW	Sunday, September 7, 2025	625	575
NLH Island Power Purchases: ⁵	70 MW	Monday, September 8, 2025	780	730
NP and CBPP Owned Generation:	100 MW	Tuesday, September 9, 2025	745	695
LIL/ML Net Imports to Island: ⁹	199 MW	Wednesday, September 10, 2025	755	705
		Thursday, September 11, 2025	760	710
7-Day Island Peak Demand Forecast:	780 MW	Friday, September 12, 2025	755	705

Island Supply Notes For September 06, 2025

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. As of 0800 Hours.
 3. Gross continuous unit output.
 4. Gross output from all Island sources (including Note 3).
 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
 8. Does not include ML Exports.
 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak

Fri, Sep 05, 2025	Island Peak Demand ¹⁰	17:00	610 MW
	Exports at Peak		212 MW
	LIL Net Imports to Island		5,086 MWh
Sat, Sep 06, 2025	Forecast Island Peak Demand		650 MW

- Notes:
10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).