

1 Q. Reference: Teshmont Report - Section 7 – Conclusion (pg 39):

2 *“Analysis of 230 kV transmission line outages on the Island Interconnected System*
3 *delivered a comparison between ac transmission system reliability in the Pre- and*
4 *Post-HVDC cases. The expected unserved energy due to 230 kV transmission line*
5 *contingencies in the Pre-HVDC case were calculated to equal 100.8 MWh/year. Of*
6 *that total 41.43 MWh/year is attributed to the loss of TL208, and 58.03*
7 *MWh/year attributed to the loss of TL242. With approved transmission system*
8 *upgrades, including the replacement of TL266, the expected unserved energy due*
9 *to 230 kV transmission line contingencies in the Post-HVDC case is reduced to*
10 *41.94 MWh/year attributed to the loss of TL208. The analysis concludes that*
11 *based on a probabilistic reliability assessment, the reliability of the 230 kV*
12 *transmission system on the Island Interconnected System is improved in the Post-*
13 *HVDC case compared to the Pre-HVDC case.”*

14 Referencing IEC 60826 at page 127 which states:

15 **60826 © IEC:2003**

16 *“It is suggested to use a reliability level characterized by return periods of 150*
17 *years for lines above 230 kV. The same is suggested for lines below 230 kV*
18 *which constitute the principal or perhaps the only source of supply to a*
19 *particular electric load (level 2).*

20 *Finally, it is suggested to use a reliability level characterised by return periods*
21 *of 500 years for lines, mainly above 230 kV which constitute the principal or*
22 *perhaps the only source of supply to a particular electric load. Their failure*
23 *would have serious consequences to the power supply.”*

24 If a 1:50 year return period was used for comparison, yet IEC recommends using
25 1:150 return period (IEC 60826 Page 127), isn't this analysis inconsistent from a
26 reliability perspective?

1 A. TL208 is a specifically-assigned radial 230 kV transmission line that supplies
2 industrial customers Vale Newfoundland & Labrador Limited and Praxair Canada
3 Inc. and these customers are responsible for all costs associated with this line. The
4 ac interconnection via TL208 was developed in consultations with the customers
5 and in an effort to manage cost; they specified that the interconnection shall
6 employ the single transmission line that was used to supply the previous industrial
7 customer in the area.