

- 1 **Q: In the event that the LIL and/or ML was used to solve the pre-Muskrat Falls**
2 **supply issue, please comment on what (if any) new opportunities might this**
3 **provide for Hydro to establish effective mitigation to address extended outages**
4 **of the LIL post-Muskrat Falls?**
5
6
- 7 A. The use of recall power is of no help in post-Muskrat Falls outage mitigation since it
8 is assumed that, with the Labrador Island Link tripped, there is no access to that
9 power. Any capacity available from Nova Scotia post Muskrat Falls would
10 presumably be helpful, and in fact the IIS will be relying on it unless additional
11 generation is installed in the IIS. This is true whether such capacity was available
12 pre- Muskrat Falls or not.