

1 Q. The responses to Requests for Information PUB-NLH-2017 and GRK-NLH-068
2 describe in general how the system will be designed to respond to a permanent
3 bipole failure. Please provide any design criteria that will be used to design the
4 system to respond to a bipole failure. In the response please provide the following
5 information:

- 6 1) Initial design estimates for the time from bipole failure to restoring supply in
7 accordance with the 22 corrective actions outlined in Table 16 of the Teshmont
8 Report.
- 9 2) Whether the level of exports will be managed to limit exposure to customers
10 from load shedding for potential bipole failures.
- 11 3) Whether there is a limit to the amount of load shed beyond which there is
12 potential for a shut-down of the total island interconnected system.
- 13 4) The extent to which the total load requirements on the island will impact the
14 time required to restore supply.
- 15 5) The extent to which the duration of the repair to a bipole failure might impact
16 the time required to restore supply.
- 17 6) Whether the load shedding scheme will require a greater portion of the load on
18 the Avalon Peninsula to be shed than on the rest of the island interconnected
19 system.
- 20 7) Any considerations given to potential cold load pickup issues in designing the
21 system response.

- 22
- 23
- 24 A. The system response in the event of a bipole failure is summarized as follows:
25 1) Initial design estimates for the time from bipole failure to restoring supply in
26 accordance with the 22 corrective actions outlined in Table 16 of the
27 Teshmont Report.

1 Please see Hydro's response to PUB-NLH-617 for discussion relating to these
2 time requirements.

3

4 2) Whether the level of exports will be managed to limit exposure to
5 customers from load shedding for potential bipole failures.

6

7 In the event of a contingency involving the Labrador Island Link, exports
8 over the Maritime Link would be curtailed to avoid under frequency load
9 shedding within the IIS. The coordination of import from Labrador and
10 export to Nova Scotia therefore ensures compliance with Hydro's
11 Transmission Planning Criteria. This coordinated operation also ensures that
12 load shed is minimized in the event of a permanent bipole failure.

13

14 It should also be noted that dispatch over the HVdc links would be limited
15 under adverse conditions such as lightning, in accordance with good utility
16 practice.

17

18 3) Whether there is a limit to the amount of load shed beyond which there is
19 potential for a shut-down of the total island interconnected system.

20

21 Please see Hydro's response to PUB-NLH-569 from Phase I of the Island
22 Interconnected System Supply Issues and Power Outages for discussion
23 relating to requirements for controlled load shed.

24

25 4) The extent to which the total load requirements on the island will impact
26 the time required to restore supply.

1 Load restoration time would be a function of the amount of load shed and
2 the capacity shortfall before backup generation is brought online. Hydro's
3 operating procedures are such that adequate reserve levels must be
4 maintained during all loading conditions. These reserve levels would help to
5 minimize restoration times throughout the year. Details relating to the
6 worst case capacity shortfall would be in accordance with Hydro's response
7 to PUB-NLH-617.

8

9 5) The extent to which the duration of the repair to a bipole failure might
10 impact the time required to restore supply.

11

12 Hydro's Transmission Planning Criteria are such that there shall be no under
13 frequency load shedding for the temporary loss of a bipole. In the event of
14 the permanent loss of the Labrador Island Link, restoration procedures shall
15 be in accordance with Hydro's response to PUB-NLH-617. If the Labrador
16 Island Link can be restored before other sources of backup generation are
17 brought online, the additional capacity would allow for load restoration to
18 be accelerated.

19

20 6) Whether the load shedding scheme will require a greater portion of the load
21 on the Avalon Peninsula to be shed than on the rest of the island
22 interconnected system.

23

24 Hydro's future under frequency load shedding scheme will be designed in a
25 study to be completed in 2016/2017. This consideration will be addressed in
26 this study.

- 1 7) Any considerations given to potential cold load pickup issues in designing
2 the system response.

3

4 The work completed by Hydro in the under frequency load shedding study
5 discussed above will help to minimize cold load pickup issues. The analysis
6 will involve the design of a scheme where load shed is minimized and the
7 loss of generator synchronism is avoided.

8

9 As stated above, Hydro must maintain adequate reserve levels. By also
10 ensuring that equipment such as the synchronous condensers at Soldiers
11 Pond Terminals Station remain online following the loss of the bipole, the
12 availability of dynamic voltage support will further facilitate the restoration
13 process.

14

15 Upon completion of the under frequency load shedding study, Hydro will
16 work in cooperation with Newfoundland Power to implement an effective
17 under frequency load shedding scheme that will minimize customer impact.