

1 Q. **Asset Management**

2 Further to the response to PUB-NLH-087 provide the number of transmission line
 3 inspections and the number of Wood Pole Line Management (WPLM) inspections
 4 scheduled, and the numbers completed, each year 2011 through 2013.

5
 6

7 A. The number of inspections scheduled and the number of inspections completed are
 8 outlined below:

9

WPLM Wood Pole Inspections		
	Scheduled	Completed
2011	1659	1659
2012	1286	1286
2013	2070	2070

Steel Structure Inspections* (PM's)		
	Scheduled	Completed
2011	44	44
2012	43	43
2013	45	45

* Each individual steel structure PM inspection includes either a ground inspection or a climbing inspection on 10% of a given transmission line