

1 Q. Reference PUB-NLH-265: Does Hydro believe that a wide range of the rate of  
2 frequency change would complicate the design of the protection, or make the  
3 design of the protection easier? Please explain your answer in detail.

4

5

6 A. The application of rate of change of frequency (df/dt) relaying as part of an Under  
7 Frequency Load Shedding (UFLS) scheme has both advantages and disadvantages.  
8 Perhaps one of the bigger advantages is that for sudden loss of a relatively large  
9 amount of generation resulting in a significant df/dt, application of an appropriate  
10 df/dt relay setting can be used to quickly trip load to arrest the system frequency  
11 decay prior to governor action which, in turn, permits governor action to recover  
12 system frequency in a timely manner, and thereby reduce the overall magnitude of  
13 load that would otherwise be shed for the event.

14

15 Comparatively, systems with significant amounts of thermal generation may  
16 respond to frequency changes quicker than systems with significant amount of  
17 hydro-electric generation given the inherent delays introduced by the water start  
18 times associated with hydro-electric turbines. As a result, a df/dt relay based UFLS  
19 scheme can be of benefit for hydro-electric based systems. For example, a review  
20 of the Northeast Power Coordinating Council (NPCC) Directory 12 *Under Frequency*  
21 *Load Shedding Program Requirements* dated July 9, 2013, indicates that each  
22 Balancing Authority in the NPCC portion of the Eastern Interconnection with 100  
23 MW or more of end user load will have five threshold stages of under frequency  
24 load shedding blocks. Four of these blocks must trip within 300 ms and one block is  
25 an anti-stall block that must trip in 10 s. There is no df/dt relaying. However, the  
26 directory also indicates that the Balancing Authority in the Québec Interconnection  
27 UFLS program consists of five threshold stages and four df/dt stages of load

1 shedding blocks. Four of the Québec Interconnection threshold blocks must trip in  
 2 300 ms and one anti-stall block must trip in 20 s. Table 1 provides a comparison of  
 3 the UFLS programs for NPCC portion of the Eastern Interconnection, the Québec  
 4 Interconnection and the existing Island Interconnected System.

| Table 1<br>Comparison of Existing Under Frequency Load Shedding Programs |   |          |        |   |                   |                |        |   |                   |           |        |
|--|---|----------|--------|---|-------------------|----------------|--------|---|-------------------|-----------|--------|
|  | NPCC Portion of Eastern Interconnection<br>~ 118,000 MW Installed<br>1250 MW contingency (NE)<br>with no load loss<br>Minimum frequency 58.0 Hz |          |        | Québec Interconnection<br>~ 45,000 MW Installed<br>1000 MW loss 1 <sup>st</sup> contingency<br>with no load loss<br>Minimum frequency 56.0 Hz |                   |                |        | Existing Island Interconnection<br>~ 1900 MW Installed<br>170 MW loss 1 <sup>st</sup> contingency<br>with load loss<br>Target Min Frequency 58.0 Hz |                   |           |        |
| Stage  | System Freq. (Hz)   | Load (%) | Time   | df/dt (Hz/s)  | System Freq. (Hz) | Load MW & MVAR | Time   | df/dt (Hz/s)  | System Freq. (Hz) | Load (MW) | Time   |
| 1  | 59.5  | 6.5-7.5  | 300 ms | -   | 58.5              | 1000           | 300 ms | -   | 58.8              | 40        | 100 ms |
| 2  | 59.3  | 6.5-7.5  | 300 ms | -   | 58.0              | 800            | 300 ms | -   | 58.6              | 43        | 100 ms |
| 3  | 59.1  | 6.5-7.5  | 300 ms | -   | 57.5              | 800            | 300 ms | -   | 58.4              | 50        | 100 ms |
| 4  | 58.9  | 6.5-7.5  | 300 ms | -   | 57.0              | 800            | 300 ms | -   | 58.2              | 60        | 100 ms |
| 5  | 59.5  | 2-3      | 10 s   | -   | 59.0              | 500            | 20 s   | -   | 58.1              | 90        | 100 ms |
| 6  | -   | -        | -      | -   | -                 | -              | -      | -   | 58.0              | 159       | 100 ms |
| 7  | -   | -        | -      | -   | -                 | -              | -      | -   | 59.0              | 40        | 15 s   |
| 1  | -   | -        | -      | -0.3  | 58.5              | 400            | 300 ms | -0.5  | 59.5              | 10        | 100 ms |
| 2  | -   | -        | -      | -0.4  | 59.8              | 400            | 300 ms | -0.6  | 59.5              | 20        | 100 ms |
| 3  | -   | -        | -      | -0.6  | 59.8              | 400            | 300 ms | -0.7  | 59.5              | 30        | 100 ms |
| 4  | -   | -        | -      | -0.9  | 59.8              | 800            | 300 ms | -   | -                 | -         | -      |

Notes

Eastern Interconnection including Québec has installed capacity of approximately 610,000 MW

NE – New England

6.5 – 7.5% of NPCC load equates to approx. 4800 – 5500 MW for entire NPCC Portion of Eastern Interconnection 2015-16 peak load forecast of approx. 73,490 MW (non coincident). Quebec Interconnection forecast 2015-2016 peak load approx.. 38,200 MW. Data from **Northeast Power Coordinating Council Reliability Assessment For Winter 2015-16 FINAL REPORT Approved by the RCC December 1, 2015** ([www.npcc.org](http://www.npcc.org))

Existing Island Interconnected System ULFS relays are set to trip instantaneously except the 59.0 Hz block with a 15 second time delay. Instantaneous relay operation is considered to be 100 msec or 6 cycles, one cycle for relay and 5 cycles for the circuit breaker.

1 The review of the NPCC Directory 12 also provides insight into the acceptability of  
2 frequency excursion. The NPCC portion of the Eastern Interconnection (substantial  
3 thermal generation) requires that frequency decline is arrested at no less than 58.0  
4 Hz, that the frequency does not remain below 58.5 Hz for more than 10 seconds  
5 and that the frequency does not remain below 59.5 Hz for more than 30 seconds.  
6 By comparison, the Québec Interconnection (predominantly hydro-electric)  
7 requires that the frequency decline is arrested at no less than 56.0 Hz, that the  
8 frequency does not remain below 58.5 Hz for more than 10 seconds and that the  
9 frequency does not remain below 59.5 Hz for more than 30 seconds. It is Hydro's  
10 belief that the additional frequency deviation permitted in the Québec  
11 Interconnection before arresting is due in part to the relative sizes of the Eastern  
12 Interconnection and the Québec Interconnection, the "slower" response times of  
13 hydro-electric versus thermal, and the ability of hydro-electric generators to  
14 withstand larger frequency deviations than higher speed thermal units. Hydro's  
15 existing UFLS stage at 59.0 Hz with a 15 second time delay is meant to trip load to  
16 push the frequency above 59 Hz to prevent damage to Holyrood thermal units due  
17 to off nominal speed operation.

18  
19 Perhaps one of the bigger disadvantages of the application of  $df/dt$  relaying can be  
20 found in relatively small grids. In smaller grids with limited inertia, a high  
21 impedance transmission line fault can appear as a substantial increase in system  
22 load that may last longer than a typical line fault. Having too low a  $df/dt$  setting (i.e.  
23 0.2 Hz/s as opposed to 0.9 Hz/s) can result in a false trip of the load shedding block  
24 as the load increase and sudden frequency decay may cause the  $df/dt$  relay to pick  
25 up and trip the circuit breaker. Consequently careful coordination between the  
26  $df/dt$  relay settings (i.e. frequency set point and rate of change), the available  
27 system inertia to maintain frequency for the generation loss and the governor

1 reaction time is required. To this end, a large number of  $df/dt$  stages over a large  
2 range of rate of change settings may be difficult to coordinate to ensure proper  
3 response to a multitude of generation loss scenarios over a wide range of system  
4 operating conditions.

5

6 A practicable application of  $df/dt$  relaying for the Island Interconnected System post  
7 LIL, given the system size and HVdc connections, may be to limit use to the very  
8 severe generation losses such as permanent bipole outage or complete loss of Bay  
9 d'Espoir plant at 600 MW, where the rate of change of frequency will be quite  
10 dramatic. This would leave the traditional threshold stages at set frequencies to  
11 respond for the less severe generation losses (i.e. loss of four units at Bay d'Espoir  
12 for a fault on a 230 kV bus followed by stuck breaker – up to 300 MW loss).

13

14 The impact of  $df/dt$  application is dependent, in part, on the governor response due  
15 to the water start times of the hydro-electric generators providing frequency  
16 control versus thermal units in combination with the amount of system inertia and  
17 the relative sizes of generation loss to inertia impact.