

1 Q. Further to PUB-NLH-617, does Hydro agree with Teshmont's estimate of the
2 Expected Unserved Energy value?

3

4

5 A. Hydro's assessment of the Teshmont analysis is that the report is primarily
6 concerned with the relative performance of the IIS in the Post-HVdc scenario as
7 compared to the Pre-HVdc scenario. Due to the methodology and assumptions used
8 in the analysis, it is Hydro's opinion that the results provide a reasonable
9 comparison of system performance, but should not be used as an indication of the
10 absolute expected unserved energy.

11

12 The Teshmont analysis was initiated in 2014 and some assumptions have since
13 changed. These assumptions relate to IIS demand, gross continuous unit ratings,
14 and capacity assistance arrangements, as per Hydro's response to PUB-NLH-615. It
15 was determined that it was not necessary to redo the analysis with these updated
16 parameters due to the fact that the assumptions were consistently applied to both
17 the Pre-HVdc and Post-HVdc scenarios. Changing the assumptions would therefore
18 not have an appreciable impact on the relative comparison performed in the
19 analysis. However, these variations would impact the absolute value of expected
20 unserved energy calculated in the analysis.

21

22 With respect to methodology, the calculation of expected unserved energy
23 performed in the Teshmont analysis was based on the unavailability of system
24 elements and load curtailment requirements at peak. Teshmont then reviewed load
25 duration curves for the system and identified periods during which there would be
26 an exposure for unserved load. This is in contrast to the Energy Supply Risk
27 Assessment, which involved an hour by hour summation of unserved energy based

1 on load shape and the capacity impacts of probabilistic outage rates. The
2 differences in these techniques are subtle, but it is Hydro's view that that both are
3 appropriate for their respective purposes. For the Teshmont study, a complex
4 analysis involving several system components was used to perform a relative
5 reliability comparison for two systems. For Hydro's Energy Supply Risk Assessment,
6 the analysis focused on the impact of specific units to determine an accurate
7 estimate of expected unserved energy.

8

9 It is also noted that the Teshmont analysis involved the calculation of expected
10 unserved energy on the basis that the performance of the Labrador Island Link
11 would be equivalent to a typical HVdc system. Consideration of design aspects such
12 as the robustness of the transmission towers or specific performance guarantees¹
13 were beyond the scope of the study.

¹ Please see Hydro's response to PUB-NLH-616 for discussion relating to performance guarantees for the converter stations.