

1 **Q. Please describe Newfoundland Power’s transmission system planning policy,**  
2 **3 criterion and process. Include in the response the numbers and titles of personnel**  
3 **involved with the transmission planning process.**

4  
5 **A. Terminology**

6  
7 Newfoundland Power does not use the terms “transmission” and “subtransmission” to  
8 differentiate portions of its transmission system. Newfoundland Power uses the terms  
9 “transmission system” or “transmission line” to refer to the parts of its electrical system  
10 that transmit electricity from the infeed points of the Newfoundland and Labrador Hydro  
11 (“Hydro”) bulk electricity grid, or from its own generation sources, to Newfoundland  
12 Power’s distribution substations.

13  
14 Accordingly, the following is Newfoundland Power’s single response to Requests for  
15 Information PUB-NP-155 and PUB-NP-156.

16  
17 **General**

18  
19 Newfoundland Power operates a transmission system that comprises 104 transmission  
20 lines with a combined total length of 2,062 kilometres, together with the associated line  
21 terminations and substation transformers. Newfoundland Power’s transmission system  
22 operates primarily at voltages of 66 kV and 138 kV, with a very limited portion operating  
23 at 33 kV for legacy reasons.

24  
25 The general objective of Newfoundland Power’s transmission planning is to ensure that  
26 its transmission system operates in a safe, reliable and cost-effective manner. Proper  
27 planning ensures the transmission system is able to supply the aggregate electricity  
28 requirements of consumers at all times, taking into account expected future load growth  
29 and scheduled, and reasonably expected unscheduled, outages of system components.

30  
31 The Company maintains models of the electricity system that enable it to analyze and  
32 evaluate its transmission system. These models are used in forward-looking planning  
33 studies and also for operational planning.<sup>1</sup>

34  
35 Planning requires both engineering analysis of different electricity system configurations  
36 and economic analysis of alternatives. It also requires the application of engineering  
37 standards, judgement and experience.

38  
39 In planning and monitoring the capability of its transmission system, Newfoundland  
40 Power applies criteria for both voltage and current (or capacity). The various

---

<sup>1</sup> Operational planning involves analysis of short-term or temporary system configurations.

1 components of the transmission system are monitored on an ongoing basis with reference  
2 to these criteria, and any issues identified are addressed as appropriate.  
3

4 In addition to considering the capability of its transmission system relative to the  
5 applicable voltage and capacity criteria, Newfoundland Power also considers the extent to  
6 which service reliability concerns may require that redundant capacity be incorporated  
7 into its transmission system.  
8

### 9 **Planning Criteria**

#### 10 ***Voltage Criteria***

11 The voltage criteria used by Newfoundland Power for system planning purposes are  
12 based on limits prescribed in the Canadian Standards Association (“CSA”) standard CSA  
13 *CAN3-C235 – Preferred Voltage Levels for AC Systems, 0 to 50,000V*.<sup>2</sup> The CSA  
14 standard includes recommended voltage variation limits for circuits up to 1,000V at  
15 service entrances, and recommended voltage variation limits at point of sale and purchase  
16 for circuits between 1,000V and 50,000V. The voltage limits are defined for both normal  
17 and extreme operating conditions.  
18

19 Newfoundland Power applies these voltage criteria to ensure that the quality of the  
20 electricity provided to the customer is within acceptable limits. Essentially, voltages on  
21 transmission lines are managed so as to ensure that the specified criteria are met on the  
22 downstream distribution lines.  
23

#### 24 ***Capacity Criteria***

25 Capacity criteria for Newfoundland Power’s transmission system ensure that current  
26 levels on the transmission system under specific operating conditions do not exceed the  
27 thermal loading limits of the various components of the system. The major components  
28 of Newfoundland Power’s transmission system are the transmission lines and the  
29 substation transformers.  
30

31 For transmission lines, the capacity criteria are determined through the analytical  
32 methods outlined in the standard *CSA C22.3 No.1 – Overhead Systems*.  
33

34 Newfoundland Power’s conductor capacity (ampacity) planning criteria are based on  
35 maximum allowable conductor temperatures expected under normal seasonal ambient  
36 temperature and wind conditions. For substation transformers, the capacity planning  
37 criterion is set at the nameplate rating of the transformer. These criteria are sufficiently  
38

---

<sup>2</sup> Section 4.1 of the *Public Utilities Act* provides that voltages at the customer’s terminals shall not exceed four per centum from declared constant voltages. In 1994, the Board approved the use of CSA No. CAN3-C235-83 for determining allowed voltage levels.

1 conservative to allow for the effects of equipment aging, and for such reasonably  
2 anticipated abnormal conditions as extreme peaks and cold-load pick-up.<sup>3</sup>

### 3 4 ***Reliability Considerations***

5 Newfoundland Power's transmission system connects the Company's distribution  
6 substations to the delivery points where the system is connected to Hydro's 230 kV bulk  
7 power grid. Newfoundland Power's transmission lines are not part of the 230 kV bulk  
8 power grid.

9  
10 The transmission lines on the 230 kV grid are critical to the overall security of the Island  
11 Interconnected System.<sup>4</sup> For that reason, the 230 kV grid is designed to ensure that the  
12 loss of any single transmission line will not result in a power interruption to customers.  
13 Newfoundland Power's transmission lines are not designed to meet the same reliability  
14 criteria.

15  
16 Newfoundland Power's transmission system planning incorporates engineering  
17 judgments that seek to achieve a reasonable balance between cost of supply and  
18 reliability of service. This results in differing levels of redundancy for different  
19 transmission lines.<sup>5</sup>

### 20 21 **Planning Process**

#### 22 23 ***General***

24 Newfoundland Power's transmission system planning process involves the monitoring  
25 and forecasting of power flows and voltages on the transmission system to identify  
26 deficiencies. When deficiencies are identified engineering studies are carried out to  
27 develop appropriate solutions.

28  
29 Newfoundland Power's transmission system planners use a model to simulate system  
30 performance under various conditions to ensure compliance with the defined voltage and  
31 capacity criteria.

32  
33 The model incorporates the electrical characteristics of each major system component  
34 including transmission lines, power transformers, generators, and voltage regulating  
35 equipment.

---

<sup>3</sup> For detailed information on conductor capacity criteria, see the Response to Request for Information PUB-NP-146. For detailed information on substation transformer capacity criteria, see the response to Request for Information PUB-NP-145.

<sup>4</sup> The 230 kV grid consists of the high voltage transmission lines that tie all of Hydro's major generation sources on the island of Newfoundland to the major load centres. The 230 kV grid extends from Stephenville and Corner Brook on the west coast of the island to St. John's on the east coast.

<sup>5</sup> Where limited redundancy exists, the Company's fixed generation, mobile generation, and mobile substation equipment provides support during extended transmission outages and major transmission rebuilds and upgrades.

1 The model is used to evaluate system performance through load-flow analysis and short  
2 circuit analysis.

### 3 ***Load-flow Analysis***

4 The load-flow analysis is completed for a specific point in time, which is typically the  
5 time of expected winter peak demand. The base case includes conditions as they are  
6 expected to exist at that time, including consideration of anticipated additions and  
7 retirements. Generation and loads are set at their expected levels at each bus. The model  
8 is run to determine (i) the flows in each line and transformer and (ii) the voltages at each  
9 bus. These values are examined to assure that no bus voltage is outside its acceptable  
10 operating range and that no line current flow exceeds the applicable criteria.

### 11 ***Short Circuit Analysis***

12 Short circuit modeling is used to help design the system-protection equipment and to  
13 assure that circuit breakers are capable of withstanding and interrupting the largest  
14 possible fault, or short-circuit current.

15 Short circuit analysis determines how much fault current might flow at each node in the  
16 grid if a short circuit occurs. This information is important because excessive fault  
17 current can damage equipment and pose a safety hazard to workers.

18 Short circuit studies are done for three reasons: (i) to make sure any change to the system,  
19 for example adding a generator, reconfiguring lines, or changing a transformer, does not  
20 raise fault currents above the interrupting capability of the existing circuit breakers; (ii) to  
21 tell the designers of new substation equipment what size breakers are needed at that  
22 location; and (iii) to provide information for setting protective relays.

### 23 ***Other Inputs***

24 In addition to the results of load-flow analysis and short circuit modeling, the load  
25 forecasts prepared in conjunction with the development of the Company's annual capital  
26 budgets are considered in relation to the capacity of existing substation transformers to  
27 meet forecast peak loads.

28 Newfoundland Power also completes periodic voltage regulation studies to ensure the  
29 transmission system continues to be capable of delivering voltages within the prescribed  
30 voltage criteria.

31 Voltages on the transmission system are monitored in real time by the Company's  
32 Supervisory Control and Data Acquisition ("SCADA") system. Transducers and digital  
33 protective relays transmit information about voltages at individual substation  
34 transmission and distribution busses to the SCADA system. Voltage values are  
35 continuously monitored and compared to the high and low voltage limits. In addition to  
36

1 providing an alarm at the Control Centre where a violation of a voltage limit merits  
2 immediate attention, the voltage data is also archived for future analysis.

### 3 4 ***Planning Studies***

5 In addition to ongoing monitoring, forecasting and system modeling, Newfoundland  
6 Power conducts transmission planning studies as required. Studies are carried out  
7 primarily to assess the impact of load growth, aging infrastructure and the addition of  
8 new generation sources to the electricity system.

9  
10 Newfoundland Power's system load growth has averaged approximately 1.7% annually  
11 over the past 10 years. Load growth has not resulted in a requirement for any new  
12 transmission lines during that period.<sup>6</sup> Over the same period, however, load growth has  
13 resulted in several capacity additions to the Company's substations.<sup>7</sup>

14  
15 Newfoundland Power completes an annual review of its aging transmission lines. The  
16 results of this review are considered as part of the Company's capital budgeting process,  
17 and regularly documented in capital budget filings. When necessary, a more detailed  
18 study will be carried out to determine the best approach to rebuilding a transmission line.<sup>8</sup>

19  
20 In 2008, two wind generation farms were connected to Newfoundland Power's  
21 transmission system. The interconnection of these new generation sources necessitated a  
22 technical analysis of Newfoundland Power's transmission system. The results of load-  
23 flow analysis related to the interconnection of the Fermeuse wind farm were subsequently  
24 included in a review of the ground clearances on transmission line 24L, and resulted in  
25 upgrades to increase ground clearances in specific locations along the transmission line.<sup>9</sup>

### 26 27 **Personnel**

28  
29 Overall responsibility for transmission system planning at Newfoundland Power rests  
30 with the Electrical Engineering section of the Company's Engineering Department.  
31 Ongoing planning activities are coordinated by the System Planning Engineer, supported  
32 by a Senior Electrical Engineer, two Engineering Technologists and engineering work-  
33 term students. Additional support is provided by the Supervisor, Distribution  
34 Engineering and Standards.

---

<sup>6</sup> The last addition to Newfoundland Power's transmission system related to load growth was the construction in 1993 of transmission line 70L between Oxen Pond and Stamp's Lane Substations in St. John's.

<sup>7</sup> For example, the report *2014 Additions Due to Load Growth*, filed as part of the Company's 2014 Capital Budget Application, recommended the addition of transformer capacity at Hardwoods, Bay Roberts and Marble Mountain substations.

<sup>8</sup> For example, the report *Bonavista Loop Transmission Planning*, filed as part of the Company's 2006 Capital Budget Application, considered the replacement of transmission lines on the Bonavista Peninsula.

<sup>9</sup> The conductor ampacity analysis included a forecast of expected conductor currents from which a forecast of conductor operating temperatures was developed. Analysis of the effect of the forecast conductor operating temperatures revealed increased conductor sags which impinged on limits for allowable safe ground clearances.

- 1 In addition, the Manager, Revenue and Supply, who is a senior engineer with broad
- 2 system planning experience, provides oversight and advice in relation to the Company's
- 3 transmission system planning activities.