

1 Q: Reference: *Review of Newfoundland and Labrador Hydro Power Supply*  
2 *Adequacy and Reliability Prior to and Post Muskrat Falls Final Report, Page ES-*  
3 *4.*

4  
5 *“Liberty recommends that, given the criticality of the Maritime Link to the*  
6 *reliability of the IIS, additional studies be completed not only with the Link in*  
7 *service, but also with it out of service”*

8  
9 **Please provide details about the required studies including (i) a prioritized**  
10 **listing of studies, (ii) when these studies should be completed, and (iii) the**  
11 **possible implications of these studies to the Muskrat Falls, Labrador Island**  
12 **Link, and Maritime Link projects.**

13  
14  
15 A. Studies with the Maritime Link out of service, as well as with the Maritime Link in  
16 service at credible power import and export settings, should be performed by Hydro  
17 as part of its Operational Studies, which would then feed into the Operational  
18 Procedures. This is because the system dynamics will be significantly different  
19 dependent on the power flows on the Maritime Link, and its ability to be curtailed.  
20 The LIL should also be represented, with appropriate settings, taking into account the  
21 loads in the IIS, varying between minimum and maximum loads.

22  
23 Both load flow and dynamic power stability studies should be performed. The load  
24 flow studies are done to ensure that no equipment is overloaded, and that the  
25 voltages in the ac network can be controlled as required.

26  
27 The dynamic stability studies are performed to ensure that the system as loaded and  
28 supported by synchronous condensers can ride through disturbances, such as ac  
29 system faults, monopolar faults, bipolar faults, etc, with the ac network recovering as  
30 required by the adopted planning standard.

31  
32 The studies will identify the maximum import and export on the Maritime Link, for  
33 various operating modes of the LIL, various IIS loads and with different numbers of  
34 synchronous condensers in the IIS.

35  
36 The studies will determine the maximum Maritime Link import/export limits for  
37 different configurations of LIL, IIS loads and different number of synchronous  
38 condensers.

39  
40 The studies should prioritize operation modes that are known to be required, and  
41 other configurations should then be studied.

1 The studies must be performed before the LIL and Maritime Link enter service.  
2 Studies for other operating modes should be completed before such new modes are  
3 made available.  
4

5 The results of the studies will determine for the different configurations and settings:  
6

- 7 • the permissible import on the LIL
- 8 • the permissible import/export on the Maritime Link
- 9 • the need for additional synchronous condenser, if any
- 10 • the need for changes to the UFLS

11  
12 The Muskrat Falls generation will be a potential limit on the import of power via the  
13 LIL, depending on the state of the dam and generator availability. On the other hand,  
14 the export of power on the Maritime Link may be an opportunity to enable the  
15 Muskrat Falls generation to provide additional output for export.