

1 Q. **C-80, Volume I: Replace Power Transformers**

2 In its 2015 Capital Budget, Hydro provided a list of planned work for transformers in
3 2017, 2018 and 2019. Please provide an update on the work initially planned for
4 2017, 2018 and 2019.

5

6

7 A. Please see PUB-NLH-005, Attachment 1, for an update on planned work on
8 transformers for 2017, 2018 and 2019. Please note that CRV T1 Radiator
9 Replacement has been removed from the transformer capital works plan as this
10 radiator is welded on to the transformer. Currently, Hydro is targeting only
11 radiators that are bolted on to the transformer for replacement under the capital
12 works plan.

PUB-NLH-005

Job	Planned Year – 2015 CBA	Plan Year - Current	Reason for Change
BDE T1 Oil Replacement	2017	2017	N/A
DLS T1 Oil Reclamation	2017	2018	Oil Refurbishment long term plan revised since 2015 Capital Budget Application using more recent oil condition data
BDE T2 Oil Replacement	2018	2017	Oil Refurbishment long term plan revised since 2015 Capital Budget Application using more recent oil condition data
GFC T2 Oil Reclamation	2018	2017	Oil Refurbishment long term plan revised since 2015 Capital Budget Application using more recent oil condition data
BDE T2 Radiator Replacement	2017	2017	N/A
CRV T1 Radiator Replacement	2017	Never	Not cost-effective
BUC T1 Radiator Replacement	2018	2017	Radiator Replacement long term plan revised since 2015 Capital Budget Application using more recent radiator condition data
GBK T1 Radiator Replacement	2018	2020	Radiator Replacement long term plan revised since 2015 Capital Budget Application using more recent radiator condition data
HRD T10 Radiator Replacement	2018	2021	Radiator Replacement long term plan revised since 2015 Capital Budget Application using more recent radiator condition data
DLS T1 Radiator Replacement	2019	2018	Radiator Replacement long term plan revised since 2015 Capital Budget Application using more recent radiator condition data
BBK T3 Radiator Replacement	2019	2020	Radiator Replacement long term plan revised since 2015 Capital Budget Application using more recent radiator condition data
WAV T1 Tap Changer Overhaul	2017	>2021	Tap Changer Overhaul long term plan revised since 2015 Capital Budget Application using more recent tap changer condition data
BUC T1 Tap Changer Overhaul	2018	2017	Tap Changer Overhaul long term plan revised since 2015 Capital Budget Application using more recent tap changer condition data
BDE T10 Tap Changer Overhaul	2019	>2021	Tap Changer Overhaul long term plan revised since 2015 Capital Budget Application using more recent tap changer condition data