

1 Q. **2018 Capital Projects \$500,000 and Over, Increase Fuel and Water Treatment**
2 **System Capacity, Volume I, Page C-8**
3 *“Since being placed in service, the Holyrood Gas Turbine generating unit has been*
4 *operated more frequently and for longer durations than was forecasted during the*
5 *engineering for its installation. Table 2 provides the forecasted and actual operating*
6 *hours for the gas turbine from February 2015 to April 2017.”*

7
8 Update Table 2 to August 2017 for forecast and actual operating hours for the
9 Holyrood gas turbine.

10
11
12 A. Please see Table 2 (as referenced in the 2018 Capital Budget Application) updated
13 below. Hydro notes that the table referred to in the question contained an error
14 related to the actual running hours for 2015. This has been corrected (please refer
15 to Hydro’s Capital Budget Application Revision 2, Volume I, Tab C, page C-9), and
16 shown in the table below (gray highlight).

17
18 The updated Table 2 below includes the updated Actual Running Hours up to
19 August 31, 2017. Hydro also notes that the forecasted annual running hours for
20 2017 has been updated from 444 to 529 in this table to include operation of the
21 unit during the Holyrood Thermal Generating Station total plant outage.

22

Year	Forecasted Annual Running Hours	Actual Running Hours
2015	184	788
2016	294	1,818
2017	529	821 (to August 31, 2017)