

1 Q. **Volume I: Holyrood Projected Operating Maintenance Expenditures**

2 Hydro states on page 3, line 15, that “Since 2008, the Preventive Maintenance
3 Program has been enhanced to include the extra costs associated with plant
4 cleaning in areas where asbestos and heavy metals have been identified as
5 potential health hazards.”

6
7 In Order No. P.U. 2(2005) the Board approved an Asbestos Abatement Plan.
8 According to the *Asbestos Abatement Plan for Holyrood Thermal Generating Station*
9 *– November 2004* report, the purpose of the program was to “remove all friable
10 asbestos piping and ductwork insulation and asbestos dust and debris in a three-
11 year period.”

12
13 What is the plan to deal with whatever asbestos remains?
14
15

16 A. The remaining asbestos containing material, as documented in the Pinchin LeBlanc
17 2016 Reassessment Report (see PUB-NLH-009), is dealt with on an as needed basis
18 in accordance with the Specific Recommendations and General Recommendations
19 contained within this report (Sections 6.1 and 6.2). These recommendations have
20 either been completed or are ongoing and being followed by the plant.