

1 Q. **Reference: *Reliability and Resource Adequacy Study – 2019 Update*, November 15, 2019,**
2 **Volume 1: Study Methodology and Planning Criteria, Attachment 1, page 7, Footnote 16.**

3 Please provide a copy of the Northeast Power Coordinating Council (“NPCC”) Reliability
4 Assessment for Winter 2019-20.

5

6

7 A. Please refer to NP-NLH-033, Attachment 1.¹

¹ The document is also publicly available at
<https://www.npcc.org/Library/Seasonal%20Assessment/NPCC_Reliability_Assessment_for_2019-2020_Winter.pdf>.



NORTHEAST POWER COORDINATING COUNCIL, INC.
1040 AVE OF THE AMERICAS, NEW YORK, NY 10018 TELEPHONE (212) 840-1070 FAX (212) 302-2782

Northeast Power Coordinating Council
Reliability Assessment
For
Winter 2019-20

FINAL REPORT
Approved by the RCC
December 3, 2019

Conducted by the
NPCC CO-12 & CP-8 Working Groups

TABLE OF CONTENTS

1. EXECUTIVE SUMMARY	4
SUMMARY OF FINDINGS	4
2. INTRODUCTION	8
3. DEMAND FORECASTS FOR WINTER 2019-20	10
SUMMARY OF RELIABILITY COORDINATOR AREA FORECASTS	11
4. RESOURCE ADEQUACY	16
NPCC SUMMARY FOR WINTER 2019-20	16
MARITIMES.....	18
NEW ENGLAND.....	19
NEW YORK	21
ONTARIO	23
QUÉBEC	25
PROJECTED CAPACITY ANALYSIS BY RELIABILITY COORDINATOR AREA	27
GENERATION RESOURCE CHANGES THROUGH WINTER 2019-20	28
FUEL INFRASTRUCTURE BY RELIABILITY COORDINATOR AREA.....	32
DEMAND RESPONSE PROGRAMS	39
5. TRANSMISSION ADEQUACY.....	43
INTER-REGIONAL TRANSMISSION ADEQUACY.....	43
INTER-AREA TRANSMISSION ADEQUACY	44
AREA TRANSMISSION ADEQUACY ASSESSMENT	45
MARITIMES.....	45
6. OPERATIONAL READINESS FOR WINTER 2019-20	51
NPCC.....	51
MARITIMES.....	52
NEW ENGLAND.....	52
NEW YORK	55
ONTARIO	58
QUÉBEC	59
7. POST-SEASONAL ASSESSMENT AND HISTORICAL REVIEW	61
WINTER 2018-19 POST-SEASONAL ASSESSMENT	61
HISTORICAL WINTER DEMAND REVIEW	63
8. 2019-20 WINTER RELIABILITY ASSESSMENTS OF ADJACENT REGIONS	65

9. CP-8 2019-20 WINTER MULTI-AREA PROBABILISTIC RELIABILITY ASSESSMENT EXECUTIVE SUMMARY	66
APPENDIX I – WINTER 2019-20 NORMAL LOAD AND CAPACITY FORECASTS	67
TABLE AP-1 - NPCC SUMMARY	67
TABLE AP-2 – MARITIMES.....	68
TABLE AP-3 – NEW ENGLAND.....	69
TABLE AP-4 – NEW YORK	70
TABLE AP-5 – ONTARIO.....	71
TABLE AP-6 – QUÉBEC	72
APPENDIX II – LOAD AND CAPACITY TABLES DEFINITIONS	73
APPENDIX III – SUMMARY OF FORECASTED WINTER TRANSFER CAPABILITIES.....	79
APPENDIX IV – DEMAND FORECAST METHODOLOGY.....	89
RELIABILITY COORDINATOR AREA METHODOLOGIES.....	89
APPENDIX V - NPCC OPERATIONAL CRITERIA AND PROCEDURES	95
APPENDIX VI - WEB SITES.....	97
APPENDIX VII - REFERENCES.....	98
APPENDIX VIII – CP-8 2019-20 WINTER MULTI-AREA PROBABILISTIC RELIABILITY ASSESSMENT – SUPPORTING DOCUMENTATION	99

THE INFORMATION IN THIS REPORT IS PROVIDED BY THE CO-12 OPERATIONS PLANNING WORKING GROUP OF THE NPCC TASK FORCE ON COORDINATION OF OPERATION AND THE CP-8 WORKING GROUP OF THE NPCC TASK FORCE ON COORDINATION OF PLANNING. ADDITIONAL INFORMATION PROVIDED BY RELIABILITY COUNCILS ADJACENT TO NPCC.

The CO-12 Working Group members are:

Courtney Fasca	ISO New England Inc.
Joseph Cohen	ISO New England Inc.
Tim Hicks (Vice Chair)	New Brunswick Power – System Operator
Rod Hicks	New Brunswick Power – System Operator
Kyle Ardolino	New York Independent System Operator
Harris Miller	New York Independent System Operator
Frank Peng	Independent Electricity System Operator
Mathieu Labbé (Chair)	Hydro-Québec TransÉnergie
Saladuddin Masjedi	Hydro-Québec TransÉnergie
Natasha Flynn	Nova Scotia Power Inc.
Andreas Klaube (Coordinator)	Northeast Power Coordinating Council

The CP-8 Working Group members are:

Philip Fedora (Chair)	Northeast Power Coordinating Council
Alan Adamson	New York State Reliability Council
Haretha Alao	Hydro-Québec Distribution
Sylvie Gicquel	Hydro-Québec Distribution
Frank Ciani	New York Independent System Operator
Scott Leuthauser	HQ Energy Services - U.S.
Philip Moy	PSEG Long Island
Khatune Zannat	PSEG Long Island
Kamala Rangaswamy	Nova Scotia Power Inc.
Rob Vance	Énergie NB Power
Prathamesh Kumthekar	Énergie NB Power
Vithy Vithyananthan	Independent Electricity System Operator
Fei Zeng	ISO New England Inc.
Peter Wong	ISO New England Inc.

The CP-8 Working Group acknowledges the efforts of Messrs. Eduardo Ibanez and Mitch Bringolf, GE Energy Consulting, and Patricio Rocha-Garrido, the PJM Interconnection, and thanks them for their assistance in this analysis.

1. Executive Summary

This report is based on the work of the NPCC CO-12 Operations Planning Working Group and focuses on the assessment of reliability within NPCC for the 2019-20 Winter Operating Period. Portions of this report are based on work previously completed for the NPCC Reliability Assessment for the Winter 2018-19 Operating Period¹.

Moreover, the NPCC CP-8 Working Group on the Review of Resource and Transmission Adequacy provides a seasonal, multi-area probabilistic reliability assessment. Results of this assessment are included as a chapter in this report and supporting documentation is provided in Appendix VIII.

Aspects that the CO-12 Working Group has examined to determine the reliability and adequacy of NPCC for the season are discussed in detail in the specific report sections. The following *Summary of Findings* addresses the significant points of the report discussion. These findings are based on projections of electric demand requirements, available supply resources and the most current transmission configurations. This report evaluates NPCC's and the associated Balancing Authority (BA) areas', ability to deal with the differing resource and transmission configurations within the NPCC region and the associated Balancing Authority areas' preparations to deal with the possible uncertainties identified within this report.

Summary of Findings

- The NPCC forecasted coincident peak demand² of 109,163 MW is anticipated to occur week beginning January 19, 2020, which is 162 MW less than the forecasted 2018-19 coincident peak of 109,325 MW. The capacity outlook indicates a forecasted coincident peak Net Margin of 20,732 MW (or 19.0%) in terms of the 109,163 MW forecasted peak demand. Unless otherwise noted, all forecasted demand is a normal (50/50) net peak forecast.
- The NPCC 2018-19 coincident winter peak demand of 109,218 MW occurred on January 21, 2019 at HE18 EST.

¹ The published NPCC Assessments can be downloaded from the NPCC website <https://www.npcc.org/Library/Seasonal%20Assessment/Forms/Public%20List.aspx>

² Load and Capacity Forecast Summaries for NPCC, Maritimes, New England, New York, Ontario, and Québec are included in Appendix I.

- The minimum percentage of forecasted Net Margin available to NPCC is 19.0%, for the week beginning January 19, 2020 and the maximum forecasted NPCC Net Margin of 41.9% occurs during the week beginning March 29, 2020.
- During the NPCC forecasted peak week of January 19, 2020, the Area forecasted Area Net Margins, in terms of normal forecasted demand, ranges from 7.0% in Québec to 47.4% in New York.
- When comparing the forecasted peak week from the previous winter (January 13, 2019) to this winter's expected peak week (January 19, 2020), the forecasted NPCC installed capacity has increased by 1,192 MW, mainly due to generation additions in Ontario (+749 MW).
- The Maritimes area anticipates adequate resources to meet demand for the winter 2019-20 period. A normal winter 2019-20 peak demand of 5,528 MW has been forecasted for the week beginning January 5, 2020 with a projected net margin of 285 MW (5.2%). This winter peak demand forecast is 159 MW higher than the winter peak demand forecast of 2018-19 and is 263 MW higher than the actual peak of 5,265 MW for winter 2018-19.
- Under extreme peak demand and certain outage scenario conditions, planning and Emergency Operating Mitigations could be relied upon in the Maritimes. These could include, but are not limited to, use of interruptible load programs, curtailment of export energy sales, purchase of Emergency Energy from neighboring areas in accordance with Interconnection Agreements, reduction in 30-min Operating Reserve or public appeals.
- The Maritimes, Ontario and Quebec areas show below 10% and lower Net Margins than the previous Winter Period due to higher forecast loads and an increase in maintenance outages. Area-specific risks, as well as Area and regional operational and planning mitigations are detailed in Chapter 6 – Operational Readiness for Winter 2019-20.
- New England is forecasting adequate resources to meet the normal peak demand for the 2019-20 winter period. A normal peak demand of 20,476 MW is forecast to occur for the week beginning January 19, 2020, with a projected net margin of 4,266 MW (20.8%). This winter peak demand forecast is 119 MW higher than the winter peak demand forecast for 2018-19. New England continues to monitor factors affecting natural gas deliverability throughout the winter reliability assessment and recognizes more than 4,500 MW of natural-gas-fired capacity may be at risk due to constrained natural gas pipelines. This deliverability risk is continuously evaluated throughout the outage-coordination process and into

real-time operations. During the Winter 2018-2019 Operating Period, ISO-NE implemented a periodic 21-day Energy Assessment that was published to provide market participants with early indication of potential fuel scarcity conditions and help inform fuel procurement decisions. ISO-NE plans to continue producing this report during the Winter 2019-2020 Operating Period. For Winter 2019-2020, ISO New England will continue to utilize the Pay For Performance (PFP) program and Energy Market Opportunity Cost (EMOC) calculations in order to incentivize procuring enough fuel for generation during potential limitations or shortage events.

- The NYISO anticipates adequate resources to meet demand for the 2019-20 winter season. A capacity margin of 11,432 MW (47.4%) is expected for the normal demand forecast of 24,123 MW during the NPCC peak week of January 19, 2020. The normal demand forecast is lower than the previous year's forecast of 24,269 MW by 146 MW and 605 MW less than the actual 2018-19 winter peak of 24,728 MW. The NYISO also conducted a loss of gas installed capacity assessment to determine the impact on operating margins should gas shortages arise. It found that 5,232 MW of gas fired generation with non-firm supply are at risk. Should all of this capacity not be available during a peak load time, the projected operating margin would be reduced to 6,200 MW (25.7%).
- The IESO anticipates adequate resources to meet demand for the winter 2019-20 period. The forecasted Ontario winter peak is 21,115 MW for week beginning January 5, 2020 with a corresponding net margin of 1,559 MW (or 7.4%). This is the forecasted minimum Net Margin for the winter 2019-20 period. Ontario's 2018-19 winter peak demand was 21,525 MW, which was 191 MW higher than the peak forecast (21,334 MW) and occurred January 21, 2019. This can be mostly attributed to the consistently colder than normal temperatures that were persistent through the month of January. As part of an electricity trade agreement with Québec, in exchange for 500 MW of capacity in the winter months, Ontario will be receiving up to two terawatt hours of clean import energy annually to help reduce greenhouse gas over peak hours.
- The Québec area anticipates adequate resources to meet demand for the winter 2019-20 season. The current 2019-20 normal peak forecast is 38,665 MW (204 MW higher than the demand forecast presented in the prior winter assessment) and the forecasted operating margin is 2,720 MW (7.0%) for the peak operating week. This decrease in demand is mainly attributed to lower peak demand for heating space use. An extreme forecast has also been evaluated and the projected Net Margin is 562 (1.3%). Compared to what was anticipated for

winter 2018-19, the forecasted Installed Capacity is expected to have grown by 6 MW by December 2019. If peak demands are higher than expected, a number of measures are available to the System Control personnel.

The results of the CO-12 and CP-8 Working Groups' studies indicate that NPCC and the associated Balancing Authority areas have adequate generation and transmission capabilities for the upcoming Winter Operating Period. Necessary strategies and procedures are in place to deal with operational problems and emergencies as they may develop. However, the resource and transmission assessments in this report are based upon snapshots in time and base case studies. Continued vigilance is required to monitor changes to any of the assumptions that can potentially alter the report's findings.

2. Introduction

The NPCC Task Force on Coordination of Operation (TFCO) established the CO-12 Working Group to conduct overall assessments of the reliability of the generation and transmission system in the NPCC Region for the Summer Operating Period (defined as the months of May through September) and the Winter Operating Period (defined as the months of December through March). The Working Group may occasionally study other conditions as requested by the TFCO.

For the 2019-20 Winter Operating Period³ the CO-12 Working Group:

- Examined historical winter operating experiences and assessed their applicability for this period.
- Examined the existing emergency operating procedures available within NPCC and reviewed recent operating procedure additions and revisions.
- The NPCC CP-8 Working Group has done a probabilistic assessment of the implementation of operating procedures for the 2019-20 Winter Operating Period. The full CP-8 assessment report is included as Appendix VIII.
- Reported potential sensitivities that may impact resource adequacy on a Reliability Coordinator (RC) area basis. These sensitivities included temperature variations, capacity factors of renewables generation resources, in-service delays of new generation, load forecast uncertainties, evolving load response measures, fuel availability, system voltage and generator reactive capability limits.
- Reviewed the capacity margins for both normal and extreme forecasts while accounting for bottled capacity within the NPCC region.
- Reviewed inter-Area and intra-Area transmission adequacy, including new transmission projects, upgrades or derates and potential transmission problems.
- Reviewed the operational readiness of the NPCC region and actions to mitigate potential problems.
- Coordinated data and modeling assumptions with the NPCC CP-8 Working Group, and documented the methodology of each Reliability Coordinator area in its projection of load forecasts.

³ For the purpose of this report, the Winter Operating Period is defined as the week beginning December 1, 2019 to the week beginning March 29, 2020 inclusive.

- Coordinated with other parallel, seasonal operational assessments, including the NERC Reliability Assessment Subcommittee (RAS) seasonal assessments.

3. Demand Forecasts for Winter 2019-20

The coincident forecasted peak demand for NPCC over the 2019-20 Winter Operating Period is 109,163 MW, which is expected during the week beginning January 19, 2020. The NPCC Winter 2018-19 coincident peak demand of 109,218 MW occurred on January 21, 2019 at HE18 EST. Demand and Capacity forecast summaries for NPCC, Maritimes, New England, New York, Ontario, and Québec are included in Appendix I.

Ambient temperatures and persistent winter conditions are important variables impacting the demand forecasts. However, unlike the summer demand forecasts, the non-coincident winter peak demand varies only slightly from the coincident peak forecast. This is mainly because the drivers that impact the peak demand are concentrated into a specific period in time. In winter, the peak demands are determined mainly by low temperatures along with the reduced hours of daylight that occur over the first few weeks of January. While the peak demands appear to be confined to a few weeks in January, each area is aware that reduced margins could occur during any week of the operating period as a result of weather variables and forecasted conditions.

In the operational planning time-frame, the impact of ambient weather conditions on load forecasts can be demonstrated by various means. The Maritimes and IESO represent the resulting load forecast uncertainty in their respective areas as a mathematical function of the base load. ISO-NE updates the Load Forecast twice daily, on a seven-day time horizon in each forecast. The Load Forecast models are provided with a weather input of an eight-city weighted average dry bulb temperature, dew point, wind speed, cloud cover and precipitation. Zonal load forecasts are produced for the eight Load Zones across New England using the same weather inputs with different locational weightings. The NYISO uses a weather index that relates air temperature and wind speed to the load response and increases the load by a MW factor for each degree below the base value. TransÉnergie, the Québec system operator, updates forecasts on an hourly basis within a 12 day horizon based on local weather, wind speed, cloud cover, sunlight incidence and type and intensity of precipitation over nine regions of the Québec Balancing Authority area.

The method each Reliability Coordinator area uses to determine the peak forecast demand and the associated Load Forecast uncertainty relating to weather variables is described in Appendix IV. Below is a summary of all Reliability Coordinator area forecasts.

Summary of Reliability Coordinator Area Forecasts

Maritimes

Winter 2019-20 Forecasted Peak: 5,528 MW (normal) and 5,929 MW (extreme), week beginning January 5, 2020

Winter 2018-19 Forecasted Peak: 5,369 MW (normal) and 5,758 MW (extreme), week beginning January 6, 2019

Winter 2018-19 Actual Peak: 5,265 MW on January 18, 2019 at HE7 EST




Figure 3-1: Maritimes Winter 2019-20 Weekly Demand Profile

New England

Winter 2019-20 Forecasted Peak: 20,476 MW (normal) and 21,173 MW (extreme), weeks beginning January 5 - 19, 2019

Winter 2018-19 Forecasted Peak: 20,357 MW (normal) and 21,057 MW (extreme), weeks beginning January 6 - 20, 2019

Winter 2018-19 Actual Peak: 20,719 MW on January 21, 2019 at HE18 EST




Figure 3-2: New England Winter 2019-20 Weekly Demand Profile

New York

Winter 2019-20 Forecasted Peak: 24,123 MW (normal) and 25,724 MW (extreme) during the weeks of December 8, 2019 through February 23, 2020, although it is expected that the winter peak could occur at any time during the months of December through February.

Winter 2018-19 Forecasted Peak: 24,269 MW (normal) and 25,884 MW (extreme) during the months of December 2018 through February 2019

Winter 2018-19 Actual Peak: 24,728 MW on January 21, 2019 at HE19 EST




Figure 3-3: New York Winter 2019-20 Weekly Demand Profile

Ontario

Winter 2019-20 Forecasted Peak: 21,115 MW (normal) and 22,288 MW (extreme), week of January 5, 2020

Winter 2018-19 Forecasted Peak: 21,334 MW (normal) and 22,561 MW (extreme), week of January 6, 2019

Winter 2018-19 Actual Peak: 21,525 MW, on January 21, 2019 at HE18 EST




Figure 3-4: Ontario Winter 2019-20 Weekly Demand Profile

Québec

Winter 2019-20 Forecasted Peak: 38,665 MW (normal) and 41,923 MW (extreme), week of January 19, 2020

Winter 2018-19 Forecasted Peak: 38,461 MW (normal) and 41,847 MW (extreme), week of January 13, 2019

Winter 2018-19 Actual Peak: 38,364 MW, on January 22, 2019 at HE8 EST.




Figure 3-5: Québec Winter 2019-20 Weekly Demand Profile

4. Resource Adequacy

NPCC Summary for Winter 2019-20

The assessment of resource adequacy indicates the week with the highest forecasted coincident NPCC demand is the week beginning January 19, 2020 (109,163 MW). Detailed projected load and capacity forecast summaries specific to NPCC and each area are included in Appendix I.

In Appendix I, Table AP-1 is the NPCC load and capacity summary for the 2019-20 Winter Operating Period. Appendix I, Tables AP-2 through AP-6, contain the load and capacity summary for each NPCC Reliability Coordinator area. Each entry in Table AP-1 is simply the aggregate of the corresponding entry for the five NPCC Reliability Coordinator areas.

Table 4-1 (below) summarizes the NPCC forecasted load and resource adequacy for the peak week beginning January 19, 2020 compared to the winter 2018-19 forecasted peak week beginning January 13, 2019.

Table 4-1: Resource Adequacy Comparison of Winter Forecasts

All values in MW	2019-20	2018-19	Difference
Installed Capacity	167,391	166,199	1,192
Net Interchange	1,169	2,162	-993
Dispatchable Demand-Side Management	2,355	2,191	164
Total Capacity	170,915	170,552	363
Demand	109,163	109,325	-162
Interruptible Load	2,377	2,429	-52
Maintenance/De-rate	21,661	19,465	2,196
Required Reserve	8,885	8,885	0
Unplanned Outages	12,851	13,670	-819
Net Margin	20,732	21,636	-904
Week Beginning	19-Jan-20	13-Jan-19	-

**Note: Net Interchange value offered as the summation of capacity backed imports and exports for the NPCC region.*

The Revised Net Margin for the 2019-20 Winter Operating Period has decreased by 904 MW from the previous winter (2018-19). This decrease is largely to the increase of maintenance outages in Ontario.

The NPCC forecasted capacity outlook indicates a coincident peak Net Margin of 20,732 MW (19.0%) with respect to the 109,163 MW forecasted normal peak demand. When considering extreme coincident peak demand, the forecasted extreme Net Margin is 13,828 MW (11.9%).

The following sections detail the 2019-20 winter capacity analysis for each Reliability Coordinator area.

Maritimes

The Maritimes area declared Installed Capacity is scheduled to be available for the winter period; the Net Margins calculated include impacting factors such as wind, ambient temperature, and hydro flows that may derate generation and reflect expected out-of-service units. Imports into the Maritimes area are not included unless they have been confirmed as released capacity from their source. Therefore, unless additional forced generator outages were to occur, there would not be any further reduction in the net Installed Capacity. As part of the winter planning process, dual-fueled units will have sufficient supplies of heavy fuel oil (HFO) on-site to enable sustained operation in the event of natural gas supply interruptions. Table 4-2 conveys the Maritimes anticipated operable capacity margins for the normal and extreme winter peak load forecasts of the Winter Operating Period.

Table 4-2: Maritimes Operable Capacity for 2019-20

Winter 2019-20	Normal Forecast	Extreme Forecast
Installed Capacity (+)	7,748	7,748
Net Interchange (+)	-110	-110
Dispatchable Demand-Side Management (+)	0	0
Total Capacity	7,748	7,748
Interruptible Load (+)	243	243
Known Maintenance & Derates (-)	1,085	1,085
Operating Reserve Requirement (-)	893	893
Unplanned Outages (-)	200	200
Peak Load Forecast (-)	5,528	5,929
Net Margin (MW)	285	-116
Net Margin (%)	5.2%	-2.0%

If the Maritimes real-time peak demand becomes higher than forecasted, the System Operator may implement operating procedures to maintain system reliability, as outlined in the Maritimes section of Operational Readiness for winter 2019-20.

New England

To determine the region’s capacity risks, ISO-NE assesses the difference between New England’s installed capacity and operable capacity under normal load forecasts. Some of these factors include fuel deliverability risks for natural-gas-fired generation and the difference between a generator’s seasonal claimed capability (SCC) value and its capacity supply obligation (CSO). The SCC is recognized as a generator’s maximum output established through seasonal audits, whereas its CSO is its obligation to satisfy its share of New England’s installed capacity requirement (ICR) by generating the megawatts that cleared through a Forward Capacity Auction (FCA) within the Forward Capacity Market. Table 4-3 shows the variation in operable capacity margins for January 2020, recognizing these factors.

Table 4-3: New England Installed and Operable Capacity for Normal Forecast

Normal Load Forecast	Jan - 2020	Jan - 2020
	CSO	SCC
Operable Capacity + Non-commercial Capacity	31,372	33,530
Net Interchange (+)	917	917
Dispatchable Demand-Side Management (+)	458	328
Total Capacity	32,747	34,775
Peak Load Forecast	20,476	20,476
Interruptible Load (+)	0	0
Known Maintenance & Derates (-)	482	492
Operating Reserve Requirement (-)	2,305	2,305
Unplanned Outages and Gas at Risk (-)	7,007	7,448
Net Margin (MW)	2,477	4,054
Net Margin (%)	12.1%	19.8%

ISO-NE also compares the installed capacity with operable capacity under extreme load forecasts to further determine New England’s capacity risks. This broadened approach helps identify potential capacity concerns for the upcoming capacity period and prepare for severe demand conditions. This analysis, shown in Table 4-4 for January 2020, shows the further reduction in the operable capacity margin recognizing these factors. If forecasted extreme winter conditions materialize and generators do not achieve their SCC, New England may need to rely more heavily on import capabilities from neighboring areas, as well as implement emergency operating procedures to maintain system reliability.

Table 4-4: New England Installed and Operable Capacity for Extreme Forecast

Extreme Forecast	Jan - 2020	Jan - 2020
	CSO	SCC
Operable Capacity + Non-commercial Capacity	31,372	33,530
Net Interchange (+)	917	917
Dispatchable Demand-Side Management (+)	458	328
Total Capacity	32,747	34,775
Peak Load Forecast	21,173	21,173
Interruptible Load (+)	0	0
Known Maintenance & Derates (-)	482	492
Operating Reserve Requirement (-)	2,305	2,305
Unplanned Outages and Gas at Risk (-)	7,474	7,965
Net Margin (MW)	1,313	2,840
Net Margin (%)	6.2%	13.4%

New York

New York determines its operating margin by comparing the normal seasonal peak forecast with the projected Installed Capacity adjusted for seasonal operating factors. Installed Capacity is based on seasonal Dependable Maximum Net Capability (DMNC), tested seasonally, for all traditional thermal and large hydro generators. Wind generators are counted at nameplate for Installed Capacity and seasonal derates are applied. Net Interchange is based on projected capacity transactions external to the New York Control Area (NYCA). Dispatchable Demand-Side Management consists of Special Case Resources (SCRs) while Interruptible Load includes NYISO's Emergency Demand Response Program (EDRP). Known Maintenance and Derates includes generator maintenance outages known at the time of this writing and derates for renewable resources such as wind, hydro, solar and refuse based on historical performance data. The NPCC Operating Reserve Requirement for New York is one-and-a-half times the largest single generating source contingency in the NYCA. Beginning November 2015, the NYISO started procuring operating reserve of two times the largest single generating source contingency (2,620 MW) to ensure compliance with a New York State Reliability Council (NYSRC) Rule. Unplanned Outages are based on expected availability of all thermal units and SCRs in the NYCA based on historic availability. Historic availability factors in all forced outages including those due to weather and availability of fuel. Table 4-5 presents a conservative scenario comparing the normal and extreme operating margins for upcoming winter period.

The NYISO conducted a loss of gas installed capacity assessment to determine the impact on operating margins should gas shortages arise. It found that 5,232 MW of gas fired generation with non-firm supply are at risk. Should all of this capacity not be available during a peak load time, the projected operating margin would drop from 11,432 MW (47.4%) to 6,200 MW (25.7%).

Table 4-5: New York Operable Capacity Forecast

Winter 2019-20	Normal Forecast (MW)	Extreme Forecast (MW)
Installed Capacity (+)	41,815	41,815
Net Interchange (+)	678	678
Dispatchable Demand-Side Management (+)	853	853
Total Capacity	43,346	43,346
Interruptible Load (+)	40	40
Known Maintenance & Derates (-)	2,634	2,634
Operating Reserve Requirement (-)	2,620	2,620
Unplanned Outages (-)	2,577	2,577
Peak Load Forecast	24,123	25,724
Net Margin (MW)	11,432	9,831
Net Margin (%)	47.4%	38.2%

Ontario

Looking at the 2019-20 Winter Operating Period, considering existing and planned capacity coming in-service, the Ontario reserve requirement is met under both normal and extreme weather conditions, as indicated in Table 4-6.

Table 4-6: Ontario Operable Capacity Forecast

Winter 2019-20	Normal Forecast (MW)	Extreme Forecast (MW)
Installed Capacity (+)	37,609	37,609
Net Interchange (+)	-500	-500
Dispatchable Demand-Side Management (+)	924	924
Total Capacity	38,033	38,033
Known Maintenance & Derates (-)	12,311	12,311
Operating Reserve Requirement (-)	1,567	1,567
Unplanned Outages (-)	1,481	1,481
Peak Load Forecast	21,115	22,288
Net Margin (MW)	1,559	386
Net Margin (%)	7.4%	1.7%

The forecast energy production capability of the Ontario generators is calculated on a month-by-month basis. Monthly energy production capabilities for the Ontario generators are provided by market participants or calculated by the IESO. They account for fuel supply limitations, scheduled and forced outages and deratings, environmental and regulatory restrictions.

The results in Table 4-7 indicate that occurrences of unserved energy are not expected over the winter 2019-20 period. Based on these results, it is anticipated that Ontario will be energy adequate for the normal weather scenario for the review period.

Table 4-7: Ontario Energy Production Capability Forecast by Month

Month	Forecast Energy Production Capability (GWh)	Forecast Energy Demand (GWh)
Oct 2019	16,038	10,875
Nov 2019	16,140	11,195
Dec 2019	17,998	12,459
Jan 2020	17,731	13,187
Feb 2020	15,694	11,893
Mar 2020	16,495	11,863

Québec

The Québec area anticipates adequate resources to meet demand for the 2019-20 Winter Operating Period. The current 2019-20 peak forecast (normal) is 38,665 MW and the forecasted operating margin is 2,720 MW for the area peak week. This includes known maintenance and derates of 4,772 MW, including scheduled generator maintenance and wind generation derating. Table 4-8 shows the factors included in the operating margin calculation. An extreme forecast scenario has also been evaluated and the margin anticipated is 562 MW.

Table 4-8: Québec Operable Capacity Forecasts

Winter 2019-20	Normal Forecast (MW)	Extreme Forecast (MW)
Installed Capacity	46,689	46,689
Net Interchange	184	184
Dispatchable Demand-Side Management (+)	250	250
Total Capacity	47,123	47,123
Interruptible Load (+)	2,034	2,034
Known Maintenance & Derates (-)	4,772	4,772
Operating Reserve Requirement (-)	1,500	1,500
Unplanned Outages (-)	1,500	1,500
Peak Load Forecast	38,665	41,923
Net Margin	2,720	562
Net Margin (%)	7.0%	1.3%

If Québec real-time peak demands are higher than forecasted, a number of measures are available to the System Control personnel and are listed in Section 6: Operational Readiness.

Québec's area energy requirements are met for the greatest part by hydro generating stations located on different river systems and scattered over a large territory. The major plants are backed by multiannual reservoirs (water reserves lasting more than one year). Due to the multi-year reservoirs, a single year of low water inflow cannot adversely impact the reliability of energy supply. However, a series of consecutive dry years may require some operating measures, such as the reduction of exports or capacity purchase from neighbouring areas. To assess its energy reliability, Hydro-Québec has developed an energy criterion stating that sufficient resources should be available to go through a

sequence of 2 consecutive years of low water inflows totalling 64 TWh, or a sequence of 4 years totalling 98 TWh, and having a 2% probability of occurrence. The use of operating measures and the hydro reservoirs will be managed accordingly. Reliability assessments based on this criterion are presented three times a year to the Québec Energy Board. Such documents can be found on the Régie de l'Énergie du Québec website.⁴

⁴ http://www.regie-energie.qc.ca/audiences/TermElecDistrPlansAppro_Suivis.html

Projected Capacity Analysis by Reliability Coordinator Area

The table below summarizes projected capacity and margins by Reliability Coordinator area. Appendix I shows these projections for the entire Winter Operating Period, respecting normal demand forecasts.

Table 4-9: Summary of Projected Capacity by Reliability Coordinator

Area	Measure	Week Beginning Sundays	Installed Capacity MW	Net Interchange MW	Dispatchable DSM MW	Total Capacity MW	Load Forecast MW	Interruptible Load MW	Known Maint./Derat. MW	Req. Operating Reserve MW	Unplanned Outages MW	Net Margin MW
NPCC	NPCC Peak Week	19-Jan-20	167,391	1,169	2,355	170,915	109,163	2,377	21,661	8,885	12,851	20,732
	Peak Week	5-Jan-20	7,748	-110	0	7,748	5,528	243	1,085	893	200	285
Maritimes	Lowest Net Margin	5-Jan-20	7,748	-110	0	7,748	5,528	243	1,085	893	200	285
	NPCC Peak Week	19-Jan-20	7,748	-110	0	7,748	5,351	303	1,085	893	200	522
New England	Peak Week	19-Jan-20	33,530	917	328	34,775	20,476	0	492	2,305	7,236	4,266
	Lowest Net Margin	12-Jan-20	33,530	917	328	34,775	20,476	0	492	2,305	7,448	4,054
	NPCC Peak Week	19-Jan-20	33,530	917	328	34,775	20,476	0	492	2,305	7,236	4,266
	Peak Week	19-Jan-20	41,815	678	853	43,346	24,123	40	2,634	2,620	2,577	11,432
New York	Lowest Net Margin	22-Mar-20	42,947	678	853	44,478	22,754	40	6,892	2,620	2,371	9,881
	NPCC Peak Week	19-Jan-20	41,815	678	853	43,346	24,123	40	2,634	2,620	2,577	11,432
	Peak Week	5-Jan-20	37,609	-500	924	38,033	21,115	0	12,311	1,567	1,481	1,559
Ontario	Lowest Net Margin	5-Jan-20	37,609	-500	924	38,033	21,115	0	12,311	1,567	1,481	1,559
	NPCC Peak Week	19-Jan-20	37,609	-500	924	38,033	20,548	0	12,678	1,567	1,338	1,902
Québec	Peak Week	19-Jan-20	46,689	184	250	47,123	38,665	2,034	4,772	1,500	1,500	2,720
	Lowest Net Margin	19-Jan-20	46,689	184	250	47,123	38,665	2,034	4,772	1,500	1,500	2,720
	NPCC Peak Week	19-Jan-20	46,689	184	250	47,123	38,665	2,034	4,772	1,500	1,500	2,720

Generation Resource Changes through Winter 2019-20

The following table lists the recent and anticipated generation resource additions, commissioning delays and retirements. Generation adjustments may be reflected as an increase or decrease in MW output, recognizing changes due to mechanical, environmental or performance audits.

Table 4-10: Resource Changes from Winter 2018-19 through Winter 2019-20

Area	Generation Facility	Nameplate Capacity (MW)	Fuel Type	In Service/Retirement Date
Maritimes	Wisokolamson Energy Project	18	Wind	Q4 2019
	ReEnergy Fort Fairfield	-33	Biomass	Q2 2019
	Caribou Station	-30	Oil/Diesel	Q3 2019
	Lingan #2	-5	Coal/Petcoke	Derate Q2 2019
	Charlottetown #8	-9	Bunker	Q4 2019
	Nova Scotia Tidal	-2	Tidal	Unrealized Q3 2019
	Charlottetown #7	-5	Bunker	Q1 2019
	Unrealized Forecasted Additions	-6	Biomass/ Solar	-
	Net Total	-72		
New England	Pilgrim	-780	Nuclear	Q2 2019
	Bridgeport Harbor 5	678	NG/DFO	Q2 2019
	Canal 3	425	NG/DFO	Q2 2019
	West Medway Jet 4	115	NG/DFO	Q1 2019
	West Medway Jet 5	115	NG/DFO	Q2 2019
	Net Total Nameplate	553		
	Seasonal Adjustments	-176		
	Net Total	377		

Area	Generation Facility	Nameplate Capacity (MW)	Fuel Type	In Service/Retirement Date
New York	KCE NY 1	20	Battery (grid-connected)	Q1 2019
	Arkwright Summit	78	Wind	Q2 2019
	Steuben County LF (retirement)	-3.2	BioGas	Q2 2019
	Copenhagen Wind	79.9	Wind	Q2 2019
	Selkirk I & II (rescinded retirement)	446	Oil	Q2 2019
	Hudson Avenue GT4 (retirement)	-16.3	Oil	Q3 2019
	Auburn – State St. (retirement)	-7.4	Natural Gas	Q3 2019
	Monroe Livingston (retirement)	-2.4	BioGas	Q3 2019
	Albany LFGE (retirement)	-5.6	BioGas	Q4 2019
	Cayuga 1 (retirement)	-155.3	Coal	Q4 2019
	Seasonal ICAP Adjustments	-157.7		
	Net Total	276		
Ontario	Loyalist Solar	54	Solar	Q4 2019
	Henvey Inlet Wind Farm	300	Wind	Q1 2020
	Napanee Generating Station	985	Gas	Q1 2020
	Nation Rise	100	Wind	Q1 2020
	Romney Wind Energy Centre	60	Wind	Q1 2020
	Seasonal Adjustments	-		
	Net Total	1,499		
Québec	Seasonal Adjustments	6		
	Net Change	6		

Maritimes

Since the 2018-19 Winter Operating Period, there has been a net decrease of 72 MW of installed capacity in the Maritimes. Scheduled to be put in service by early November 2019 is a new 18 MW Wisokolamson wind facility in New Brunswick. However, with the retirement of several biomass and diesel/oil fired units in Northern Maine during the 2019-20 winter operating period, the derating of a coal unit and unrealized tidal. Biomass and solar projects in Nova Scotia and the retirement of two oil fired generators in Prince Edward Island, the net total is a 72 MW decrease.

New England

Since the 2018-19 Winter assessment period, ISO-NE has retired a large nuclear unit and added several new gas-fired plants. New generation consists primarily of over 1,000 MW of natural-gas-fired units, including Bridgeport Harbor 5, Canal 3, and West Medway 4 and 5. Pilgrim, a 780 MW nameplate nuclear unit, was retired as of June 1, 2019. The seasonal adjustments value of 176 MW reflects a reduction in the SCC based on seasonal audit results.

New York

Since the 2018-19 winter season, generation capacity in New York has increased slightly. The coal-powered steam unit Cayuga 1 (155 MW nameplate) is expected to retire before the end of 2019. In addition, several small generators across the NYCA have retired, or are expected to retire, totaling 19 MW nameplate of BioGas and 16 MW nameplate of Oil. New generation in-service since last winter includes two wind farms, Arkwright Summit (78 MW nameplate) and Copenhagen Wind (80 MW nameplate), and a behind-the-meter solar plant, Rivex Solar (20 MW nameplate). The KCE NY 1 is a behind-the-meter battery storage facility totaling 20 MW nameplate.

Ontario

By the end of the winter 2019-20 Operating Period, the total capacity in Ontario is expected to increase by 1,499 MW. New renewable (wind and solar) capacity totalling 514 MW will be added to the system. There are no capacity reductions expected during this timeframe. The 985 MW Napanee Generating station has been delayed a number of times with a new expected in service date of Q1-2020. The facility will not be available over the 2019-20 winter peak.

Québec

The Installed Capacity is estimated at 46,689⁵ MW, a net 6 MW increase since last winter due to a few seasonal adjustments.

⁵ This value may not exactly correspond to the value published in Hydro-Québec's annual report because it was calculated using assumptions that are specific to the current report.

Fuel Infrastructure by Reliability Coordinator Area

The following figures depict installed generation resource profiles for each Reliability Coordinator Area and for the NPCC Region by fuel supply infrastructure as projected for the NPCC coincident peak week.

Figure 4-1: Installed Generation Fuel Type by Reliability Coordinator Area





Figure 4-2: Installed Capacity Fuel Profiles for NPCC



Wind and Solar Capacity Analysis by Reliability Coordinator Area

For the upcoming 2019-20 Winter Operating Period, wind and solar capacity accounts for approximately 7.4% of the total NPCC Installed Capacity during the coincident peak load. This breaks down to 7.1% and 0.3% solar. Solar capacity is derated to zero for all areas since it is expected peak load will occur during a time near or after sunset. Reliability Coordinators have distinct methods of accounting for both of these types of generation. The Reliability Coordinators continue to develop their knowledge regarding the operation of wind and solar generation in terms of capacity forecasting and utilization factor.

Table 4-11 below illustrates the nameplate of wind and solar capacity in NPCC for the 2019-20 Winter Operating Period for each of the NPCC Reliability Coordinators. The Maritimes, IESO, NYISO and Québec areas include the entire nameplate capacity in the Installed Capacity section of the Load and Capacity Tables and use a derate value in the Known Maintenance/Constraints section to account for the fact that some of the capacity will not be online at the time of peak. ISO-NE reduces the nameplate capacity and includes this reduced capacity value directly in the Installed Capacity section of the Load and Capacity Table. Please refer to Appendix II, for information on the derating methodology used by each of the NPCC Reliability Coordinators.

Table 4-12 illustrates behind-the-meter solar PV capacity and the amount of impact it has on peak load demand for each area. The IESO, ISO-NE and NYISO each factor in behind-the-meter solar as a peak load reduction. Methodologies for each area can be found in Appendix IV.

Table 4-11: NPCC Wind and Solar Capacity and Applied Derates

Reliability Coordinator area	Nameplate Wind Capacity Winter (MW)	Wind Capacity After Applied Derating Factor (MW)	Nameplate Solar Capacity (MW)	Solar Capacity After Applied Derating Factor (MW)
Maritimes	1,170	326	1	0
New England	1,353	386	218	0
New York*	1,897	630	31	0
Ontario	4,486	1,696	424	0
Québec	3,880	1,352	0	0
Total	12,786	4,390	674	0

**Total wind nameplate capacity in New York is 1,985 MW; however, only 1,897 MW participates in the ICAP market.*

Table 4-12: Behind-the-Meter Solar PV

Reliability Coordinator area	Installed Behind-the-Meter Solar PV (MW)	Impact of BTM Solar PV on Peak Load (MW)
Maritimes	0	0
New England	3,129	0
New York	1,674	0
Ontario	2,286	0
Québec	8	0
Total	7,097	0

Maritimes

Wind projected capacity is derated to its demonstrated output for each summer or winter capability period. In New Brunswick and Prince Edward Island, the wind facilities that have been in production over a three year period, a derated monthly average is calculated using metering data from previous years over each seasonal assessment period. For those that have not been in service that length of time (three years), the deration of wind capacity in the Maritimes area is based upon results from the Sept. 21, 2005 NBSO report, “Maritimes Wind Integration Study”. This wind study showed that the effective capacity from wind projects, and their contribution to loss of load expectation (LOLE) was equal to or better than their seasonal capacity factors.

The Northern Maine Independent System Administrator (NMISA) uses a fixed capacity factor of 30% for both the summer and winter assessment periods.

Nova Scotia applies an 18% capacity value to installed wind capacity (82% derated) throughout the year. This figure was calculated via a Cumulative Frequency Analysis of historical wind data (2010-2015). The top 10% of load hours were analyzed to reflect peak load conditions, and a 90% confidence limit was selected as the critical value. This analysis showed that NS Power can expect to have at least 18% of installed wind capacity producing energy in 90% of peak hours.

New England

During the 2019-20 winter assessment period, New England derated the 1,353 MW of wind resources by ~71% as a result of established winter claimed-capability audits (CCAs). Recognizing that wind resources could provide more power than the derated value, ISO New England produces a daily seven-day wind forecast, which provides an aggregate wind power forecast for each hour of the seven-day period. The ISO also utilizes system functions and control room displays to improve situational awareness for system operators.

New England continues to observe sustained growth in distributed photovoltaic (PV) resources. By the end of 2019, approximately 3,347 MW (3,129 nameplate of behind the meter, 218 MW in front of the meter) of nameplate PV will be installed within the region. Load reduction from PV can be observed during the midday hours of sunny winter days; however, with the winter peak demand occurring after sunset, ISO-NE fully derates the PV resources.

New York

For the 2019-20 winter season there is projected to be 1,897 MW of nameplate wind and 31 MW of nameplate solar installed capacity in New York. The nameplate capacity is counted at full value towards the Installed Capacity for New York and is derated by 66.8% for wind and 100% for solar based on historical performance data when determining operating margins.

Ontario

The nameplate capacity of transmission connected wind and solar facilities total 4,486 MW and 424 MW respectively.

For Ontario, monthly Wind Capacity Contribution (WCC) values are used to forecast the contribution from wind generators at the time of the weekday peak. WCC values in percentage of installed capacity are determined from a combination of actual historic median wind generator contribution over the last 10 years at the top 5 contiguous demand hours of the day for each winter and summer season, or shoulder period month. The top 5 contiguous demand hours are determined by the frequency of demand peak occurrences over the last 12 months.

Similarly, monthly Solar Capacity Contribution (SCC) values are used to forecast the contribution expected from solar generators. SCC values in percentage of installed capacity are determined by calculating the median contribution at the top 5 contiguous demand hours of the day for each winter and summer season, or shoulder period month. A dataset comprising ten years of simulated solar production history is used for this purpose. As actual solar production data becomes available in future, the process of combining actual historical solar data and the simulated 10-year historical solar data will be incorporated into the SCC methodology, until 10 years of actual solar data is accumulated at which point the use of simulated data will be discontinued.

From an adequacy assessment perspective, although the entire installed capacity of the wind and solar generation is included in Ontario's total installed capacity number, the appropriate reduction is applied to the 'Known Maint./Derate/Bottled Cap.' Number to ensure the WCC and SCC values are accounted for when assessing net margins.

Embedded (behind-the-meter) generation reduces the need to grid supplied electricity by generating electricity on the distribution system. Since the majority of embedded generation is solar powered, embedded generation is divided into two separate components – solar and non-solar. Non-solar embedded generation includes generation fuelled by biogas and natural gas, water and wind. Contract information is used to

estimate both the historical and future output of embedded generation. This information is incorporated into the demand forecast model.

Québec

In the Québec area, wind generation plants are owned and operated by Independent Power Producers (IPPs). Nameplate capacity is 3,880 MW for the 2019-20 winter peak period. Of this 3,880 MW, 104 MW is de-rated by 100% and the remainder (3,776 MW) is de-rated by 65 percent. For the next winter period, the wind power contribution is estimated to be 1,352 MW. Behind-the-meter solar generation is estimated at 8 MW for the upcoming winter period.

Demand Response programs

Each Reliability Coordinator area utilizes various methods of demand management. Grid modernization, smart grid technologies, and their resulting market initiatives have created a need to treat some demand response programs as supply-side resources, rather than as a load-modifier. The table below summarizes the expected Dispatchable Demand-Side Management (DDSM) Resources and Interruptible Loads available within the NPCC region for the forecasted peak demand week of January 13, 2019. Definitions of the terms are included in Appendix II (Load and Capacity Tables definitions).

Table 4-13: Summary of Forecasted Demand Response Programs

Reliability Coordinator Area	DDSM Resources (MW)	Interruptible Loads (MW)	Total (MW)
Maritimes	0	303	303
New England	328	0	328
New York	853	40	893
Ontario	924	0	924
Québec	250	2,034	2,284
Total	2,355	2,377	4,732

In the Load and Capacity tables presented in Appendix I, the Dispatchable Demand-Side Management values are accounted for on the resources side (included in Total Capacity) and the Interruptible Loads values are accounted for on the demand side as load modifier.

The total forecasted 2019-20 Winter demand response available for NPCC is 4,732 MW, a 112 MW increase from the forecasted 4,620 MW of winter demand response available during 2018-19.

Maritimes

Interruptible loads are forecast on a weekly basis and range between 243 MW and 364 MW. The values can be found in Table AP-2 and are available for use when corrective action is required within the Area.

New England

In New England, 328 MW of active demand resources are projected to be available on peak for the 2019-20 winter assessment period. In addition to active demand resources, 2,594 MW of passive demand resources (i.e., energy-efficiency measures and conservation) are treated as demand reducers in this report and are accounted for in the load forecast of 20,476 MW. Passive demand measures include installed products, equipment, and systems, as well as services, practices, and strategies, at end-use customer facilities that result in additional and verifiable reductions in the total amount of electrical energy used during on-peak hours. The amount of energy efficiency is based on capacity supply obligations in the Forward Capacity Market.

New York

The NYISO has three demand response programs to support system reliability. The NYISO currently projects 893 MW of total demand response available for the 2019-20 winter season.

The Emergency Demand Response Program (EDRP) is categorized as Interruptible Load. It provides demand resources an opportunity to earn the greater of \$500/MWh or the prevailing locational-based marginal price (“LBMP”) for energy consumption curtailments provided when the NYISO calls on the resource. Resources must be enrolled through Curtailment Service Providers (“CSPs”), which serve as the interface between the NYISO and resources, in order to participate in EDRP. There are no obligations for enrolled EDRP resources to curtail their load during an EDRP event.

The Installed Capacity (ICAP) Special Case Resource program is categorized as Dispatchable Demand-Side Management. It allows demand resources that meet certification requirements to offer Unforced Capacity (“UCAP”) to Load Serving Entities (“LSEs”). The load reduction capability of Special Case Resources (“SCRs”) may be sold in the ICAP Market just like any other ICAP Resource; however, SCRs participate through Responsible Interface Parties (RIPs), which serve as the interface between the NYISO and the resources. RIPs also act as aggregators of SCRs. SCRs that have sold ICAP are obligated to reduce their system load when called upon by the NYISO with two or more hours’ notice, provided the NYISO notifies the Responsible Interface Party a day ahead of the

possibility of such a call. In addition, enrolled SCRs are subject to testing each Capability Period to verify their capability to achieve the amount of enrolled load reduction. Failure of an SCR to reduce load during an event or test results in a reduction in the amount of UCAP that can be sold in future periods and could result in penalties assessed to the applicable RIP in accordance with the ICAP/SCR program rules and procedures. Curtailments are called by the NYISO when reserve shortages are anticipated or during other emergency operating conditions. Resources may register for either EDRP or ICAP/SCR but not both. In addition to capacity payments, RIPs are eligible for an energy payment during an event, using the same calculation methodology as EDRP resources.

The Targeted Demand Response Program (“TDRP”), introduced in July 2007, is a NYISO reliability program that deploys existing EDRP and SCR resources on a voluntary basis, at the request of a Transmission Owner, in targeted subzones to solve local reliability problems. The TDRP program is currently available in Zone J, New York City.

Ontario

Ontario’s demand response is comprised of the following programs: Dispatchable Loads and resources procured through the Demand Response (DR) auction. Demand measures are dispatched like a generation resource and therefore are included in the supply mix.

Load modifiers include energy efficiency (energy-efficiency programs, codes and standards), price impacts (time of use and Industrial Conservation Initiative) and embedded generation. The load modifiers are incorporated into the demand forecast.

For the winter assessment period, the capacity of the demand response program consists of 769 MW of DR auction participants with the balance of 155 MW being made up by dispatchable loads.

Québec

The Québec area has various types of Demand Response resources specifically designed for peak shaving during winter operating periods, having an estimated combined impact of 2,284 MW under winter peak conditions (2019-20).

1. The Interruptible load programs are mainly designed for large industrial customers treated as supply-side resources, totaling 1,719 MW for the 2019-20 winter period. Interruptible load programs are usually used in situations where either the load is expected to reach high levels or when resources are expected to be insufficient to meet peak load demand. Before the peak period, generally during the fall season, all customers are regularly contacted in order to reaffirm their commitment to provide capacity when called, during peak periods.

2. The area is also developing some interventions in demand response (e.g., direct control load management and others) to its customers. One of these programs will expand the existing interruptible load program for commercial buildings which has already shown great results. This program has an anticipated impact of 280 MW in 2019-20 and should reach 595 MW by 2025-26, considering impacts of the expansion. Another similar program for residential customers is under development and should gradually rise from 9 MW for winter 2019-2020 to 635 MW for winter 2028-2029.
3. New dynamic rate options for residential and small commercial or institutional customers will also contribute to reducing peak load during winter periods. Other dynamic rate options are not considered in the long-term forecast as their impact is not yet certain. These options will be accounted for as DSM resource for the Quebec area once sufficient historical data is available to assess their impact.
4. Data centers specialized in blockchain applications, which are part of new developments in the commercial sector, are required to reduce their demand during peak hours at Hydro-Quebec Distribution's request. Their contribution as a resource is expected to peak around 682 MW by winter 2021-2022
5. The voltage reduction program consists of 250 MW that allows the system operator to strategically reduce voltage across designated portions of its distribution system, within regulatory guideline in order to reduce peak demand. This 250 MW is accounted in the "Dispatchable Demande-Side Management" column of the Load and Capacity table presented in Table AP-6.

In additions, Energy Efficiency and Conservation programs are implemented throughout the year by Hydro-Québec Distribution and by the provincial government, through its Ministry of Natural Resources. Energy Efficiency and Conservation programs are integrated in the assessment area's demand forecasts.

5. Transmission Adequacy

Regional Transmission studies specifically identifying interface transfer capabilities in NPCC are not normally conducted. However, NPCC uses the results developed in each of the NPCC Reliability Coordinator Areas and compiles them for all major interfaces and for significant load areas (Appendix III). Recognizing this, the CO-12 Working Group reviewed the transfer capabilities between the Balancing Authority Areas of NPCC under normal and peak demand configurations.

The following is a transmission adequacy assessment from the perspective of the ability to support energy transfers for the differing levels, Inter-Region, Inter-Area and Intra-Area.

Inter-Regional Transmission Adequacy

Ontario – Manitoba Interconnection

The Ontario – Manitoba interconnection consists of two 230 kV circuits and one 115 kV circuit. The transfers on the 230 kV are constrained by stability and thermal limitations; 300 MW for exports and imports. The transfers on the 115 kV is limited to 68 MW into Ontario, with no export allowed.

Ontario – Minnesota Interconnection

The Ontario – Minnesota interconnection consists of a single 115 kV circuit, with total transfer capability constrained by stability and thermal limitations to 150 MW exports and 100 MW imports.

Ontario – Michigan Interconnection

The Ontario – Michigan interconnection consists of two 230/345 kV circuits, one 230/115 kV circuit, and one 230 kV circuit with a total transfer capability export limit of 1,750 MW and an import limit of 1,750 MW which are all constrained by thermal limitations. There are four phase angle regulators in service to help manage flows on this interface.

New York – PJM Interconnection

The New York – PJM interconnection consists of one PAR controlled 500/345 kV circuit, one uni-directional DC cable into New York, one uni-directional DC/DC controlled 345 kV circuit into New York, two free flowing 345 kV circuits, a VFT controlled 345/230 kV circuit, five PAR controlled 345/230 kV circuits, two free flowing 230 kV circuits, three 115 kV

circuits, and a 138/69 kV network serving a PJM load pocket through the New York system.

The 230/345 kV “B” and “C” PAR controlled lines are currently out-of-service and expected to remain so at least through the end of the winter season.

Inter-Area Transmission Adequacy

Appendix III provides a summary of the Total Transfer Capabilities (TTC) on the interfaces between NPCC Reliability Coordinator areas and for some specific load zone areas. They also indicate the corresponding Available Transfer Capabilities (ATC) based on internal limitations or other factors and indicate the rationale behind reductions from the Total Transfer Capability. The table below summarizes the transfer capabilities between Areas:

Table 5-1: Interconnection Total Transfer Capability Summary

Area	Total Transfer Capability (MW)
Transfers from Maritimes to	
Québec	770
New England	1,000
Transfers from New England to	
Maritimes	550
New York	1,840
Québec	1,370
Transfers from New York to	
New England	2,230
Ontario	2,000
PJM	2,150
Québec	1,100
Transfer from Ontario to	
MISO	2,200
New York	2,100
Québec	2,170
Transfers from Québec to	
Maritimes	773 + radial loads
New England	2,275
New York	1,999
Ontario	2,955

Area Transmission Adequacy Assessment

Transmission system assessments are conducted in order to evaluate the resiliency and adequacy of the bulk power transmission system. Within each region, areas evaluate the ongoing efforts and challenges of effectively managing the reliability of the bulk transmission system and identifying transmission system projects that would address local or system wide improvements. The CO-12 Working Group reviewed the forecasted conditions for the Winter 2019-20 Operating Period under normal and peak demand configurations and have provided the following review as well as identified transmission improvements listed in Table 5-2.

Table 5-2: NPCC – Recent and Future Transmission Additions

NPCC Sub-Area	Transmission Project	Voltage (kV)	In Service
Maritimes	-	-	-
New England	Mystic 345B	345/115	Q2 2019
	Wakefield Reactor	345	Q2 2019
	Woburn Reactor	345	Q3 2019
	F107 (Portsmouth – Madbury)	115	Q2 2020
New York	Cricket Valley Substation	345	Q3 2019
	E. 13 th St Reconfig. Complete	345	Q3 2019
	Rainey-Corona Tie line w/ PAR	345/138	Q3 2019
	2 nd Transformer at Watercure	345/115	Q4 2019
	Marcy-South Series Compensation SSR Relays	345	Q1 2019
Ontario	Niagara Reinforcement Project (Q26M, Q35M)	230	Q3 2019
Québec	Line from Chamouchouane substation to Montréal area	735	Q2 2019

Maritimes

The Maritimes bulk transmission system is projected to be adequate to supply the demand requirements for the Winter Operating Period. Part of the Total Transfer Capability (TTC) calculation with Quebec is based on the ability to transfer radial loads

onto the Quebec system. The radial load value will be calculated monthly and Quebec will be notified of the changes (See Appendix III).

A 500 MW (475 MW received in Nova Scotia) High Voltage Direct Current (HVDC) undersea cable link (Maritime Link) between Newfoundland, Labrador and Nova Scotia was installed in late 2017; however, the 153 MW firm capacity contract from the Muskrat Falls hydro development in Labrador is not expected until mid-2020. The firm capacity contract is expected to facilitate the retirement of a 153 MW coal-fired unit in Nova Scotia by mid-2020, thus the overall resource adequacy will be unaffected by these changes. Currently the Maritime Link is being used as an additional tie line providing minimal energy flow between Nova Scotia and Newfoundland.

New England

Numerous transmission upgrades continue to be commissioned to address New England's reliability needs. These transmission improvements have reinforced the overall reliability of the electric power system and reduced congestion, enabling power to flow more easily around the entire region. The improvements support decreased energy costs and increased power system flexibility.

The Wakefield and Woburn variable reactors and Mystic 345B transformer are components of the Greater Boston Reliability Project. This project identified transmission reinforcements required in the Boston area to reliably continue to serve the area's increasing load. The reactors, which are 70-160 MVar each, will provide high voltage control and will mitigate the need for unit commitment in Boston during the overnight periods. The 345B transformer mitigates Mystic generation export constraints within Boston. This allows Mystic to supply additional generation to help serve Boston load.

The F107 line (Portsmouth – Madbury) provides additional support to the import-constrained New Hampshire Seacoast area. Once the F107 line goes into service, generator must – run requirements for the Seacoast area will be significantly lower and local area fast-starts can be utilized in emergency scenarios as opposed to normal operating conditions.

New York

Since the last Winter Operating Period, four transmission modifications have come into service. In Q1 of 2019 the current Special Protection System for the Marcy South Series Compensation was replaced through the addition of Sub-Synchronous Resonance (SSR) detecting relays at the Fraser Annex station. In Q3 of 2019 the Cricket Valley substation

came into service as the interconnection point for the generating station of the same name, the E. 13th Street Station Reconfigurations was completed, and a new 345/115 kV PAR controlled Rainey-Corona tie line came in-service.

In addition, a second 345/115 kV transformer is expected to be in-service at Watercure in Q4 of 2019.

Ontario

For this Winter Operating Period, Ontario's transmission system is expected to be adequate with planned transmission system enhancements and scheduled transmission outages under normal and extreme conditions. Ontario has an expected coincident import capability of approximately 5,200 MW.

The Niagara region transmission reinforcement project was completed on August 30, 2019. This 230kV transmission system improvement increased the summertime transfer capability from the Niagara region to the rest of Ontario by approximately 800 MW.

The Phase Angle Regulator (PAR) connected to the 230kV Ontario-NY interconnection circuit L33P remains out of service (forced) with an in-service date expected to be November 2021. Having the PAR and by association L33P out of service has resulted in a tighter band of operation on our New York-St. Lawrence interconnection, and within Ontario at St. Lawrence. These constraints impact our ability to import from NY through the New York-St. Lawrence interconnection and from Quebec through the Beauharnois interconnection. The long-term outage also requires more focused management of area resources in real-time, and introduces complexity in responding to forced outages and planning maintenance outages.

Outages affecting neighboring jurisdictions can be found in Table 5-3: Area Transmission Outage Assessment. Based on the information provided, Ontario does not foresee any transmission issues for the winter season.

Québec

The Québec area is winter-peaking and no transmission equipment is scheduled for maintenance outages during this period. No major transmission project has been commissioned since last winter assessment.

In the Lac-Saint-Jean region, four transmission lines bring power to the Chamouchouane and Saguenay substations from the north (from Baie-James on one side, and Côte-Nord on the other), while only three run southwards. This creates a funnel effect and limits the system's capacity to bring power to the south, where the major load centers are located.

As a result, the transmission system have been reinforced between Chamouchouane substation and the Montréal metropolitan loop to counter the funnel effect and reduce pressure on the entire system. A new 735-kV line (250 miles or 400 km) has been commissioned in 2019 that will reduce electrical losses on the system and increase operating flexibility, benefiting all Hydro-Québec customers.

Area Transmission Outage Assessment

The section below outlines any known scheduled outages on interfaces between Reliability Coordinators.

Table 5-3: Area Transmission Outage Assessment

Maritimes

No planned outages to materially impact the transfer capabilities at this time.

New England

Impacted Area	Interface Impacted	Planned Start	Planned End	Reduction in Limit
New Brunswick	3001 line	2019/12/02	2019/12/04	NB-NE limited to 345-700 MW based on system condition (up to -655MW)
New York	354 line	2019/12/03	2019/12/20	NY-NE limited to 1200 MW (-200MW) NE-NY limited to 600 MW (-600 MW)
New York	387 line	2019/12/12	2019/12/20	NY CSC-NE = 0 MW (-346 MW) NE-NY CSC = 0 MW (-330 MW)
New York	387 line	2020/03/02	2020/03/03	NY CSC-NE = 0 MW (-346MW) NE-NY CSC = 0 MW (-330 MW)
New York	354 line	2020/03/09	2020/04/03	NY-NE limited to 1200 MW (-200MW) NE-NY limited to 600MW (-600 MW)

New York

Impacted Area	Interface Impacted	Planned Start	Planned End	Reduction in Limit
Ontario	Niagara 345/230 kV AT4	2019/10/23	2019/12/17	NY-ON limited to 1,400 MW (-300 MW Export)

Ontario

Impacted Area	Interface Impacted	Planned Start	Planned End	Reduction in Limit
New York	NY St. Lawrence (L33P)	2018/04/30	2021/11/01	Dependent on dispatch
New York	NY Niagara (PA27)	2020/02/03	2020/02/13	0 MW
New York	NY Niagara (PA27)	2020/03/30	2020/05/29	0 MW

Québec

Impacted Area	Interface Impacted	Planned Start	Planned End	Reduction in Limit
Ontario	P33C line	2019/09/30	2019/12/13	HQT-P33C = 0 MW (-345 MW Export)

6. Operational Readiness for Winter 2019-20

NPCC

NPCC promotes and provides a forum for the active coordination of reliability and operation of the international, interconnected bulk power system within Northeastern North America. NPCC Task Forces and Working Groups support continued reliability operations through reviewing and assessing the performance of the bulk power system.

In addition to conducting pre-seasonal reliability assessments, the NPCC also coordinates periodic and specific operational communications to ensure that potential system changes and outages for operations are reviewed. Whenever adverse system operating or weather conditions are expected or encountered, any RC Area or NPCC Staff, may request an Emergency Preparedness Conference Call to discuss issues related to the adequacy and security of the interconnected bulk power supply system with appropriate operations management personnel from the NPCC RC Areas, NPCC staff and neighboring systems. These procedures are frequently tested on a continual basis throughout the year. NPCC also conducts Weekly Conference Calls to review a seven-day outlook for the Region, including largest contingencies, margins and weather, as well as to ensure that future system changes, such as generation and transmission outages that have the potential to affect neighboring Areas are coordinated.

The NPCC TFCO is reviewing the findings and recommendations of the 2019 FERC and NERC Staff Report, *The South Central United States Cold Weather Bulk Electric System Event of January 17, 2018*⁶ to determine appropriate follow-up actions. Some Areas are in the process or have already incorporated recommendations of the report into their Winter preparedness programs, including enhancing pre-seasonal generator readiness surveys.

Lastly, NPCC supports Electric-Gas Operations reliability coordination efforts to promote communications, awareness and information sharing.

In addition to coordinated regional activities, NPCC Reliability Coordinator-specific readiness activities are detailed below.

⁶The South Central United States Cold Weather Bulk Electric System Event of January 17, 2018 (July 18, 2019), <https://www.ferc.gov/legal/staff-reports/2019/07-18-19-ferc-nerc-report.pdf>

Maritimes

Voltage Control

The Maritimes area, in addition to the reactive capability of the generating units, employs a number of capacitors, reactors, synchronous condensers and a Static Var Compensator (SVC) in order to provide local area voltage control.

Operational Procedures

The Maritimes area is a winter peaking system and does not anticipate any operational issues. Some of these ascertain planning and Emergency Operating mitigations, or Energy Emergency Alerts could be needed under extreme peak demand and certain outage scenarios within these procedures include the following:

- Use of interruptible load curtailments
- Purchase of Emergency Energy in accordance with Interconnection Agreements
- Curtailment of export energy sales
- Public Appeals
- Shedding of Firm Load

For changes to internal operating conditions (i.e. transmission and or generator outages) these will be handled with Short Term Operating Procedures (STOP) which would outline any special operating conditions.

Winter Preparation

As part of the winter planning process, dual-fueled units will have sufficient supplies of heavy fuel oil (HFO) on-site to enable sustained operation in the event of natural gas supply interruptions.

Wind Integration

Monitoring of thermal unit dispatch under high wind / low load periods (e.g. shoulder season overnight hours) is an area of focus; work to assess steam unit minimum loads and minimum steam system configurations is ongoing.

New England

Zonal Load Forecasting

New England continues to use the Metrix Zonal load forecast, which produces a zonal load forecast for the eight regional load zones through the current operating day and up to six days in advance. This forecast enhances reliability by taking into account weather differences across the region, which may distort the normal distribution of load. An example would be when the Boston zone temperature is forecasted to be 5 degrees Fahrenheit (°F), while the Hartford-area temperature is forecasted at 30 °F. This zonal forecast approach provides a better New England load forecast, resulting in an improved reliability commitment across the region.

Natural Gas Supply

Because natural gas continues to be the predominant fuel source in New England to produce electricity, ISO-NE continues to closely monitor factors affecting the deliverability of natural gas throughout the winter reliability assessment period. ISO-NE has reviewed natural gas pipeline maintenance schedules and determined that they should have no adverse impact on gas availability for the 2019-20 assessment period. However, ISO-NE does anticipate the potential for various amounts of single-fuel, gas-only power plants to be temporarily unavailable during cold or extreme winter weather or during force majeure conditions on the regional gas infrastructure. ISO-NE forecasts more than 4,500 MW of natural-gas-fired capacity may be at risk for this winter period. As needed, ISO-NE would mitigate generator fuel deliverability issues with real-time supplemental commitment and the use of emergency procedures.

ISO-NE currently utilizes the pay-for-performance (PFP) market design⁷. PFP aims to create strong financial incentives for all capacity suppliers, without exception, to maximize their performance and availability during scarcity conditions (i.e., during operating-reserve deficiencies). ISO-NE also calculates the Energy Market Opportunity Cost (EMOC) to improve resource-specific mitigation procedures by calculating an estimated daily opportunity cost for oil and dual fuel resource with limitations on energy production over a 7-day horizon. Starting December 3, 2019, this calculation will be performed twice per day – once before the close of the Day Ahead market, the second after the Day Ahead market closes.

⁷ Information about the FERC approved pay-for-performance market design is available at *Order on Tariff Filing and Instituting Section 206 Proceeding* (FERC order), 147 ¶ 61,172 (May 30, 2014), https://www.iso-ne.com/regulatory/ferc/orders/2014/may/er14-1050-000_5-30-14_pay_for_performance_order.pdf.

New England surveys fossil-fueled generators on a weekly basis to monitor and confirm their current and expected fuel availability throughout the winter period. If conditions require more frequent updates, these surveys may be sent daily. ISO-NE also requests gas-fired generators to confirm adequate gas nominations to meet their day-ahead obligations daily, and if system conditions call for it, these requests could occur more frequently.

During the 2019-2020 Winter Operating Period, ISO-NE will continue to participate in weekly NPCC conference calls to share information on current and forecasted operating conditions. ISO-NE will continue to coordinate and communicate with the regional natural gas industry regarding planned outages, unplanned outages, and real-time operating conditions to promote the reliability of the bulk electric system. ISO-NE has several procedures that can also be invoked to mitigate regional fuel-supply emergencies adversely affecting the power generation sector:

1. Operating Procedure No. 4 (OP 4), *Action During a Capacity Deficiency*, establishes criteria and guidelines for actions during capacity deficiencies resulting from generator and transmission contingencies and prescribes actions to manage operating-reserve requirements⁸.
2. Operating Procedure No. 7 (OP 7), *Action in an Emergency*, establishes criteria to be followed in the event of an operating emergency involving unusually low frequency, equipment overload, capacity or energy deficiency, unacceptable voltage levels, or any other emergency ISO-NE deems needing resolution through an appropriate action in either an isolated or widespread area of New England⁹.

⁸ ISO New England, *Operating Procedure No. 4, Action During a Capacity Deficiency* (May 7, 2019), <https://www.iso-ne.com/participate/rules-procedures/operating-procedures>

⁹ ISO New England, *Operating Procedure No. 7, Action in an Emergency* (January 4, 2019), <https://www.iso-ne.com/participate/rules-procedures/operating-procedures>

3. Operating Procedure No. 21 (OP 21), Energy Inventory Accounting and Action During an Energy Emergency, helps mitigate the adverse impacts on bulk power system reliability resulting from the loss of operable capacity due to regional fuel-supply deficiencies that can occur anytime¹⁰. Fuel-supply deficiencies are the temporary or prolonged disruption to regional fuel-supply chains for coal, natural gas, liquefied natural gas (LNG), and heavy and light fuel oil.

OP 21 was modified in the fall of 2018 to allow for an enhanced energy-alert procedure, which includes the following:

- Development of an energy forecasting and reporting framework to establish energy-alert thresholds based on an energy assessment over the next 21 days of operation that includes fuel availability and allowable emissions availability, as well as the anticipated availability of fuel infrastructure and supplies
- Establishing forecast-alert thresholds the ISO would issue on the basis of its energy assessments
- Use of the forecasting and reporting process to inform the declaration of Energy Alerts and Energy Emergencies, which would allow for proactive responses in advance of an Energy Emergency declaration.

New York

Operational Readiness

The New York Independent System Operator (NYISO), as the sole Balancing Authority for the New York Control Area (NYCA), anticipates adequate capacity exists to meet the New York State Reliability Council's (NYSRC) Installed Reserve Margin (IRM) of 17% for the 2019-20 winter season.

The weather-normalized 2018-19 winter peak was 24,114 MW, 155 MW (0.6%) lower than the forecast of 24,269 MW. The current 2019-20 peak forecast is 24,123 MW, 146 MW (0.4%) less than the previous year. It is 605 MW (3.2%) less than the actual winter

¹⁰ ISO New England, Operating Procedure No. 21, *Energy Inventory Accounting and Actions During an Energy Emergency* (October 19, 2018), <https://www.iso-ne.com/participate/rules-procedures/operating-procedures>

peak in 2018-19 of 24,728 MW. This forecast load is 3.9% lower than the all-time winter peak load of 25,738 MW set in winter 2013-14 on January 7, 2014.

There are two higher-than-expected scenarios forecast. One is a forecast without the impacts of energy efficiency programs. The second is a forecast based on extreme weather conditions, set to the 90th percentile of typical peak-producing weather conditions. These are 24,537 MW and 25,724 MW respectively.

The lower forecasted growth in energy usage can largely be attributed to the projected impact of existing statewide energy efficiency initiatives and the growth of distributed behind-the-meter energy resources encouraged by New York State energy policy programs such as the Clean Energy Fund (CEF), the NY-SUN Initiative, and other programs developed as part of the Reforming the Energy Vision (REV) proceeding. The NYISO expects that these and other programs currently being developed to further implement the 2015 New York State Energy Plan will continue to affect forecasted seasonal peak demand and energy usage for the foreseeable future.

No unique operational problems were observed from NYISO capability assessment studies. The NYISO maintains Joint Operating Agreements with each of its adjacent Reliability Coordinators that include provisions for the procurement, or supply, of emergency energy, and provisions for wheeling emergency energy from remote areas, if required. Prior to the operating month, the NYISO communicates to neighboring control areas both the capacity-backed import and export transactions that are expected for the NYCA in the upcoming month. Discrepancies identified by neighboring control areas are resolved. During the 2019-20 winter season, the New York Balancing Authority expects to have 853 MW of net import capacity available.

The NYISO anticipates sufficient resources to meet peak demand without the need to resort to emergency operations. The Emergency Demand Response Program (EDRP) and ICAP/Special Case Resource program (ICAP/SCR) are designed to promote participation and the expectation is for full participation. Further control actions are outlined in NYISO policies and procedures. There is no limitation as to the number of times a resource can be called upon to provide response. Special Case Resources are required to respond when notice has been provided in accordance with NYISO's procedures; response from EDRP is voluntary for all events.

NYISO is monitoring the potential for natural gas supplies to electric generators to be affected by natural gas infrastructure maintenance scheduled through the end of December. Potential risk to the Bulk Power System is mitigated by extensive dual-fuel generator capability. Generator preparations are informed by prior winter experience and

include increased on-site fuel reserves, firm contracts with suppliers of back-up fuel, aggressive replenishment plans, and proactive pre-winter maintenance.

In addition to the resources evaluated hitherto, Emergency Operating Procedures are available to provide up to 3,000 MW of resources should the need arise. Reducing Operating Reserves to zero is also an option in extenuating circumstances to avoid load shed.

Winter Readiness

The NYISO Market Mitigation and Analysis Department performed on-site visits of several generating stations to discuss past winter operations and preparations for winter 2019-20. Their visits focused on units with low capacity factors. A pre-visit questionnaire included assessments of natural gas availability during peak conditions, issues associated with burning or obtaining oil, emissions limitations, preventative maintenance plans, causes of failed starts, programs to improve performance, and programs in place to insure switchyard reliability. They found that generators have increased generation testing, cold-weather preventative maintenance, fuel capabilities, and fuel switching capabilities to improve winter operations.

In the winter of 2013-14, the NYISO instituted a Cold Weather Survey. This survey is sent to all generators and assesses their primary and secondary fuel inventories. This survey is sent prior to the winter season to get baseline numbers and then on a weekly basis. In addition, the survey is sent on days in which extreme temperatures are forecast, in order to enhance real-time situational awareness. The survey allows operators to monitor gas nominations, oil inventories, and expected oil replenishment schedules for all dual-fuel, gas-fired, and oil-fired generators prior to each cold day. This procedure will be in place for winter 2019-20.

Gas Electric Coordination

Enhanced Operator visualization of the gas system is in place in the NYISO Control Center. Weekly and daily dashboards are issued during cold weather conditions indicating fuel and capacity margin status. An emergency communication protocol is in place to communicate electric reliability concerns to pipelines and gas distribution centers during tight electric operating conditions.

The NYISO conducted a loss of gas installed capacity assessment to determine the impact on operating margins should gas shortages arise. It found that 5,232 MW of gas fired generation with non-firm supply are at risk. Should all of this capacity not be available

during a peak load time, the project operating margin would drop from 11,432 MW (47.4%) to 6,200 MW (25.7%)

The NYISO continues to work on improving gas-electric coordination to enhance reliability and availability of gas fueled units in the future. The NYISO is also considering potential market changes to provide incentives to generators to maintain alternate fuel availability.

Ontario

Base Load

Ontario will continue to experience potential surplus baseload conditions during the Outlook period. However, the magnitude and the frequency of the SBG are reduced with the nuclear refurbishment process in flight since 2016. It is expected that SBG will continue to be managed effectively through existing market mechanisms, which includes intertie scheduling, the dispatch of grid-connected renewable resources and nuclear maneuvers or shutdown.

Voltage Control

Ontario does not foresee any voltage management issues this winter season. However, as high voltage situations arise during periods of light load, the removal of at least one 500 kV circuit may be required to help reduce voltages. Planning procedures are in place to ensure adequate voltage control devices are available during outage conditions when voltage control conditions are more acute. To address high voltage issues on a more permanent basis, the IESO has requested additional high voltage reactors at Lennox TS with a target in-service date of Q4-2020.

Distributed Energy Resources (DERs)

With contributions from DERs growing in Ontario, the IESO has seen periods where these resources have significantly reduced demand by offsetting the load on the distribution system and, in some cases, supplying enough energy to flow energy back into the transmission system. This creates challenges in how the IESO forecasts Ontario demand and in changing transmission flow patterns across the province. The rising penetration of DERs means that more data needs to be shared between the IESO and LDCs and DER operators to provide the control room visibility required to improve forecasting and dispatch.

Operating Procedures

Ontario expects to have sufficient electricity to meet its forecasted demand. To prepare for the peak seasons, the IESO meets with gas pipeline operators every six months to discuss gas supply and planned maintenance on the gas and electric systems. Since winter 2015-16, the IESO has formalized a Unit Readiness program that exercises units which have been offline for a significant length of time to ensure their readiness for peak periods.

Québec

Extreme load weather and extreme temperatures

Extreme cold weather results in a large load pickup over the normal demand forecast. This situation is addressed at the planning stage through TransÉnergie's Transmission Design Criteria. When designing the system, one particular criterion requires that both steady state and stability assessments be made with winter scenarios involving demands 4,000 MW higher than the normal weather peak demand forecast. This is equivalent to 110% of peak winter demand. This ensures that the system is designed to carry the resulting transfers while conforming to all design criteria. Resources needed to feed the load during such episodes must be planned and provided by Hydro-Québec Distribution, the Load Serving Entity.

On an operations horizon, if peak demands are higher than expected, a number of measures are available to the System Control personnel. Operating Instruction 33199-I-001 lists such measures:

- Limitations on non-guaranteed wheel through and export transactions
- Operation of hydro generating units at their near-maximum output (away from optimal efficiency, but still allowing for reserves)
- Use of import contracts with neighbouring systems
- Use of interruptible load programs
- Reducing 30-minute reserve and stability reserve
- Applying voltage reduction
- Making public appeals
- Ultimately, using cyclic load shedding to re-establish reserves

Most of the Québec area hydro generators are located in the north of the province, where extremely cold ambient temperatures often occur during winter periods. Specific Design requirements are implemented to ensure that extreme ambient temperature does not

affect operations. In case of any issues that might arise in real time, Maintenance Notices are issued to operators to handle such concerns.

Voltage control

Voltage support in the southern part of the system (load area) might be a concern during Winter Operating Periods, especially during episodes of heavy load. Hydro-Québec Production (the largest producer on the system) ensures that maintenance on generating units is finished by December 1, and that all possible generation is available. This, along with yearly testing of reactive capability of the generators, ensures maximum availability of both active and reactive power.

Voltage variations on the high voltage transmission system are also of some concern. These are normal variations due to changes in transmitted power from North to South during load pickup and interconnection ramping. In this situation, the system has to meet a specific Transmission Design Criterion concerning voltage variations on the system. This criterion quantifies acceptable voltage variations due to load pickup and/or interconnection ramping. All planning and operating studies must now conform to this criterion.

7. Post-Seasonal Assessment and Historical Review

Winter 2018-19 Post-Seasonal Assessment

The sections below describe each Reliability Coordinator area's winter 2018-19 operational experiences.

The NPCC coincident peak of 109,218 MW occurred on January 21, 2019 HE18 EST. It was 107 MW lower than the forecasted load of 109,325 MW.

Maritimes

The Maritimes system demand during the NPCC coincident peak was 4,549 MW. Maritimes actual peak was 5,265 MW on January 18, 2019 at HE7 EST.

All major transmission and interconnections were in service.

New England

The New England system actual peak demand of 20,719 MW occurred on January 21, 2019 HE18 EST and was coincident to the NPCC peak.

ISO-NE did not experience any extended cold weather days and was not required to issue any energy-alerts per the OP 21 procedure.

New York

The actual peak demand of 24,728 MW occurred on January 21, 2019 HE19 EST.

During the 2018-19 Winter Operating Period, the NYISO did not experience transmission or reactive capability issues, and was not required to utilize firm load shedding or emergency procedures.

Ontario

The actual peak demand was 21,525 MW on January 21, 2019 HE18 EST and was coincident to the NPCC peak.

Overall, the 2018-2019 winter weather averaged close to normal. Energy demand for the three months from December to February was up 0.1% compared with the same three months one year prior. After adjusting for the weather, demand for the three months showed an increase of 0.3%.

Since the 2009 recession, the grid-supplied energy demand has been fairly flat with small increases and decreases year-to-year. Going into 2020, a strong U.S. economy and low

Canadian dollar will help boost demand in the industrial sector, while population growth and consumer activity should help increase electricity demand in the residential and commercial markets.

Québec

During the NPCC coincident peak, the Québec demand was 37,810 MW and the actual peak demand of 38,364 MW occurred on January 22, 2019 at HE8 EST. The internal demand forecast was 38,461 MW for the 2018-19 Winter Operating Period.

At the time of the Québec peak, net exports of 2,303 MW were sustained by the Québec Balancing Authority. Moreover, 997 MW of interruptible industrial load was called for the peak hour. Wind power plants were generating 3,152 MW, 81% of the wind nameplate capacity which is more than twice times the assumption number used in this assessment (35% of total wind capacity during the winter peak period). During the 2018-19 Winter peak period, appeals to the public were not required.

The actual peak demand for the Winter 2018-19 (38,364 MW) was lower than the historical peak demand of 39,240 MW that occurred during the 2013-14 Winter Operating period.

Historical Winter Demand Review

The table below summarizes historical non-coincident winter peaks for each NPCC Balancing Authority area over the last ten years along with the forecasted normal coincident peak demand for Winter 2019-20. Highlighted values are record demand that occurred during the NPCC Winter Operating Period over the last 10 years.

Table 7-1: Ten Year Historical Winter Peak Demands (MW)

Winter	Maritimes	New England	New York	Ontario	Québec	NPCC Coincident Demand	Date
2009-10	5,205	20,791	24,074	22,045	34,659	-	-
2010-11	5,252	21,495	24,654	22,733	37,717	-	-
2011-12	4,963	19,926	23,901	21,649	35,481	-	-
2012-13	5,431	20,877	24,658	22,610	38,797	111,127	23-Jan-13
2013-14	5,467	21,453	25,738	22,774	39,240	111,801	2-Jan-14
2014-15	5,314	20,583	24,648	21,814	38,950	108,092	8-Jan-15
2015-16	5,237	19,545	23,317	20,836	37,650	102,466	15-Feb-16
2016-17	5,418	19,647	24,164	20,688	37,200	104,335	16-Dec-16
2017-18	5,344	20,631	25,081	20,906	38,410	109,117	5-Jan-18
2018-19	5,265	20,719	24,728	21,525	38,364	109,218	21-Jan-19
2019-20 Forecasted	5,528	20,476	24,123	21,115	38,665	109,163	19-Jan-20

*NPCC Coincident Peak data is unavailable prior to the 2012-13 Winter Operating Period.

The following table presents the all-time peak demand for each NPCC area with the corresponding date and time.

Table 7-2 : All-Time Peak Demand by Area

Reliability Coordinator Area	Load (MW)	Date and time
Maritimes	5,716	January 16, 2004 HE08 EST
New England	22,818	January 15, 2004 HE19 EST
New York	25,738	January 7, 2014 HE19 EST
Ontario	24,979	December 20, 2004 HE18 EST
Québec	39,240	January 22, 2014 HE08 EST

8. 2019-20 Winter Reliability Assessments of Adjacent Regions

For a comprehensive review of the Reliability First Corporation Seasonal Resource, Demand and Transmission Assessment, go to:

<https://www.rfirst.org/ProgramAreas/RAPA/>

For reviews of the other NERC Regional Entities and Assessment Areas, please go to:

<http://www.nerc.com/pa/RAPA/ra/Pages/default.aspx>

9. CP-8 2019-20 Winter Multi-Area Probabilistic Reliability Assessment Executive Summary

This assessment was prepared by the CP-8 Working Group to estimate the use of the available NPCC Area Operating Procedures to mitigate resource shortages from the November 2019 through March 2020 period. Please refer to Appendix VIII (page 25 – Table 9) for a description of the Base Case and Severe Case Assumptions.

Base Case Scenario

Under Base Case conditions, only the Maritimes Area estimates a likelihood of using their operating procedures designed to mitigate resource shortages (reducing 30-min reserve and initiating interruptible loads) during the 2019/20 winter period for the expected load forecast (representing the probability weighted average of all seven load levels).

Extreme Peak Load

The results for the extreme load forecast (representing the second to highest load level, having approximately a 6% chance of occurring) estimates a likelihood of the Maritimes Area using their operating procedures designed to mitigate resource shortages (reducing 30-min reserve and initiating interruptible loads, and reducing 10-min reserve) during the 2019/20 winter period.

The results are primarily driven by Nova Scotia's forecast load and corresponding reserve margin expectations.

Severe Case Scenario

The Maritimes Area estimated use of operating procedures increases assuming Severe Case conditions, especially for the extreme load forecast; again, these results are primarily driven by Nova Scotia's forecast load and corresponding reserve margin expectations. The Hydro-Quebec and Ontario Areas show use of their operating procedures (activation of DR/SCR, reduction of 30-min reserve) for the Severe Case, extreme load forecast assumptions.

Appendix I – Winter 2019-20 Normal Load and Capacity Forecasts

Orange highlighting indicates the peak week on the table. Blue highlighting indicates the NPCC coincident peak week.

Table AP-1 - NPCC Summary

Area	Revision Date	NPCC	Control Area Load and Capacity												
Week Beginning SUNDAYS	Installed Capacity MWh	Net Interchange MWh ¹	Dispatchable DSM MWh ²	Total Capacity MWh ³	Load Forecast MWh	Interruptible Load MWh	Known Maint./Derat. MWh	Req. Operating Reserve MWh	Unplanned Outages MWh	Total Outages MWh	Net Margin MWh ⁴	Net Margin %	Revised Net Margin MWh ⁴	Revised Net Margin %	
1-Dec-19	167,398	869	2,355	170,622	97,576	2,392	26,952	8,885	11,519	38,471	28,082	28.8%	25,393	26.0%	
8-Dec-19	167,398	1,169	2,355	170,922	101,613	2,406	23,237	8,885	12,222	35,459	27,371	26.9%	25,174	24.8%	
15-Dec-19	167,398	1,169	2,355	170,922	102,950	2,370	21,569	8,885	12,420	33,989	27,468	26.7%	26,125	25.4%	
22-Dec-19	167,398	1,169	2,355	170,922	102,447	2,334	20,230	8,885	12,940	33,170	28,754	28.1%	27,847	27.2%	
29-Dec-19	167,391	1,169	2,355	170,915	103,105	2,368	20,282	8,885	13,349	33,631	27,662	26.8%	24,815	24.1%	
5-Jan-20	167,391	1,169	2,355	170,915	107,337	2,317	21,006	8,885	12,773	33,779	23,231	21.6%	22,938	21.4%	
12-Jan-20	167,391	1,169	2,355	170,915	108,704	2,411	20,932	8,885	13,142	34,074	21,663	19.9%	21,663	19.9%	
19-Jan-20	167,391	1,169	2,355	170,915	109,163	2,377	21,661	8,885	12,851	34,512	20,732	19.0%	20,732	19.0%	
26-Jan-20	167,391	1,169	2,355	170,915	108,948	2,371	21,341	8,719	12,875	34,216	21,403	19.6%	21,403	19.6%	
2-Feb-20	167,691	1,169	2,355	171,215	105,506	2,387	22,525	8,719	13,049	35,574	23,803	22.6%	23,803	22.6%	
9-Feb-20	167,691	1,169	2,355	171,215	104,312	2,427	23,666	8,719	12,513	36,169	24,442	23.4%	24,442	23.4%	
16-Feb-20	167,691	1,169	2,355	171,215	102,863	2,390	23,765	8,719	12,124	35,889	26,134	25.4%	25,566	24.8%	
23-Feb-20	167,691	1,169	2,355	171,215	101,329	2,359	23,918	8,719	11,210	35,128	28,398	28.0%	26,944	26.6%	
1-Mar-20	168,823	1,169	2,355	172,347	99,659	2,391	26,353	8,719	9,689	36,042	30,318	30.4%	28,159	28.3%	
8-Mar-20	168,983	1,169	2,355	172,607	98,188	2,422	28,544	8,719	9,459	38,003	30,019	30.6%	28,185	28.7%	
15-Mar-20	168,983	1,169	2,355	172,507	95,582	2,438	28,933	8,719	8,396	37,329	33,315	34.9%	30,694	32.1%	
22-Mar-20	168,983	1,169	2,355	172,507	92,889	2,372	30,690	8,719	7,869	38,559	34,712	37.4%	30,685	33.0%	
29-Mar-20	168,939	1,169	2,468	172,576	89,255	2,327	31,523	8,985	7,758	39,281	37,382	41.9%	31,082	34.8%	

Key

Highlighted week beginning 19-Jan-20 denotes the NPCC forecasted coincident peak demand and minimum Revised Net Margin.
Highlighted week beginning 29-Mar-20 denotes week with the largest forecasted NPCC "Revised Net Margin".

Notes

- (1) Net interchange represents purchases and sales with Areas outside of NPCC
- (2) Dispatchable Demand-Side Management (DDSM) are demand resources assets that help meet an Area's electricity needs by reducing consumption.
- (3) Total Capacity = Installed Capacity + Net Interchange + Dispatchable Demand Response
- (4) Net Margin = Total Capacity - Load Forecast + Interruptible Load - Known maintenance - Operating reserve - Unplanned Outages
- (5) Revised Net Margin = Net Margin - Bottled resources

Table AP-2 – Maritimes

Area Maritimes
 Revision Date October 30, 2019

Control Area Load and Capacity

Week Beginning Sundays	Installed Capacity MW	Net Interchange MW	Dispatchable DSM MW	Total Capacity MW	Normal Forecast MW	Interruptible Load MW	Known Maint./Derat. MW ¹	Req. Operating Reserve MW	Unplanned Outages MW	Net Margin MW	Net Margin %
1-Dec-19	7,755	-110	0	7,755	4,833	318	1,413	893	200	734	15.2%
8-Dec-19	7,755	-110	0	7,755	5,068	332	1,263	893	200	663	13.1%
15-Dec-19	7,755	-110	0	7,755	5,025	296	1,263	893	200	670	13.3%
22-Dec-19	7,755	-110	0	7,755	5,211	260	1,118	893	200	593	11.4%
29-Dec-19	7,748	-110	0	7,748	5,281	294	1,085	893	200	583	11.0%
5-Jan-20	7,748	-110	0	7,748	5,528	243	1,085	893	200	285	5.2%
12-Jan-20	7,748	-110	0	7,748	5,304	337	1,085	893	200	603	11.4%
19-Jan-20	7,748	-110	0	7,748	5,351	303	1,085	893	200	522	9.9%
26-Jan-20	7,748	-110	0	7,748	5,467	297	1,096	893	200	389	7.1%
2-Feb-20	7,748	-110	0	7,748	5,348	313	1,084	893	200	536	10.0%
9-Feb-20	7,748	-110	0	7,748	5,248	353	1,100	893	200	660	12.6%
16-Feb-20	7,748	-110	0	7,748	5,051	316	988	893	200	932	18.5%
23-Feb-20	7,748	-110	0	7,748	4,941	285	952	893	200	1,047	21.2%
1-Mar-20	7,748	-110	0	7,748	4,826	317	953	893	200	1,193	24.7%
8-Mar-20	7,748	-110	0	7,748	4,782	348	970	893	200	1,251	26.2%
15-Mar-20	7,748	-110	0	7,748	4,723	364	970	893	200	1,326	28.1%
22-Mar-20	7,748	-110	0	7,748	4,485	298	1,123	893	200	1,345	30.0%
29-Mar-20	7,748	-110	0	7,748	4,143	253	1,415	893	200	1,350	32.6%

Key

Highlighted week beginning 19-Jan-20 denotes the NPCC forecasted coincident peak demand.
 Highlighted week beginning 29-Mar-20 denotes week with the largest forecasted NPCC "Revised Net Margin".
 Highlighted number denotes forecasted Summer 2019 Peak Load for Maritimes. Months of May and September are excluded.

Notes

- (1) Known Maint./Derate include wind. The Maritimes installed wind capacity has been derated by 72 percent.
- (2) Week beginning 05-Jan-20 denotes the forecasted Maritimes Winter 2019-20 Peak Week.

Table AP-3 – New England

Area: ISO-NE
 Revision Date: October 4, 2019

Control Area Load and Capacity

Week Beginning Sundays	Installed Capacity MW ¹	Net Interchange MW ²	Dispatchable DSM MW	Total Capacity MW	Normal Forecast MW ³	Interruptible Load MW ⁴	Known Maint./Derat. MW ⁵	Req. Operating Reserve MW ⁶	Unplanned Outages MW ⁷	Net Margin MW	Net Margin %
1/Dec/19	33,530	917	328	34,775	19,232	0	1,819	2,305	5,801	5,618	29.2%
8/Dec/19	33,530	917	328	34,775	19,532	0	1,935	2,305	6,310	4,693	24.0%
15/Dec/19	33,530	917	328	34,775	19,543	0	973	2,305	6,848	5,106	26.1%
22/Dec/19	33,530	917	328	34,775	19,608	0	330	2,305	7,201	5,331	27.2%
29/Dec/19	33,530	917	328	34,775	19,993	0	330	2,305	7,584	4,563	22.8%
5/Jan/20	33,530	917	328	34,775	20,476	0	621	2,305	7,015	4,358	21.3%
12/Jan/20	33,530	917	328	34,775	20,476	0	492	2,305	7,448	4,054	19.8%
19/Jan/20	33,530	917	328	34,775	20,476	0	492	2,305	7,236	4,266	20.8%
26/Jan/20	33,530	917	328	34,775	20,245	0	492	2,305	6,930	4,803	23.7%
2/Feb/20	33,530	917	328	34,775	19,967	0	561	2,305	7,230	4,712	23.6%
9/Feb/20	33,530	917	328	34,775	19,937	0	561	2,305	6,771	5,201	26.1%
16/Feb/20	33,530	917	328	34,775	19,664	0	513	2,305	6,465	5,828	29.6%
23/Feb/20	33,530	917	328	34,775	18,636	0	409	2,305	5,853	7,572	40.6%
1/Mar/20	33,530	917	328	34,775	18,273	0	1,602	2,305	4,194	8,401	46.0%
8/Mar/20	33,530	917	328	34,775	18,069	0	1,622	2,305	4,042	8,737	48.4%
15/Mar/20	33,530	917	328	34,775	17,690	0	2,022	2,305	3,031	9,727	55.0%
22/Mar/20	33,530	917	328	34,775	17,102	0	2,650	2,305	2,572	10,146	59.3%
29/Mar/20	33,530	917	441	34,888	16,344	0	4,301	2,305	2,700	9,238	56.5%

Key

Highlighted week beginning jj-Jan-aa denotes the NPCC forecasted coincident peak demand.
 Highlighted week beginning jj-Mar-aa denotes week with the largest forecasted NPCC "Revised Net Margin".
 Highlighted numbers denote forecasted Summer 2019 Peak Load for ISO-NE.

Notes

- (1) Installed Capacity values based on Seasonal Claimed Capabilities (SCC) and ISO-NE Forward Capacity Market (FCM) resource obligations expected for the 2019-2020 capacity commitment period.
- (2) Net Interchange includes peak purchases / sales from Maritimes, Quebec, and New York.
- (3) Preliminary load forecast assumes net Peak Load Exposure (PLE) of 20,476 MW and does include 2,668 MW credit for Energy Efficiency (EE) and 0 MW of behind-the-meter PV (BTM PV).
- (4) On peak, 497 MW of Active Demand Capacity Resource (ADCR) is considered available for economic dispatch, which has been taken into account in Dispatchable DSM MW
- (5) Includes known resource outages (scheduled and forced) as of the Revision Date listed above.
- (6) 2,305 MW operating reserve assumes 120% of the largest contingency of 1,400 MW and 50% of the second largest contingency of 1,250 MW.
- (7) Assumed unplanned outages is based on historical observation of forced outages and any additional reductions for generation at risk due to natural gas supply.

Table AP-4 – New York

Area NYISO
 Revision Date October 7, 2019

Week Beginning Sundays	Installed Capacity MW	Net Interchange MW ¹	Dispatchable DSM MW	Total Capacity MW	Load Forecast MW	Interruptible Load MW	Known Maint./Derat. MW	Req. Operating Reserve MW	Unplanned Outages MW	Net Margin MW	Net Margin %
1-Dec-19	41,815	678	853	43,346	23,678	40	3,355	2,620	2,529	11,204	47.3%
8-Dec-19	41,815	678	853	43,346	24,123	40	2,462	2,620	2,588	11,593	48.1%
15-Dec-19	41,815	678	853	43,346	24,123	40	2,651	2,620	2,576	11,416	47.3%
22-Dec-19	41,815	678	853	43,346	24,123	40	2,634	2,620	2,577	11,432	47.4%
29-Dec-19	41,815	678	853	43,346	24,123	40	2,634	2,620	2,577	11,432	47.4%
5-Jan-20	41,815	678	853	43,346	24,123	40	2,634	2,620	2,577	11,432	47.4%
12-Jan-20	41,815	678	853	43,346	24,123	40	2,634	2,620	2,577	11,432	47.4%
19-Jan-20	41,815	678	853	43,346	24,123	40	2,634	2,620	2,577	11,432	47.4%
26-Jan-20	41,815	678	853	43,346	24,123	40	2,634	2,620	2,577	11,432	47.4%
2-Feb-20	41,815	678	853	43,346	24,123	40	3,033	2,620	2,550	11,060	45.8%
9-Feb-20	41,815	678	853	43,346	24,123	40	3,385	2,620	2,527	10,731	44.5%
16-Feb-20	41,815	678	853	43,346	24,123	40	3,430	2,620	2,524	10,689	44.3%
23-Feb-20	41,815	678	853	43,346	24,123	40	3,430	2,620	2,524	10,689	44.3%
1-Mar-20	42,947	678	853	44,478	24,099	40	3,773	2,620	2,576	11,450	47.5%
8-Mar-20	42,947	678	853	44,478	23,763	40	5,608	2,620	2,456	10,071	42.4%
15-Mar-20	42,947	678	853	44,478	23,215	40	5,895	2,620	2,437	10,351	44.6%
22-Mar-20	42,947	678	853	44,478	22,754	40	6,892	2,620	2,371	9,881	43.4%
29-Mar-20	41,918	678	853	43,449	22,351	40	5,115	2,620	2,420	10,983	49.1%

Key

Highlighted week beginning 19-Jan-20 denotes the NPCC forecasted coincident peak demand.
 Highlighted week beginning 29-Mar-20 denotes week with the largest forecasted NPCC "Revised Net Margin".
 Highlighted number denotes forecasted Summer 2019 Peak Load for NYISO.

Notes

(1) Figures include the election of Unforced Capacity Deliverability Rights (UDRs), External CRIS Rights, Existing Transmission Capacity for Native Load (ETCNL) elections, First Come First Serve Rights (FCFSR) as currently known, and grandfathered exports. For more information on the use of UDRs, please see section 4.14
 (2) Week beginning 19-Jan-20 denotes the New York Peak Week

Table AP-5 – Ontario

Area: Ontario
 Revision Date: September 26, 2019

Control Area Load and Capacity

Week Beginning Sundays	Installed Capacity MW ¹	Net Interchange MW	Dispatchable DSM MW	Total Capacity MW	Load Forecast MW ²	Interruptible Load MW	Known Maint./Derat./Bottled Cap. MW ³	Req. Operating Reserve MW	Unplanned Outages MW ⁴	Net Margin MW	Net Margin %
1/Dec/19	37,609	-500	924	38,033	19,924	0	12,988	1,567	1,489	2,065	10.4%
8/Dec/19	37,609	-500	924	38,033	20,307	0	12,082	1,567	1,624	2,453	12.1%
15/Dec/19	37,609	-500	924	38,033	20,086	0	11,923	1,567	1,296	3,161	15.7%
22/Dec/19	37,609	-500	924	38,033	18,512	0	11,773	1,567	1,462	4,719	25.5%
29/Dec/19	37,609	-500	924	38,033	19,859	0	12,186	1,567	1,488	2,933	14.8%
5/Jan/20	37,609	-500	924	38,033	21,115	0	12,311	1,567	1,481	1,559	7.4%
12/Jan/20	37,609	-500	924	38,033	20,694	0	12,085	1,567	1,417	2,270	11.0%
19/Jan/20	37,609	-500	924	38,033	20,548	0	12,678	1,567	1,338	1,902	9.3%
26/Jan/20	37,609	-500	924	38,033	20,573	0	12,279	1,401	1,668	2,112	10.3%
2/Feb/20	37,909	-500	924	38,333	19,853	0	12,906	1,401	1,569	2,604	13.1%
9/Feb/20	37,909	-500	924	38,333	19,490	0	13,352	1,401	1,515	2,575	13.2%
16/Feb/20	37,909	-500	924	38,333	19,245	0	13,449	1,401	1,435	2,803	14.6%
23/Feb/20	37,909	-500	924	38,333	19,764	0	13,656	1,401	1,133	2,379	12.0%
1/Mar/20	37,909	-500	924	38,333	19,318	0	14,391	1,401	1,219	2,004	10.4%
8/Mar/20	38,069	-500	924	38,493	18,214	0	14,544	1,401	1,261	3,073	16.9%
15/Mar/20	38,069	-500	924	38,493	17,543	0	14,009	1,401	1,228	4,312	24.6%
22/Mar/20	38,069	-500	924	38,493	17,526	0	13,986	1,401	1,226	4,354	24.8%
29/Mar/20	39,054	-500	924	39,478	17,257	0	15,059	1,667	938	4,557	26.4%

Key

Highlighted week beginning j1-Jan-aa denotes the NPCC forecasted coincident peak demand.
 Highlighted week beginning j1-Mar-aa denotes week with the largest forecasted NPCC "Revised Net Margin".
 Highlighted number denotes forecasted Summer 2019 Peak Load for Ontario.

Notes

- (1) "Installed Capacity" includes all generation registered in the IESO-administered market.
- (2) "Load Forecast" represents the normal weather case, weekly 60-minute peaks.
- (3) "Known Maint./Derat./Bottled Cap." includes planned outages, deratings, historic hydroelectric reductions and variable generation reductions.
- (4) "Unplanned Outages" is based on the average amount of generation in forced outage for the assessment period.
- (5) Week beginning j1-Jan-aa denotes the Ontario Peak Week

Table AP-6 – Québec

Area Québec
Revision Date October 30, 2019

Control Area Load and Capacity

Week Beginning Sundays	Installed Capacity MW ¹	Net Interchange MW ²	Dispatchable DSM MW	Total Capacity MW	Load Forecast MW	Interruptible Load MW	Known Maint./Derat. MW ³	Req. Operating Reserve MW	Unplanned Outages MW	Net Margin MW	Net Margin %
1/Dec/19	46,689	-116	250	46,823	29,909	2,034	7,377	1,500	1,500	8,571	28.7%
8/Dec/19	46,689	184	250	47,123	32,583	2,034	5,495	1,500	1,500	8,079	24.8%
15/Dec/19	46,689	184	250	47,123	34,173	2,034	4,759	1,500	1,500	7,225	21.1%
22/Dec/19	46,689	184	250	47,123	34,993	2,034	4,375	1,500	1,500	6,789	19.4%
5/Jan/20	46,689	184	250	47,123	33,849	2,034	4,047	1,500	1,500	8,261	24.4%
12/Jan/20	46,689	184	250	47,123	36,095	2,034	4,355	1,500	1,500	5,707	15.8%
19/Jan/20	46,689	184	250	47,123	38,107	2,034	4,636	1,500	1,500	3,414	9.0%
26/Jan/20	46,689	184	250	47,123	38,665	2,034	4,772	1,500	1,500	2,720	7.0%
2/Feb/20	46,689	184	250	47,123	38,540	2,034	4,840	1,500	1,500	2,777	7.2%
9/Feb/20	46,689	184	250	47,123	36,215	2,034	4,941	1,500	1,500	5,001	13.8%
16/Feb/20	46,689	184	250	47,123	35,514	2,034	5,258	1,500	1,500	5,385	15.2%
23/Feb/20	46,689	184	250	47,123	34,780	2,034	5,385	1,500	1,500	5,992	17.2%
1/Mar/20	46,689	184	250	47,123	33,865	2,034	5,471	1,500	1,500	6,821	20.1%
8/Mar/20	46,689	184	250	47,123	33,143	2,034	5,634	1,500	1,500	7,380	22.3%
15/Mar/20	46,689	184	250	47,123	33,360	2,034	5,800	1,500	1,500	6,997	21.0%
22/Mar/20	46,689	184	250	47,123	32,411	2,034	6,037	1,500	1,500	7,709	23.8%
29/Mar/20	46,689	184	250	47,123	31,022	2,034	6,039	1,500	1,500	9,096	29.3%
	46,689	184	250	47,123	29,160	2,034	5,633	1,500	1,500	11,364	39.0%

Key

Highlighted week beginning jj-Jan-aa denotes the NPCC forecasted coincident peak demand.

Highlighted week beginning jj-Mar-aa denotes week with the largest forecasted NPCC "Revised Net Margin".

Highlighted number denotes forecasted Winter 2019-20 Peak Load for Québec area.

Notes

- (1) Includes Independent Power Producers (IPPs) and available capacity of Churchill Falls at the Newfoundland - Québec border.
- (2) Includes firm sale of 145 MW to Cornwall and transmission losses due to firm sales.
- (3) Includes 65% of Wind capacity derating.
- (4) Numbers published in this report may not exactly correspond to the values available on other Hydro-Québec public information sources because assumptions specific to the current report are applied.

Appendix II – Load and Capacity Tables definitions

This appendix defines the terms used in the Load and Capacity tables of Appendix I. Individual Balancing Authority Area particularities are presented when necessary.

Installed Capacity

This is the generation capacity installed within a Reliability Coordinator area. This should correspond to nameplate and/or test data and may include temperature derating according to the Operating Period. It may also include wind and solar generation derating.

Individual Reliability Coordinator Area particularities

Maritimes

This number is the maximum net rating for each generation facility (net of unit station service) and does not account for reductions associated with ambient temperature derating and intermittent output (e.g. hydro and/or wind).

New England

Installed capacity is based on generator seasonal claimed capabilities (SCC) and generation anticipated to be commercial for the identified capacity period. Totals account for the capacity values for derated renewable resources.

New York

This number includes all generation resources that participate in the NYISO Installed Capacity (ICAP) market.

Ontario

This number includes all generation registered with the IESO.

Québec

Most of the Installed Capacity in the Québec Area is owned and operated by Hydro-Québec Production. The remaining capacity is provided by Churchill Falls and by private producers (hydro, wind, biomass and natural gas cogeneration).

Net Interchange

Net Interchange is the total of Net Imports – Net Exports for NPCC and each Balancing Authority area.

Dispatchable Demand-Side Management

Dispatchable Demand-Side Management (DDSM) are demand resources assets that help meet an Area's electricity needs by reducing consumption. This is the portion of the Demand Response Programs that is accounted as capacity instead of load modifier.

Total Capacity

Total Capacity = Installed Capacity +/- Net Interchange + Dispatchable Demand-Side Management.

Demand Forecast

This is the total internal demand forecast for each Reliability Coordinator Area as per its normal Demand Forecast Methodology (Appendix IV).

Interruptible Loads

Loads that are interruptible under the terms specified in a contract and are not dispatchable.

Known Maintenance/Derates

This is the reduction in Capacity caused by forecasted generator outages or derates and by any additional forecasted transmission outages or constraints causing internal bottling within the Reliability Coordinator area. Some Reliability Coordinator areas may include wind and solar generation derating.

Individual Reliability Coordinator area particularities

Maritimes

This includes scheduled generator maintenance and ambient temperature derates. It also includes wind and hydro generation derating.

New England

Known maintenance includes all known planned outages as publically reported in the ISO-NE Annual Maintenance Schedule.

New York

This includes scheduled generator maintenance and includes all wind and other renewable generation derating.

Ontario

This includes planned generator outages, deratings, bottling, historic hydroelectric reductions and variable generation reductions.

Québec

This includes scheduled generator maintenance and hydraulic as well as mechanical restrictions. It also includes wind generation derating. It may include transmission constraints on the TransÉnergie system.

Required Operating Reserve

This is the minimum operating reserve on the system for each Reliability Coordinator area.

NPCC Glossary of Terms

Operating Reserve: *This is the sum of ten-minute and thirty-minute reserve (fully available in 10 minutes and in 30 minutes).*

Individual Reliability Coordinator Area particularities

Maritimes

The required operating reserve consists of 100% of the first-largest contingency and 50% of the second-largest contingency.

New England

The required operating reserve consists of 120% of the first largest contingency and 50% of the second largest contingency.

New York

The operating reserve consists of 200% of the largest single generator contingency.

Ontario

The required operating reserve consists of 100% of the first largest contingency and 50% of the second largest contingency.

Québec

The required operating reserve consists of 100% of the largest first contingency and 50% of the largest second contingency, including 1,000 MW of hydro synchronous reserve distributed all over the system to be used as stability and frequency support reserve.

Unplanned Outages

This is the forecasted reduction in Installed Capacity by each Reliability Coordinator area based on historical conditions used to take into account a certain probability that some capacity may be on forced outage.

Individual Reliability Coordinator Area particularities

Maritimes

Monthly unplanned outage values have been calculated based on historical unplanned outage data.

New England

Monthly unplanned outage values have been calculated on the basis of historical unplanned outage data and will also include values for natural gas-at-risk capacity.

New York

Seasonal generator unplanned outage values are calculated based on historical generator availability data and include the loss of largest generator source contingency value.

Ontario

This value is a historical observation of the capacity that is on forced outage at any given time.

Québec

This value includes a provision for frequency regulation in the Québec Balancing Authority area, for unplanned outages and for heavy loads as determined by the system controller.

Net Margin

Net margin = Total capacity – Load forecast + Interruptible load – Known maintenance/derates – Required operating reserve – Unplanned outages

Individual Reliability Coordinator Area particularities

New York

New York requires load serving entities to procure capacity for their loads equal to their peak demand plus an Installed Reserve Margin. The Installed Reserve Margin requirement represents a percentage of capacity above peak load forecast and is approved annually by the New York State Reliability Council (NYSRC). New York also maintains locational reserve requirements for certain regions, including New York City (Load Zone J), Long Island (Load Zone K) and the G-J Locality (Load Zones G, H, I and J are located in Southeast New York). Load serving entities in those regions must procure a certain amount of their capacity from generators within those regions.

New England

Net margin is the operable capacity margin for ISO-NE. The operable capacity margin is calculated in the monthly Current Year and First Future Year Annual Maintenance Schedule (AMS) report.

Bottled Resources

Bottled resources = Québec Net margin + Maritimes Net margin – available transfer capacity between Québec/Maritimes and the rest of NPCC.

This is used primarily in the summer capacity period. It takes into account the fact that the margin available in Maritimes and Québec exceeds the transfer capability to the rest of NPCC since Québec and Maritimes are winter peaking.

Revised net margin (Table AP-1, NPCC Summary only)

Revised net margin = Net margin – Bottled resources

This is used in the NPCC assessment and follows from the Bottled Resources calculation.

Appendix III – Summary of Forecasted Winter Transfer Capabilities

The following table represents the forecasted transfer capabilities between Reliability Coordinator Areas represented as Total Transfer Capability (TTC). It is recognized that the forecasted and actual transfer capability may differ depending on system conditions and configurations such as real-time voltage profiles, generation dispatch or operating conditions. This may also account for Transmission Reliability Margin (TRM). Readers are encouraged to review information on the Available Transfer Capability (ATC) and Total Transfer Capability (TTC) between Reliability Coordinator Areas. These capabilities may not correspond to exact ATC values posted on the Open Access Same-Time Information Transmission System (OASIS) or the Reliability Coordinator's website since the existing transmission services commitments are not considered. Area specific websites are listed below.

- **Maritimes**
<https://tso.nbpower.com/public/en/access.aspx>
<http://oasis.nspower.ca/en/home/oasis/default.aspx>
- **New England**
<https://www.iso-ne.com/isoexpress/web/reports/operations/-/tree/ttc-tables>
- **New York**
<http://mis.nyiso.com/public/>
- **Ontario**
<http://reports.ieso.ca/public/TxLimitsAllInService0to34Days/>
<http://reports.ieso.ca/public/TxLimitsOutage0to2Days/>
<http://reports.ieso.ca/public/TxLimitsOutage3to34Days/>
- **Québec**
<http://www.hydroquebec.com/transenergie/en/oasis.html>

Transfers from Maritimes to

Interconnection Point	TTC (MW)	ATC (MW)	Comments
Québec			
Eel River (NB)/Matapédia (QC)	335	335	Eel River winter rating is 350 MW. When Eel River converter losses and line losses to the Québec border are taken into account, Eel River to Matapédia transfer is 335 MW.
Edmundston (NB)/Madawaska (QC)	435	435	Madawaska HVDC winter rating is 435 MW.
Total	770	770	The NB to HQ-HVDC transfer capability is limited to 650 MW due to Load loss limitations in the Maritimes.
New England			
Orrington, Keene Road	1,000	1,000	For resource adequacy studies, NE assumes that it can import 1,000 MW of capacity to meet New England loads with 50 MW of margin for real-time balancing control.
Total	1,000	1,000	

Transfers from New England to

Interconnection Point	TTC (MW)	ATC (MW)	Comments
Maritimes			
Keswick (3001 line), Point Lepreau (390/3016 line)	550	550	Transfer capability depends on operating conditions in northern Maine and the Maritimes area. If key generation or capacitor banks are not operational, the transfer limits from New England to New Brunswick will decrease. At present, the NBP-SO has limited the transfer to 200 MW but will increase it to 550 MW on request from the NBP-SO under emergency operating conditions for up to 30 minutes. This limitation is due to system security/stability within New Brunswick.
Total	550	550	
New York			
Northern AC Ties (393, 398, E205W, PV20, K7, K6 and 690 lines)	1,310	1,310	The transfer capability is dependent upon New England system load levels and generation dispatch. If key generators are online and New England system load levels are acceptable, the transfers to New York could exceed 1,310 MW. ISO-NE planning assumptions are based on an interface limit of 1,310 MW.
NNC Cable (Northport-Norwalk Harbor Cable)	200	200	The NNC is an interconnection between Norwalk Harbor, Connecticut and Northport, New York. The flow on the NNC interface is controlled by the Phase Angle Regulating transformer at Northport, adjusting the flows across the cables listed. ISO New England and New York ISO Operations staff evaluates the seasonal TTC across the NNC interface on a periodic basis or when there are significant changes to the transmission system that warrant an evaluation. A key objective while determining the TTC is to not have a negative impact on the prevalent TTC across the Northern NE-NY AC Ties interface.
LI / Connecticut (CSC)	330	330	The transfer capability of the Cross Sound Cable (CSC) is 346 MW. However, losses reduce the amount of MWs that can actually be delivered across the cable. When 346 MW is injected into the cable, 330 MW is received at the point of withdrawal. The Cross Sound Cable is a DC tie and is not included in the Feasible simultaneous transfer capability with NY.
Total	1,840	1,840	

Interconnection Point	TTC (MW)	ATC (MW)	Comments
Québec			
Phase II HVDC link (451 and 452 lines)	1,200	1,200	Export capability of the facility is 1,200 MW.
Highgate (VT) – Bedford (BDF) Line 1429	170	100	Capability of the tie is 225 MW but at times, conditions in Vermont limit the capability to 100 MW or less. The DOE permit is 170 MW.
Derby (VT) – Stanstead (STS) Line 1400	0	0	Though there is no capability scheduled to export to Québec through this interconnection path, exports may be able to be provided, dependent upon New England system load levels and generation dispatch. ISO-NE planning assumptions are based on a path limit of 0 MW.
Total	1,370	1,300	The New England to Québec transfer limit at peak load is assumed to be 0 MW. It should be noted that this limit is dependent on New England generation and could be increased up to approximately 350 MW depending on New England dispatch. If energy was needed in Québec and the generation could be secured in the Real-Time market, this action could be taken to increase the transfer limit.

Transfers from New York to

Interconnection Point	TTC (MW)	ATC (MW)	Comments
New England			
Northern AC Ties (393, 398, E205W, PV20, K7, K6 and 690 lines)	1,700	1,500	New York applies a 200 MW Transmission Reliability Margin (TRM).
LI / Connecticut Northport-Norwalk Harbor Cable	200	200	
LI / Connecticut Cross-Sound Cable	330	330	Cross Sound Cable power injection is up to 346 MW; losses reduce power at the point of withdrawal to 330 MW. The Cross Sound Cable is a DC tie and is not included in the Feasible Simultaneous Transfer capability with NY.
Total	2,230	2,030	
Ontario			
Lines PA301, PA302, BP76, PA27, L33P, L34P	2,000	1,700	New York applies a 300 MW Transmission Reliability Margin (TRM). Thermal limits on the QFW interface may restrict exports to lesser values when the generation in the Niagara area is taken into account.
Total	2,000	1,700	
PJM			
PJM AC Ties	1,850	1,550	New York applies a 300 MW Transmission Reliability Margin (TRM).
NYC/PJM Linden VFT	300	300	
Total	2,150	1,850	
Québec			
Chateauguay (QC)/Massena (NY)	1,000	1,000	
Cedars / Québec	100	100	
Total	1,100	1,100	

Transfers from Ontario to				
Interconnection Point	TTC (MW)	ATC (MW)	Comments	
New York				
Lines PA301, PA302, BP76, PA27, L33P, L34P	2,100	1,900	The TRM is 200 MW.	
Total	2,100	1,900		
MISO				
Michigan				
Lines L4D, L51D, J5D, B3N	1,750	1,550	The TRM is 200 MW.	
Total	1,750	1,550		
Québec				
NE / RPD – KPW Lines D4Z, H4Z	110	100	The 110 MW reflects an agreement through the TE-IESO Interconnection Committee. The TRM is 10 MW.	
Ottawa / BRY – PGN Lines X2Y, Q4C	140	140	There is no capacity to export to Québec through Lines P33C and X2Y.	
Ottawa / Brookfield Lines D5A, H9A	200	190	Only one of H9A or D5A can be in service at any time. The TRM is 10 MW.	
East / Beau Lines B5D, B31L	470	470	Capacity from Saunders that can be synchronized to the Hydro-Québec system.	
HAW / OUTA Lines A41T, A42T	1,250	1,230	The TRM is 20 MW.	
Total	2,170	2,130		

Interconnection Point	TTC (MW)	ATC (MW)	Comments
MISO			
Manitoba, Minnesota			
NW / MAN Lines K21W, K22W	300	275	The TRM is 25 MW.
NW / MIN Line F3M	150	130	The TRM is 20 MW
Total	450	405	

Transfers from Québec to

Interconnection Point	TTC (MW)	ATC (MW)	Comments
Matapédia (QC)/Eel River (NB)	350 + radial loads	350 + radial loads	Eel River HVDC winter rating is 350 MW. Radial load transfer amount is dependent on local loading and is reviewed annually
Madawaska (QC)/Edmundston (NB)	423 + radial loads	423 + radial loads	Madawaska winter rating is 435 MW. When Madawaska converter losses and line losses to the New Brunswick border are taken into account, Madawaska to St-André transfer is 423 MW. Radial load transfer amount is dependent on local loading and is reviewed annually.
Total	773 + radial loads	773 + radial loads	Radial load transfer amount is dependent on local loading and is updated monthly and reviewed annually.
New England			
NIC / CMA HVDC link	2,000	2,000	Capability of the facility is 2,000 MW The value estimated at peak load is 1,400 MW.
Bedford (BDF) – Highgate (VT) Line 1429	225	225	Capacity of the Highgate HVDC facility is 225 MW
Stanstead (STS) – Derby (VT) Line 1400	50	50	Normally only 35 MW of load in New England is connected.
Total	2,275	2,275	
New York			
Chateaugay (QC)/Massena (NY)	1,800	1,800	Beauharnois G.S. is used for Québec needs under peak load conditions, in which case transfer is limited to Châteauguay capacity (1000 MW).
Les Cèdres (QC)/Dennison (NY)	199	199	Points of delivery Dennison (NY) and Cornwall (Ont.) have a maximum capacity of 199 MW and 160 MW respectively. However, the TTC of both points of delivery combined is 325 MW, the maximum capacity of Les Cèdres substation.
Total	1,999	1,999	

Interconnection Point	TTC (MW)	ATC (MW)	Comments
Ontario			
Les Cèdres (Qc)/Cornwall (Ont.)	160	160	Points of delivery Dennison (NV) and Cornwall (Ont.) have a maximum capacity of 199 MW and 160 MW respectively. However, the TTC of both points of delivery combined is 325 MW, the maximum capacity of Les Cèdres substation.
Beauharnois(Qc)/St-Lawrence (Ont.)	800	800	Beauharnois Generating Station is used for Québec needs under peak load conditions in which case no export is expected on this path at peak time.
Brookfield/Ottawa (Ont.)	250	250	Only one of H9A or D5A can be in services at any time. The transfer capability reflects usage of D5A.
Rapide-des-Iles (Qc)/Dymond (Ont.)	85	85	This represents Line D4Z capacity. There is no capacity to export to Ontario through Line H4Z.
Bryson-Paugan (Qc)/Ottawa (Ont.)	410	410	Limitations on the Québec system under peak load conditions restrict deliveries as follows P33C - 345 MW and X2Y – 65 MW. There is no capacity to export to Ontario through Line Q4C.
Outaouais (Qc)/Hawthorne (Ont.)	1,250	1,250	HVDC back-to-back facility at Outaouais.
Total	2,955	2,955	

Import Transfers from Regions External to NPCC

Interconnection Point	TTC (MW)	ATC (MW)	Rationale for Constraint
MISO (Michigan) / ONT			
Lines L4D, L51D, J5D, B3N	1,750	1,550	The TRM is 200 MW
Total	1,750	1,550	
MISO (Manitoba-Minnesota) / ONT			
NW / MAN Lines K21W, K22W	368	343	Flows into Ontario include flows on circuit SK1 of 68 MW. The TRM on the K21W, K22W interface is 25 MW.
NW / MIN Line F3M	100	80	The TRM is 20 MW.
Total	468	423	
PJM / New York			
PJM AC Ties	2,750	2,450	The TRM is 300 MW
PJM/NYC Linden VFT	315	315	
PJM/Long Island Neptune Cable	660	660	
PJM/NYC HTP DC/DC Tie	660	660	
Total	4,385	4,085	

Appendix IV – Demand Forecast Methodology

Reliability Coordinator Area Methodologies

Maritimes

The Maritimes area demand is the mathematical sum of the forecasted weekly peak demands of the sub-areas (New Brunswick, Nova Scotia, Prince Edward Island, and the area served by the Northern Maine Independent System Operator). As such, it does not take the effect of load coincidence within the week into account. If the total Maritimes Area demand included a coincidence factor, the forecast demand would be approximately 1% to 3% lower.

For New Brunswick, the demand forecast is based on an End-use Model (sum of forecasted loads by use e.g. water heating, space heating, lighting etc.) for residential loads and an Econometric Model for general service and industrial loads, correlating forecasted economic growth and historical loads. Each of these models is weather adjusted using a 30-year historical average.

For Nova Scotia, the load forecast is based on a 10-year weather average measured at the major load center, along with analyses of sales history, economic indicators, customer surveys, technological and demographic changes in the market, and the price and availability of other energy sources.

For Prince Edward Island, the demand forecast uses average long-term weather for the peak period (typically December) and a time-based regression model to determine the forecasted annual peak. The remaining months are prorated on the previous year.

The Northern Maine Independent System Administrator performs a trend analysis on historic data in order to develop an estimate of future loads.

To determine load forecast uncertainty (LFU) an analysis of the historical load forecasts of the Maritimes area utilities has shown that the standard deviation of the load forecast errors is approximately 4.6% based upon the four year lead time required to add new resources. To incorporate LFU, two additional load models were created from the base load forecast by increasing it by 5.0% and 9.0% (one or two standard deviations) respectively. The reliability analysis was repeated for these two load models. Nova Scotia uses 5% as the Extreme Load Forecast Margin while the rest of the Maritimes uses 9% after similar analysis on their part.

New England

ISO New England's energy model is an annual model of the total energy of the ISO-NE Area, using real income, the real price of electricity, economics, and weather variables as drivers. Income is a proxy for all economic activity.

The long-term forecast for electricity use is developed each year using state and regional economic forecasts, 25 years of weather history in New England, results of both the ISO-NE's energy-efficiency (EE) forecast and solar photovoltaic (PV) forecast, and other factors. ISO-NE calculates a gross forecast and then applies the EE and PV forecasts to develop reference and extreme demand forecasts.

The reference (normal) demand forecast¹¹, which has a 50% chance of being exceeded, is based on weekly weather distributions and the monthly model of typical daily peak. The weekly weather distributions are built using 40 years of temperature data at the time of daily electrical peaks (for non-holiday weekdays). A reasonable approximation for "normal weather" associated with the winter peak is 7.0°F and with the summer peak is 90.2°F. The extreme demand forecast, which has a 10% chance of being exceeded, is associated with a winter peak of 1.6°F and a summer peak of 94.2°F.¹²

From a short-term load forecast perspective, New England utilizes a Metrix Zonal load forecast, which produces a zonal load forecast for the eight regional load zones for up to six days in advance through the current operating day. This forecast enhances reliability on a zonal level by taking into account conflicting weather patterns, for example, when the Boston zone is forecasted to be five degrees while the Hartford area is forecast to be thirty degrees. This zonal forecast ensures an accurate reliability commitment on a regional level. The loads for the eight zones are then summed to estimate a total New England load, adding an additional New England load forecast to its Advanced Neural Network (ANN) models and Similar-Day (SimDay) analyses).

New York

The NYISO conducts load forecasting for the NYCA and for localities within the NYCA. The NYISO employs a two-stage process to develop load forecasts for each of the eleven zones within the NYCA. In the first stage, zonal load forecasts are based upon econometric projections. These forecasts assume a conventional portfolio of appliances and electrical technologies. The forecasts also assume that future improvements in energy efficiency

¹¹ Additional information describing ISO New England's load forecasting may be found at <https://www.iso-ne.com/system-planning/system-plans-studies/celt>

¹² Further information describing ISO New England's load forecasting methodologies is available at <http://www.iso-ne.com/system-planning/system-forecasting/load-forecast>.

measures will be similar to those of the recent past and that spending levels on energy efficiency programs will be similar to recent history. In the second stage the NYISO adjusts the econometric forecasts to explicitly reflect a projection of the energy savings resulting from statewide energy efficiency programs, impacts of new building codes and appliance efficiency standards and a projection of energy usage due to electric vehicles. The baseline forecasts include the load-reducing impacts of energy efficiency programs, building codes, and appliance efficiency standards solar PV and distributed energy generation. The actual impact of solar PV varies considerably by hour of day. The hour of the NYCA peak varies yearly. The forecast of solar PV-related reductions in summer peak assumes that the NYCA peak occurs from 4 p.m. to 5 p.m. EDT in late July. The forecast of solar PV-related reductions in winter peak is zero because the sun sets before the assumed peak hour of 6 p.m. EST.

In addition to the baseline forecast, the NYISO also produces high and low forecasts for each zone that represent extreme weather conditions. The forecast is developed by the NYISO using a Temperature-Humidity Index (THI) which is representative of normal weather during peak demand conditions. The weather assumptions for most regions of the state are set at the 50th percentile of the historic series of prevailing weather conditions at the time of the system coincident peak. For Orange & Rockland and for Consolidated Edison, the weather assumptions are set at the 67th percentile of the historic series of prevailing weather conditions at the time of the system coincident peak.

Individual utilities include the peak demand impact of demand side management programs in their forecasts. Each investor owned utility, the New York State Energy Research and Development Authority (NYSERDA), the New York Power Authority (NYPA), and the Long Island Power Authority (LIPA), maintain a database of installed measures from which estimates of impacts can be determined. The impact evaluation methodologies and measurement and verification standards are specified by the state's evaluation advisory committee known as "E²", in which the NYISO participates, and that provides input to the New York Department of Public Service staff reporting to the New York Public Service Commission.

There are two higher-than-expected scenarios forecast for the NYCA. One is a forecast without the impacts of energy efficiency programs or behind-the-meter solar photovoltaic generation. The second is a forecast based on extreme weather conditions, set to the 90th percentile of typical peak-producing weather conditions.

Ontario

The Ontario Demand is the sum of coincident loads plus the losses on the IESO-controlled grid. Ontario Demand is calculated by taking the sum of injections by registered

generators, plus the imports into Ontario, minus the exports from Ontario. Ontario Demand does not include loads that are supplied by non-registered generation. The IESO forecasting system uses multivariate econometric equations to estimate the relationships between electricity demand and a number of drivers. These drivers include weather effects, economic data, conservation, embedded generation and calendar variables. Using regression techniques, the model estimates the relationship between these factors and energy and peak demand. Calibration routines within the system ensure the integrity of the forecast with respect to energy, minimum and peak demand, including zone and system wide projections. IESO produces a forecast of hourly demand by zone. From this forecast, the following information is available:

- hourly peak demand
- hourly minimum demand
- hourly coincident and non-coincident peak demand by zone
- energy demand by zone

These forecasts are generated based on a set of weather and economic assumptions. IESO uses a number of different weather scenarios to forecast demand. The appropriate weather scenarios are determined by the purpose and underlying assumptions of the analysis. The base case demand forecast uses a median economic forecast and monthly-normalized weather. Multiple economic scenarios are only used in longer-term assessments. A quantity of price-responsive demand is also forecast based on market participant information and actual market experience.

A consensus of four major, publicly available provincial forecasts is used to generate the economic drivers used in the model. In addition, forecast data from a service provider is purchased to enable further analysis and insight. Population projections, labor market drivers and industrial indicators are utilized to generate the forecast of demand. The impact of conservation measures are decremented from the demand forecast, which includes demand reductions due to energy efficiency, fuel switching and conservation behavior (including the impact smart meters).

In Ontario, demand management programs include Demand Response programs and the dispatchable loads program. Historical data is used to determine the quantity of reliably available capacity, which is treated as a resource to be dispatched. Embedded generation leads to a reduction in “on-grid” demand on the grid, which is decremented from the demand forecast.

Ontario uses 31 years of history to calculate a weather factor to represent the MW impact on demand if the weather conditions (temperature, wind speed, cloud cover and humidity) are observed in the forecast horizon. Weather is sorted on a monthly basis, and

for the extreme weather scenario, Ontario uses the maximum value from the sorted history.

The variable generation capacity in Table 4 is the total installed capacity expected during the operating period, with the variable generation resources expected in-service outlined in Table 3. For determining wind and solar derating factors, Ontario uses seasonal contribution factors based upon median historical hourly production values. The wind contribution factor is 37.8% for the winter and 12.2% for the summer. The solar contribution factor is 0% for the winter and 10.1% for the summer.

Québec

Hydro-Québec's demand and energy-sales forecasting is Hydro-Québec Distribution's responsibility. First, the energy-sales forecast is built upon the forecast from four different consumption sectors – domestic, commercial, small and medium-size industrial and large industrial. The model types used in the forecasting process are different for each sector and are based on end-use and/or econometric models. They consider weather variables, economic-driver forecasts, demographics, energy efficiency, and different information about large industrial customers. This forecast is normalized for weather conditions based on an historical trend weather analysis.

The requirements are obtained by adding transmission and distribution losses to the sales forecasts. The monthly peak demand is then calculated by applying load factors to each end-use and/or sector sale. The sum of these monthly end-use/sector peak demands is the total monthly peak demand.

Load Forecast Uncertainty (LFU) includes weather and load uncertainties. Weather uncertainty is due to variations in weather conditions. It is based on a 47-year temperature database (1971–2017), adjusted by 0.30°C (0.54°F) per decade starting in 1971 to account for climate change. Moreover, each year of historical climatic data is shifted up to ±3 days to gain information on conditions that occurred during either a weekend or a weekday. Such an exercise generates a set of 329 different demand scenarios. Weather uncertainty is calculated from these 329 demand scenarios (energy and peak). Load uncertainty is due to the uncertainty in economic and demographic variables affecting demand forecast and to residual errors from the models.

Overall uncertainty is defined as the independent combination of climatic uncertainty and load uncertainty. This Overall Uncertainty is lower during the summer than during the winter. For example, at the summer peak, weather conditions uncertainty is about 450 MW, equivalent to one standard deviation. During winter, this uncertainty is about 1,500 MW.

TransÉnergie – the Québec system operator – then determines the Québec Balancing Authority area forecasts using Hydro-Québec Distribution’s forecasts (HQ internal demand) and accounting for agreements with different private systems within the Balancing Authority area. The forecasts are updated on an hourly basis, within a 12-day horizon according to information on local weather, wind speed, cloud cover, sunlight incidence and type and intensity of precipitation over nine regions of the Québec Balancing Authority area. Forecasts on a minute basis are also produced within a two day horizon. TransÉnergie has a team of meteorologists who feed the demand forecasting model with accurate climatic observations and precise weather forecasts. Short-term changes in industrial loads and agreements with different private systems within the Balancing Authority Area are also taken into account on a short-term basis.

Appendix V - NPCC Operational Criteria and Procedures

NPCC Directories Pertinent to Operations

NPCC Regional Reliability Reference Directory #1 – Design and Operation of the Bulk Power System

Description: This directory provides a “design-based approach” to ensure the bulk power system is designed and operated to a level of reliability such that the loss of a major portion of the system, or unintentional separation of a major portion of the system, will not result from any design contingencies. Includes Appendices F and G “Procedure for Operational Planning Coordination” and “Procedure for Inter Reliability Coordinator area Voltage Control”, respectively.

NPCC Regional Reliability Reference Directory #2 - Emergency Operations

- Description: Objectives, principles and requirements are presented to assist the NPCC Reliability Coordinator areas in formulating plans and procedures to be followed in an emergency or during conditions which could lead to an emergency.

NPCC Regional Reliability Reference Directory #5 – Reserve

Description: This directory provides objectives, principles and requirements to enable each NPCC Reliability Coordinator Area to provide reserve and simultaneous activation of reserve.

NPCC Regional Reliability Reference Directory #6 – “Reserve Sharing Groups”

Description: This directory provides the framework for Regional Reserve Sharing Groups within NPCC. It establishes the requirements for any Reserve Sharing Groups involving NPCC Balancing Authorities.

NPCC Regional Reliability Reference Directory #8 - System Restoration

Description: This directory provides objectives, principles and requirements to enable each NPCC Reliability Coordinator Area to perform power system restoration following a major event or total blackout.

NPCC Regional Reliability Reference Directory # 12 - Underfrequency Load Shedding Requirements

Description: This document presents the basic criteria for the design and implementation of under frequency load shedding programs to ensure that

declining frequency is arrested and recovered in accordance with established NPCC performance requirements to prevent system collapse due to load-generation imbalance.

A-10 Classification of Bulk Power System Elements

Description: This *Classification of Bulk Power System Elements* (Document A-10) provides the methodology for the identification of those elements of the interconnected NPCC Region to which NPCC bulk power system criteria are applicable. Each Reliability Coordinator Area has an existing list of bulk power system elements. The methodology in this document is used to classify elements of the bulk power system and has been applied in classifying elements in each Reliability Coordinator Area as bulk power system or non-bulk power system.

- **Note:** *This document is currently under review.*

NPCC Procedures Pertinent to Operations

C-01 NPCC Emergency Preparedness Conference Call Procedures - NPCC Security Conference Call Procedures

Description: This document details the procedures for the NPCC Emergency Preparedness Conference Calls, which establish communications among the Operations Managers of the Reliability Coordinator (RC) Areas which discuss issues related to the adequacy and security of the interconnected bulk power supply system in NPCC.

C-15 Procedures for Solar Magnetic Disturbances on Electrical Power Systems

Description: This procedural document clarifies the reporting channels and information available to the operator during solar alerts and suggests measures that may be taken to mitigate the impact of a solar magnetic disturbance.

C-43 NPCC Operational Review for the Integration of New Facilities

Description: The document provides the procedure to be followed in conducting operations reviews of new facilities being added to the power system. This procedure is intended to apply to new facilities that, if removed from service, may have a significant, direct or indirect impact on another Reliability Coordinator area's inter-Area or intra-Area transfer capabilities. The cause of such impact might include stability, voltage, and/or thermal considerations.

Appendix VI - Web Sites

Independent Electricity System Operator

<http://www.ieso.ca/>

ISO-New England

<http://www.iso-ne.com>

Maritimes

Maritimes Electric Company Ltd.

<http://www.maritimeelectric.com>

New Brunswick Power Corporation

<http://www.nbpower.com>

New Brunswick Transmission and System Operator

<http://tso.nbpower.com/public>

Nova Scotia Power Inc.

<http://www.nspower.ca/>

Northern Maine Independent System Administrator

<http://www.nmisa.com>

Midwest Reliability Organization

<https://www.midwestreliability.org>

New York ISO

<http://www.nyiso.com/>

Northeast Power Coordinating Council, Inc.

<http://www.npcc.org/>

North American Electric Reliability Corporation

<http://www.nerc.com>

ReliabilityFirst Corporation

<http://www.rfirst.org>

Hydro-Québec TransÉnergie

<http://www.hydroquebec.com/transenergie/en/>

Appendix VII - References

CP-8 2019-20 Winter Multi-Area Probabilistic Reliability Assessment

NPCC Reliability Assessment for Winter 2018-19

**Appendix VIII – CP-8 2019-20 Winter Multi-Area Probabilistic Reliability
Assessment – Supporting Documentation**



Northeast Power Coordinating Council, Inc.
Multi-Area Probabilistic Reliability
Assessment
For
Winter 2019 - 2020

Approved by the RCC
December 3, 2019

Conducted by the
NPCC CP-8 Working Group

This page intentionally left blank.

CP-8 WORKING GROUP

Philip Fedora (Chair)	Northeast Power Coordinating Council, Inc.
Alan Adamson	New York State Reliability Council
Haretha Alao Sylvie Gicquel	Hydro-Québec Distribution
Frank Ciani	New York Independent System Operator
Scott Leuthauser	HQ Energy Services - U.S.
Philip Moy Khatune Zannat	PSEG Long Island
Kamala Rangaswamy	Nova Scotia Power Inc.
Rob Vance Prathamesh Kumthekar	Énergie NB Power
Vithy Vithyanathan	Independent Electricity System Operator
Fei Zeng Peter Wong	ISO New England Inc.

The CP-8 Working Group acknowledges the efforts of Messrs. Eduardo Ibanez and Mitch Bringolf, GE Energy Consulting, and Patricio Rocha-Garrido, the PJM Interconnection, and thanks them for their assistance in this analysis.

1. EXECUTIVE SUMMARY	6
2. INTRODUCTION	9
3. STUDY ASSUMPTIONS	10
3.1 Demand	10
3.1.1 Load Assumptions	10
3.1.2 Load Model in MARS	13
3.2 Resources	16
3.3 Transfer Limits	18
3.4 Operating Procedures to Mitigate Resource Shortages	21
3.5 Assistance Priority	22
3.6 Modeling of Neighboring Regions	22
PJM-RTO	24
3.7 Study Scenarios	24
4. STUDY RESULTS	27
4.1 Base Case Scenario	27
4.2 Severe Case Scenario	28
5. HISTORICAL REVIEW	29
5.1 Operational Review	29
6. CONCLUSIONS	31
APPENDIX A OBJECTIVE, SCOPE OF WORK AND SCHEDULE	32
A.1 Objective	32
A.2 Scope	32
A.3 Schedule	32
APPENDIX B DETAILED STUDY RESULTS	33
APPENDIX C MULTI-AREA RELIABILITY PROGRAM DESCRIPTION	35
C.1 Modeling Technique	35
C.2 Reliability Indices	35
C.3 Resource Allocation Among Areas	36
C.4 Generation	36

C.5	Transmission System	38
C.6	Contracts	39
APPENDIX D MODELING DETAILS		40
D.1	Resources	40
D.2	Resource Availability.....	41
D.3	Thermal	43
D.4	Hydro	44
D.5	Solar	44
D.6	Wind.....	45
D.7	Demand Response.....	46
APPENDIX E PREVIOUS WINTER REVIEW.....		48
E.1	Weather	48

1. EXECUTIVE SUMMARY

This report, which was prepared by the CP-8 Working Group, estimates the use of the available NPCC Area Operating Procedures to mitigate resource shortages from November 2019 through March 2020 period.

General Electric's (GE) Multi-Area Reliability Simulation (MARS) program was used for the analysis. GE Energy was retained by NPCC to conduct the simulations.

The assumptions used in this probabilistic study are consistent with the CO-12 Working Group's study, "*NPCC Reliability Assessment for Winter 2019-20*", December 2019 ¹, and summarized in Table 1.

Table 1: Assumed Load and Base Case Capacity for Winter 2019/20

Area	Expected Peak ² (MW)	Extreme Peak ³ (MW)	Available Capacity ⁴ (MW)	Peak Month
Québec (HQ)	38,783	42,041	44,295	January
Maritimes Area (MT)	5,466	5,969	7,669	January
New England (NE)	20,476 ⁵	21,355	30,299 ⁶	January
New York (NY)	24,123	24,871	42,348	January
Ontario (ON)	21,115	22,022	30,779	January

¹ See: <https://www.npcc.org/Library/Seasonal%20Assessment/Forms/Public%20List.aspx>

² The expected peak load forecast represents each Area's projection of mean demand over the study period based on historical data analysis.

³ The extreme peak load forecast is determined at two standard deviations higher than the mean, which has a 6.06 percent probability of occurrence.

⁴ Available Capacity represents Area's effective capacity at the time of the peak; it takes into account firm imports and exports, reductions due to deratings, Active Demand Response, and scheduled outages.

⁵ This is the net peak forecast reflecting the reduction from passive demand response resources and the peak reduction impacts from BTM PV. Gross peak = 23,144 MW; Passive DR = 2,668 MW; BTM PV reduction = 0; Net peak = 20,476 MW.

⁶ Total generation = 33,585 - Active DR (497 MW) + Net import (917 MW) - Gas at risk (4,700 MW) = 30,299 MW (Net).

The study was conducted for two load scenarios: expected load level scenario and extreme load level scenario. The expected load level was based on the probability-weighted average of seven load levels simulated, while the extreme load represents the second highest load level of the seven levels simulated (see section 3.1.2). The extreme load level has a six percent chance of occurring. While the extreme load as defined for this study may be different than the extreme load defined by the Areas in their own studies, the Working Group finds this load level appropriate for providing an assessment of the extreme condition in NPCC. Details of information provided by each Area for the forecasts are presented in Section 3.1 of this report.

For each of the two demand scenarios described above, two different system conditions were considered: Base Case assumptions and Severe Case assumptions. Details regarding the two sets of assumptions are described in Section 3.7 of this report.

Table 2 shows the estimated use of demand response programs and operating procedures under the Base Case assumptions for the expected load level and the extreme load level scenarios for the November 2019–March 2020 period. Occurrences greater than 0.5 days/period are **highlighted**.⁷

Table 2: Expected Use of the Operating Procedures under Base Case Assumptions (days/period)

	HQ	MT	NE	NY	ON	HQ	MT	NE	NY	ON
	Expected Load Level					Extreme Load Level				
Activation of DR/SCR	0.016	-	-	-	0.001	0.232	-	-	-	0.016
Reduce 30-min Reserve	-	1.836	-	-	-	0.006	11.308	-	-	0.001
Initiate Interruptible Loads/Voltage Reduction ⁸	-	1.005	-	-	-	-	7.174	-	-	-
Reduce 10-min Reserve ⁹	-	0.135	-	-	-	-	1.345	-	-	-
Appeals	-	0.018	-	-	-	-	0.216	-	-	-
Disconnect Load	-	0.018	-	-	-	-	0.216	-	-	-

⁷ Rounded to the nearest whole occurrence, likelihoods of less than 0.5 days/period are not considered significant.

⁸ Initiate Interruptible Loads for the Maritimes Area (implemented only for the Area), Voltage Reduction for all the other Areas.

⁹ New York initiates Appeals prior to reducing 10-min Reserve.

Under Base Case conditions, only the Maritimes Area estimates a likelihood of using their operating procedures designed to mitigate resource shortages (reducing 30-min reserve and initiating interruptible loads) during the 2019/20 winter period for the expected load forecast (representing the probability weighted average of all seven load levels). The results for the extreme load forecast (representing the second to highest load level, having approximately a 6% chance of occurring) also estimates a need for reducing 10-min reserve, as well. These results are primarily driven by Nova Scotia’s forecast load and corresponding reserve margin expectations.

Table 3 shows the estimated use of demand response programs and operating procedures under the Severe Case assumptions for the expected load level and the extreme load level scenarios for the November 2019 - March 2020 period. Occurrences greater than 0.5 days/period are **highlighted**.⁵

Table 3: Expected Use of the Operating Procedures under Severe Case Assumptions (days/period)

	HQ	MT	NE	NY	ON	HQ	MT	NE	NY	ON
	Expected Load Level					Extreme Load Level				
	Activation of DR/SCR	0.319	-	-	-	0.175	3.134	-	-	-
Reduce 30-min Reserve	0.061	11.852	0.006	-	0.061	0.798	49.593	0.067	-	0.759
Initiate Interruptible Loads/Voltage Reduction ¹⁰	0.026	8.525	-	-	0.013	0.381	41.361	0.013	-	0.193
Reduce 10-min Reserve ¹¹	0.009	2.918	-	-	0.001	0.129	19.853	0.008	-	0.021
Appeals	-	0.618	-	-	-	-	5.858	0.008	-	-
Disconnect Load	-	0.618	-	-	-	-	5.858	0.002	-	-

As shown in Table 3, the Maritimes Area estimated use of operating procedures increases assuming Severe Case conditions, especially for the extreme load forecast; again, these results are primarily driven by Nova Scotia’s forecast load and corresponding reserve margin expectations. The Hydro-Quebec and Ontario Areas show use of their operating procedures (activation of DR/SCR, reduction of 30-min reserve) for the Severe Case, extreme load forecast assumptions.

¹⁰ Initiate Interruptible Loads for the Maritimes Area (implemented only for the Area), Voltage Reduction for all the other Areas.

¹¹ New York initiates Appeals prior to reducing 10-min Reserve.

the Maritimes Area risk increases assuming Severe Case conditions, especially for the extreme load forecast; again, these results are primarily driven by Nova Scotia's forecast load and corresponding reserve margin expectations. The Hydro-Quebec and Ontario Areas show use of their operating procedures (activation of DR/SCR, reduction of 30-min reserve) for the Severe Case, extreme load level forecasts assumptions. The extreme load level represents the second to highest load level, having approximately a 6% chance of occurring.

2. INTRODUCTION

This report was prepared by the CP-8 Working Group and estimates the use of NPCC Area Operating Procedures designed to mitigate resource shortages from November 2019 through March 2020.

The CP-8 Working Group's efforts are consistent with the NPCC CO-12 Working Group's study, "*NPCC Reliability Assessment for Winter 2019-20*", December 2019. The CP-8 Working Group's Objective, Scope of Work, and Schedule is shown in Appendix A.

General Electric's (GE) Multi-Area Reliability Simulation (MARS) program was used for the analysis and GE Energy was retained by NPCC to conduct the simulations. APPENDIX C provides an overview of General Electric's Multi-Area Reliability Simulation (MARS) Program; version 3.25.945 was used for this assessment.

3. STUDY ASSUMPTIONS

The database developed by the CP-8 Working Group for the "*NPCC Reliability Assessment for Summer 2019*"¹² was used as the starting point for this analysis. Working Group members reviewed the existing data and made revisions to reflect the conditions expected for the winter 2019/20 assessment period.

3.1 Demand

3.1.1 Load Assumptions

Each area provided annual or monthly peak and energy forecasts for winter 2019/20. Table 4 summarizes each Area's winter expected peak load assumptions for the study period.

Table 4: Assumed NPCC Areas 2019/20 Winter Peak Demand

Area	Month	Peak Load (MW)
Québec	January	38,783
Maritimes Area	January	5,466
New England	January	20,476 ¹³
New York	January	24,123
Ontario	January	21,115

Specifics related to each Area's demand forecast used in this assessment are described below.

Maritimes

The Maritimes Area demand is the maximum of the hourly sums of the individual sub-area load forecasts. Except for the Northern Maine sub-area which uses a simple scaling factor, all other sub-areas use a combination of some or all of efficiency trend analysis, anticipated weather conditions, econometric modelling, and end use modeling to develop their load forecasts. Load forecast uncertainty is modeled in the Area's resource adequacy analysis. The load forecast uncertainty factors were developed by applying statistical methods to a comparison of historical forecast values of load to the actual loads experienced.

¹² See: <https://www.npcc.org/Library/Seasonal%20Assessment/Forms/Public%20List.aspx>.

¹³ This is the net peak forecast reflecting the reduction from passive demand response resources and the peak reduction impacts from BTM PV. Gross peak = 23,144 MW; Passive DR = 2,668 MW; BTM PV reduction = 0; Net peak = 20,476 MW.

New England

ISO-New England develops an independent demand forecast for its Balancing Authority (BA) area using historical hourly demand data from individual member utilities, which is based upon revenue quality metering. This data is then used to develop historical demand data on which the regional peak demand and energy forecasts are subsequently based. From this, ISO-New England develops a forecast of both state and system seasonal peak and energy demands. The peak demand forecast for the region and the states can be considered a coincident peak demand forecast. This demand forecast is referred to as the Gross Demand Forecast (Without Reductions) within the ISO-New England 2019 Load Forecast.¹⁴

The gross reference (50/50) winter peak forecast is 23,144 MW for the winter of 2019/20. It corresponds to a dry bulb temperature of 7.0°F, which is the 95th percentile of a weekly weather distribution and is consistent with the median of the dry-bulb value at the time of the winter peak over the last 25 years. The reference demand forecast is based on the reference economic forecast, which reflects the regional economic conditions that are expected that would most likely to occur.

In addition to the annual update to ISO-New England's forecast for both peak demand and energy, ISO-New England also forecasts the anticipated growth and impact of Behind-The-Meter Photovoltaic (BTM PV) resources within the BA area that do not participate in wholesale markets. ISO-New England's BTM PV forecast is developed annually with stakeholder input from the Distributed Generation Forecast Working Group. For the BTM PV forecast, the resources are considered to be those with typically 5 MW or less in nameplate capacity that are interconnected to the distribution system (typically 69 kilovolts or below) according to state-jurisdictional interconnection standards. The 2019 BTM PV forecast can be found using the following link: <https://www.iso-ne.com/static-assets/documents/2019/04/final-2019-pv-forecast.pdf>.

Around 3,347 MW of installed Photovoltaic (PV) resources are expected within New England by the end of 2019; the majority of them (~2,047 MW) are behind-the-meter PV resources. Their contribution to reducing system peaks, however, is diminished during the winter period, because New England's daily forecasted winter peak typically occurs during the evening hours, when the PV contribution is significantly reduced.

ISO-New England also develops a forecast of long-term savings in peak and energy use for the BA area and for each state stemming from state-sponsored Energy-Efficiency (EE) programs. Examples of EE measures include the use of more efficient lighting, motors, refrigeration, HVAC equipment, control systems, and industrial process equipment. ISO-New England's forecast of EE resources is developed with stakeholder input from the Energy-Efficiency Forecast Working Group. Data used to create the EE forecast originates from state-regulated utilities, energy-efficiency program administrators, and state regulatory agencies. The EE forecast is based on

¹⁴ See: https://www.iso-ne.com/static-assets/documents/2019/04/forecast_data_2019.xlsx.

averaged production costs, peak-to-energy ratios, and projected budgets of state-sponsored energy-efficiency programs.

The 2019 EE forecast can be found using the following link: https://www.iso-ne.com/static-assets/documents/2019/04/eef2019_final_fcst.pdf. The amount of EE resources is expected to be around 2,668 MW for the 2019/20 winter.

New York

The New York Independent System Operator (New York ISO) employs a multi-stage process in developing load forecasts for each of the eleven zones within the New York Control Area (NYCA). In the first stage, baseline energy and peak models are built based on projections of end-use intensities and economic variables. End-use intensities modeled include those for lighting, refrigeration, cooking, heating, cooling, and other plug loads. Appliance end-use intensities are generally defined as the product of saturation levels (average number of units per household or commercial square foot) and efficiency levels (energy usage per unit or a similar measure). End-use intensities specific to New York are estimated from appliance saturation and efficiency levels in both the residential and commercial sectors. These intensities include the projected impacts of energy efficiency programs and improved codes and standards. Economic variables considered include GDP, households, population, and commercial and industrial employment. In the second stage, the incremental impacts of behind-the-meter solar PV and distributed generation are deducted from the forecast, and the incremental impacts of electric vehicle usage are added to the forecast. In the final stage, the NYISO aggregates load forecasts by Load Zone (referenced in the rest of this document as “Zone”).

These forecasts are based on information obtained from the New York State Department of Public Service (DPS), the New York State Energy Research and Development Authority (NYSERDA), state power authorities, Transmission Owners, the U.S. Census Bureau, and the U.S. Energy Information Administration. The baseline and topline forecasts reflect a combination of information provided by Transmission Owners for their respective territories and forecasts prepared by the New York ISO.¹⁵

Ontario

The IESO demand forecast includes the impact of conservation, time-of-use rates, and other price impacts, as well as the effects of distributed energy resources.

¹⁵ See: <https://www.nyiso.com/documents/20142/2226333/2019-Gold-Book-Final-Public.pdf/>

Québec

The load forecast was consistent with the assumptions used in the “NERC *2019 Québec Long-Term Reliability Assessment*.”¹⁶ Hydro-Québec’s demand and energy-sales forecasting is Hydro-Québec Distribution’s responsibility. First, the energy-sales forecast is built on the forecast from four different consumption sectors – domestic, commercial, small and medium-size industrial and large industrial. The model types used in the forecasting process are different for each sector and are based on end-use and/or econometric models. They consider weather variables, economic-driver forecasts, demographics, energy efficiency, and different information about large industrial customers. This forecast is normalized for weather conditions based on an historical trend weather analysis.

The requirements are obtained by adding transmission and distribution losses to the sales forecasts. The monthly peak demand is then calculated by applying load factors to each end-use and/or sector sale. The sum of these monthly end-use/sector peak demands is the total monthly peak demand.

Load Forecast Uncertainty (LFU) includes weather and load uncertainties. Weather uncertainty is due to variations in weather conditions. It is based on a 48-year database of temperatures (1971-2018), adjusted by +0.3 °C (+0.5 °F) per decade starting in 1971 to account for climate change. Moreover, each year of historical climatic data is shifted up to ±3 days to gain information on conditions that occurred during either a weekend or a weekday. Such an exercise generates a set of 336 different demand scenarios. The base case scenario is the arithmetical average of the peak hour in each of these 336 scenarios. Load uncertainty is due to the uncertainty in economic and demographic variables affecting demand forecast and to residual errors from the models.

Overall uncertainty is defined as the independent combination of climatic uncertainty and load uncertainty. This Overall Uncertainty, expressed as a percentage of standard deviation over total load, is lower during the summer than during the winter. As an example, at the summer peak, weather conditions uncertainty is about 470 MW, equivalent to one standard deviation. During winter, this uncertainty is 1,510 MW.

3.1.2 Load Model in MARS

The loads for each Area were modeled on an hourly, chronological basis, using the 2003/04 winter load shape. The MARS program modified the hourly loads through time to meet each Area's specified peaks and energies.

¹⁶ See: <https://www.nerc.com/pa/RAPA/ra/Pages/default.aspx>.

In 2006, the Working Group reviewed and agreed that the weather patterns associated with the 2003/04 winter are representative of weather conditions that stress the system and are appropriate for use in future winter assessments.

The growth rate in each month's peak was used to escalate Area loads to match the Area's winter demand and energy forecasts.

Figure 1 shows the diversity in the NPCC area load shapes used in this analysis, with the 2003/04 load shape assumptions.




Figure 1: 2019/20 Projected Monthly Peak Loads for NPCC

The effects on reliability of uncertainties in the peak load forecast due to weather and/or economic conditions were captured through the load forecast uncertainty model in MARS. The program computes the reliability indices at each of the specified load levels and calculates weighted-average values based on input probabilities of occurrence. For this study, seven load levels were modeled based on the monthly load forecast uncertainty provided by each Area.

The seven load levels represent the expected load level and one, two and three standard deviations above and below the expected load level.

In computing the reliability indices, all the Areas were evaluated simultaneously at the corresponding load level, the assumption being that the factors giving rise to the uncertainty affect all the Areas at the same time. The amount of the effect can vary according to the variations in the load levels.

Table 5 shows the load variation assumed for each of the seven load levels modeled and the probability of occurrence for the winter peak month in each Area. The probability of occurrence is the weight given to each of the seven load levels; it is equal to half of the sum of the two areas on either side of each standard deviation point under the probability distribution curve.

Table 5: Per Unit Variation in Load by Load Level Assumed for the month of January 2020

Area	Per-Unit Variation in Load						
	Level 1	Level 2	Level 3	Level 4	Level 5	Level 6	Level 7
HQ	1.084	1.084	1.042	1.000	0.959	0.916	0.911
MT	1.138	1.092	1.046	1.000	0.954	0.908	0.862
NE	1.093	1.038	0.997	0.963	0.940	0.850	0.800
NY	1.043	1.031	1.016	0.998	0.975	0.944	0.905
ON	1.057	1.043	1.022	1.000	0.972	0.945	0.928
Probability of Occurrence	0.0062	0.0606	0.2417	0.3830	0.2417	0.0606	0.0062

The results for this study are reported for two load conditions: expected and extreme. The values for the expected load conditions are derived from computing the reliability at each of the seven load levels and computing a weighted-average expected value based on the specified probabilities of occurrence.

The indices for the extreme load conditions provide a measure of the reliability in the event of higher than expected loads and were computed for the second-to-highest load level. They represent a load level two standard deviation higher than the expected load level, with a six percent probability of occurrence. These values are highlighted in Table 5.

While the extreme load as defined for this study may be different than the extreme load defined by the Areas in their own studies, the Working Group finds this load level appropriate for providing an assessment of the extreme condition in NPCC.

3.2 Resources

Table 6 below summarizes the winter 2019/20 capacity assumptions for the NPCC Areas used in the analysis for the Base Case Scenario and are consistent with the assumptions used in the NPCC CO-12 Working Group, "NPCC Reliability Assessment for Winter 2019-20", December 2019.

Additional adjustments were made for the Severe Scenario, as explained in section 3.7 of the report.

Table 6: Resource Assumptions at Winter Peak - Base Case (MW)

	HQ	MT	NE	NY	ON
Assumed Capacity ¹⁷	44,295	7,669	28,855	42,348	30,779
Demand Response ¹⁸	1,711	270	497	6	924
Net Imports/Exports ¹⁹	347	-110	917	209	-500
Reserve (%)	18.8	43.2	49.0 ²⁰	76.4	47.8
Scheduled Maintenance ²¹	-	110	-	3,667	2,808

¹⁷ Assumed Capacity - the total generation capacity assumed to be installed at the time of the winter peak. For New England, this is the amount of generation capacity assumed available after reflecting the reduction from gas-fired generation assumed due to fuel supply (4,700 MW).

¹⁸ Demand Response: the amount of "controllable" demand expected to be available for reduction at the time of peak. New York value represents the SCR amount. For New England, this represents the Active Demand Capacity Resources.

¹⁹ Net Imports / Exports: the amount of expected firm imports and exports at the time of the winter peak. The value is positive for imports and negative for exports.

²⁰ Based on the values shown in Table 1 – $30,299/20,476 = 149\%$.

²¹ Maintenance scheduled at time of peak.

Details regarding the NPCC Area's assumptions for generator unit availability are described in the respective Area's most recent NPCC Review of Resource Adequacy.²² In addition, the following Areas provided the following:

New England

The generating resources include the existing units and planned resources that are expected to be available for the 2019-20 winter, and their ratings are based on their Seasonal Claimed Capability. Settlement Only Generating (SOG) resources are not included in this assessment, but they do participate in the energy market and help serve New England system loads. Since last winter, ~1,000 MW of gas-fired generating capacity has been placed in-service, including Bridgeport Harbor 5, Canal 3 and West Medway Peakers. Pilgrim, an approximately 680 MW nuclear unit, has retired as of June 1, 2019 and has been factored into the winter assessment.

The resources assumed in this assessment also include the Active Demand Capacity Resources and capacity imports from the neighboring areas. The Active Demand Capacity Resources and imports are based on their Capacity Supply Obligations associated with the 3rd Annual Reconfiguration Auction for Capacity Commitment Period (CCP) of 2019-2020.²³

New York

Detailed availability assumptions used for the New York units can be found in the New York ISO Technical Study Report "Locational Minimum Installed Capacity Requirements Study covering the New York Control Area for the 2019 – 2020 Capability Year - January 17, 2019"²⁴ and the "New York Control Area Installed Capacity Requirement for the Period May 2019 to April 2020" New York State Reliability Council, December 7, 2018 report.²⁵

Ontario

Generating unit availability was based on the Ontario "Reliability Outlook - An adequacy assessment of Ontario's electricity system From October 2019 To March 2021" (September 19, 2019).²⁶

²² See: <https://www.npcc.org/Library/Resource%20Adequacy/Forms/Public%20List.aspx>.

²³ The 2019-2020 CCP starts on June 1, 2019 and ends on May 31, 2020.

²⁴ See: <https://www.nyiso.com/documents/20142/3679493/LCR2019-Report2-clean.pdf/d6ffe9be-a058-7cde-4bd3-725cce0105ef>.

²⁵ See: [http://www.nysrc.org/pdf/Reports/2019%20IRM%20Study%20Body-Final%20Report\[6815\].pdf](http://www.nysrc.org/pdf/Reports/2019%20IRM%20Study%20Body-Final%20Report[6815].pdf).

²⁶ See: <http://www.ieso.ca/-/media/Files/IESO/Document-Library/planning-forecasts/reliability-outlook/ReliabilityOutlook2019Sep.pdf?la=en>.

Québec

The planned resources are consistent with the “*NERC 2019 Long-Term Reliability Assessment*.”²⁷ The planned outages for the winter period are reflected in this assessment. The number of planned outages is consistent with historical values. The MARS modelling details for each type of resource in each Area are provided in Appendix D of the report.

Maritimes

Planned outages forecast to occur during the period are reflected in this assessment.

3.3 Transfer Limits

Figure 2 depicts the system that was represented in this assessment, showing Area and assumed Base Case transfer limits for the winter 2019/20 period.

Maritimes

Within the Maritimes Area, the areas of Nova Scotia, PEI, and Northern Maine are each connected internally only to New Brunswick. Only New Brunswick is interconnected externally with Québec and USA Maine areas.

New England

The New England transmission system consists of mostly 345 kV, 230 kV, and 115 kV transmission lines, which in northern New England generally are longer and fewer in number than in southern New England. The region has 13 interconnections with neighboring power systems in the United States and Eastern Canada. Nine interconnections are with New York (NYISO) (two 345 kV ties; one 230 kV tie; one 138 kV tie; three 115 kV ties; one 69 kV tie; and one 330 MW, ± 150 kV high-voltage direct-current (HVDC) tie—the Cross-Sound Cable interconnection).

New England and the Maritimes (New Brunswick Power Corporation) are connected through two 345 kV AC ties, the second of which was placed in service in December 2007. New England also has two HVDC interconnections with Québec (Hydro-Québec). One is a 120 kV AC interconnection (Highgate in northern Vermont) with a 225 MW back-to-back converter station, which converts alternating current to direct current and then back to alternating current. The other is a ± 450 kV HVDC line with terminal configurations allowing up to 2,000 MW to be delivered at Sandy Pond in Massachusetts (i.e., Phase II).

There are no anticipated transmission additions/upgrades during the upcoming winter.

²⁷ See: <https://www.nerc.com/pa/RAPA/ra/Pages/default.aspx>.

New York

The New York wholesale electricity market is divided into 11 pricing or load zones and is interconnected to Ontario, Quebec, New England, and PJM. The transmission network is comprised of 765 kV, 500 kV, 345 kV, 230 kV as well as 138 kV and 115 kV lines. These transmission lines exceed 11,000 miles in total.

Ontario

The Ontario transmission system is mainly comprised of a 500 kV transmission network, a 230 kV transmission network, and several 115 kV transmission networks. It is divided into ten zones and nine major internal interfaces in the Ontario transmission system. Ontario has interconnections with Manitoba, Minnesota, Québec, Michigan, and New York.

Québec

The Québec Area is a separate Interconnection from the Eastern Interconnection, into which the other NPCC Areas are interconnected. TransÉnergie, the main Transmission Owner and Operator in Québec, has interconnections with Ontario, New York, New England, and the Maritimes.

There are back to back HVDC links with New Brunswick at Madawaska and Eel River (in New Brunswick), with New England at Highgate (in New England) and with New York at Châteauguay. The Radisson – Nicolet – Sandy Pond HVDC line ties Québec with New England. Radial load can be picked up in the Maritimes by Québec at Madawaska and at Eel River and at Stanstead feeding Citizen's Utilities in New England. Moreover, in addition to the Châteauguay HVDC back to back interconnection to New York, radial generation can be connected to the New York system through Line 7040. The Variable Frequency Transformer (VFT) at Langlois substation connects into the Cedar Rapids Transmission system, down to New York State at Dennison. The Outaouais HVDC back to back converters and accompanying transmission to the Ottawa, Ontario area are now in service. Other ties between Québec and Ontario consist of radial generation and load to be switched on either system.

Transfer limits between and within some Areas are indicated in Figure 2 with seasonal ratings (S-summer, W- winter) where appropriate. Details regarding the transmission representation for Ontario ²⁸, New York ²⁹, and New England ³⁰ are provided in the respective references.

²⁸ See: <http://www.ieso.ca/localContent/ontarioenergymap/index.html>.

²⁹ See: [http://www.nysrc.org/pdf/Reports/2019%20IRM%20Study%20Appendices%20-Final%20Report\[6816\].pdf](http://www.nysrc.org/pdf/Reports/2019%20IRM%20Study%20Appendices%20-Final%20Report[6816].pdf).

³⁰ The New England Regional System plans can be found at: <http://www.iso-ne.com/trans/rsp/index.html>.




Figure 2: Assumed Transfer Limits

Note: With the Variable Frequency Transformer operational at Langlois (Cdrs), Hydro- Québec can import up to 100 MW from New York.³¹

The acronyms and notes used in Figure 2 are defined as follows:

Chur. - Churchill Falls	NOR - Norwalk – Stamford	RF - ReliabilityFirst
MANIT - Manitoba	BHE - Bangor Hydro Electric	NB - New Brunswick
ND - Nicolet-Des Cantons	Mtl - Montréal	PEI - Prince Edward Island
JB - James Bay	C MA - Central MA	CT - Connecticut
MAN - Manicouagan	W MA - Western MA	NS - Nova Scotia
NE - Northeast (Ontario)	NBM - Millbank	NW - Northwest (Ontario)
MRO - Midwest Reliability Organization	VT - Vermont	CSC - Cross Sound Cable
NM - Northern Maine	Que - Québec Centre	Cdrs - Cedars
	Centre	

³¹ See: http://www.oasis.oati.com/HQT/HQTdocs/2014-04_DEN_et_CORN-version_finale_en.pdf.

3.4 Operating Procedures to Mitigate Resource Shortages

Each Area takes defined steps as their reserve levels approach critical levels. These steps consist of those load control and generation supplements that can be implemented before firm load has to be disconnected. Load control measures could include disconnecting interruptible loads, public appeals to reduce demand, and voltage reductions. Other measures could include calling on generation available under emergency conditions, and/or reduced operating reserves. Table 7 summarizes the load relief assumptions modeled for each NPCC Area.

Table 7: NPCC Operating Procedures – 2019/20 Winter Load Relief Assumptions (MW)

Actions	HQ	MT	NE	NY ³²	ON
1. Curtail Load	1,461	-	-	-	-
Public Appeals	-	-	-	-	1%
RT-DR / SCR	-	-	-	618	-
SCR Load / Man. Volt. Red.	-	-	-	0.30 %	-
	-				
2. No 30-min Reserves	500	233	625	655	473
3. Voltage Reduction	250	-	207	1.2%	-
Interruptible Load ³³	-	270	-	166	924
4. No 10-min Reserves	750	505	-	-	945
Appeals / Curtailments	-	-	-	81	-
5. 5% Voltage Reduction	-	-	-	-	2.2%
No 10-min Reserves	-	-	980	1,310	-
Appeals / Curtailments	-	-	-	-	-

The Working Group recognizes that Areas may invoke these actions in any order, depending on the situation faced at the time; however, it was agreed that modeling the actions as in the order indicated in Table 7 was a reasonable approximation for this analysis.

The need for an Area to begin these operating procedures is modeled in MARS by evaluating the daily Loss of Load Expectation (LOLE) at specified margin states. The user specifies these margin states for each area in terms of the benefits realized from each emergency measure, which can be expressed in MW, as a per unit of the original or modified load, and as a per unit of the available capacity for the hour.

³² Values for New York’s SCR Program has been derated to account for historical availability.

³³ Interruptible Loads for Maritimes Area (implemented only for the Area), Voltage Reduction for all others.

3.5 Assistance Priority

All Areas received assistance on a shared basis in proportion to their deficiency. In this analysis, each step was initiated simultaneously in all Areas and sub- areas. The methodology used is described in Appendix C - Multi-Area Reliability Simulation Program Description - Resource Allocation Among Areas (Section C.3).

3.6 Modeling of Neighboring Regions

For the scenarios studied, a detailed representation of the PJM-RTO and MISO (Midcontinent Independent System Operator) was modeled. The assumptions are summarized in Table 8.

Table 8: PJM and MISO 2019/20 Base Case Assumptions³⁴

	PJM	MISO
Peak Load (MW)	129,140	79,189
Peak Month	January	January
Assumed Capacity (MW)	187,903	111,772
Purchase/Sale (MW)	474	-1,350
Reserve (%)	46.6	44.8
Weighted Unit Availability (%)	85.3	82.2
Operating Reserves (MW)	3,400	3,906
Curtable Load (MW)	965	4,272
No 30-min Reserves (MW)	2,765	2,670
Voltage Reduction (MW)	2,201	2,200
No 10-min Reserves (MW)	635	1,236
Appeals (MW)	400	400
Load Forecast Uncertainty (%)	100.0 +/- 3.4, 6.8, 10.1	100.0 +/- 2.6, 5.2, 7.9

Figure 3 shows the winter 2019/20 Projected Monthly Expected Peak Loads for NPCC, PJM and the MISO for the 2003/04 Load Shape assumption.

³⁴ Load and capacity assumptions for MISO based on NERC's Electricity and Supply Database (ES&D) available at: <http://www.nerc.com/pa/RAPA/ESD/Pages/default.aspx>.




Figure 3: 2019/20 Projected Monthly Winter Peak Loads – 2003/04 Load Shape

Beginning with the “*2015 NPCC Long Range Adequacy Overview*”, (LRAO) ³⁵ the MISO region (minus the recently integrated Entergy region) was included in the analysis replacing the RFC-OTH and MRO-US regions. In previous versions of the LRAO, RFC-OTH and MRO-US were included to represent specific areas of MISO, however due to difficulties in gathering load and capacity data for these two regions (since most of the reporting is done at the MISO level), it was decided to start including the entirety of MISO in the model.

MISO was modeled in this study due to the strong transmission ties of the region with the rest of the study system.

³⁵ See: <https://www.npcc.org/Library/Resource%20Adequacy/Forms/Public%20List.aspx>.

PJM-RTO

Load Model

The load model used for the PJM-RTO in this study is consistent with the PJM Planning division's technical methods.³⁶ The hourly load shape is based on observed 2003/04 calendar year values, which reflects representative weather and economic conditions for a winter peak planning study. The hourly loads were then adjusted per the PJM Load Forecast Report, January 2019.³⁷ Load Forecast Uncertainty was modeled consistent with recent planning PJM models³⁸ considering seven load levels, each with an associated probability of occurrence. This load uncertainty typically reflects factors such as weather, economics, diversity (timing) of peak periods among internal PJM zones, the period years the model is based on, sampling size, and how many years ahead in the future for which the load forecast is being derived.

Expected Resources

All generators that have been demonstrated to be deliverable were modeled as PJM capacity resources in the PJM-RTO study area. Existing generation resources, planned additions, modifications, and retirements are per the EIA-411 data submission and the PJM planning process. Load Management (LM) is modeled as an Emergency Operating Procedure. The total available MW as LM is as per results from the PJM's capacity market.

Expected Transmission Projects

The transfer values shown in the study are reflective of peak emergency conditions. PJM is a summer peaking area. The studies performed to determine these transfer values are in line with the Regional Transmission Planning Process employed at PJM, of which the Transmission Expansion Advisory Committee (TEAC) reviews these activities. All activities of the TEAC can be found at the [pjm.com](http://www.pjm.com) web site. All transmission projects are treated in aggregate, with the appropriate timing and transfer values changing in the model, consistent with PJM's regional Transmission Expansion Plan.³⁹

3.7 Study Scenarios

The study evaluated two cases (Base Case and Severe Case); a summary description is provided in Tables 9 and 10.

³⁶ Please refer to PJM Manuals 19 and 20 at <http://www.pjm.com/~media/documents/manuals/m19-redline.ashx> and <http://www.pjm.com/~media/documents/manuals/m20-redline.ashx> for technical specifics.

³⁷ See: <http://www.pjm.com/~media/library/reports-notices/load-forecast/2019-load-forecast-report.ashx>.

³⁸ See: <http://www.pjm.com/~media/planning/res-adeq/2018-pjm-reserve-requirement-study.ashx>.

³⁹ See: <http://www.pjm.com/planning.aspx>.

Table 9: Base Case and Severe Case Assumptions for the NPCC Area

	Base Case Assumptions	Severe Case – Additional Constraints
System	<ul style="list-style-type: none"> - As-Is System for the 2019-2020 period - Transfers allowed between Areas - 2003/04 and 2017/18 Load Shapes adjusted to the Area's year 2019 forecast (expected & extreme assumptions) 	<ul style="list-style-type: none"> - As-Is System for the 2019/20 period - Transfers allowed between Areas - Transfer capability between NPCC and MRO/RFC- 'Other' reduced by 50%. - 2003/04 and 2017/18 Load Shape adjusted to Area's year 2019 forecast (expected & extreme assumptions)
Maritimes	<ul style="list-style-type: none"> - ~ 1,170 MW of installed wind generation (modeled using 2017 calendar hourly wind, excluding 164 MW of formally energy only units in Nova Scotia) - 110 MW export contracts assumed - 270 MW of demand response (interruptible load) available in the Maritimes during the winter period 	<ul style="list-style-type: none"> - Wind capacity is de-rated by half (1,170 MW to 585 MW) for every hour in December, January and February to simulate icing conditions - 50% natural gas capacity curtailment (532 to 266 MW) assumed for winter 2019/20 to simulate a reduction in gas supply for December, January, and February (assuming dual fuel units revert to oil)
New England	<ul style="list-style-type: none"> - Resource and load consistent with the 2019 CELT report data for Winter 2019/2020: - ~ 33,550 MW of existing and planned generation resources modeled - ~ 2,668 MW of energy efficiency resources - ~ 497 MW of Active demand capacity resources - ~ 1,107 MW of capacity import - ~ 4,700 MW of gas-fired generation at risk due to fuel supply assumed unavailable 	<ul style="list-style-type: none"> - Assume 50% reduction to the import capabilities of external ties - Maintenance overrun by 4 weeks - ~ 5,200 MW of gas-fired generation at risk due to fuel supply assumed unavailable
New York	<ul style="list-style-type: none"> - Updated Load Forecast - (NYCA Winter 2019/20 peak load forecast – 24,123 MW; NYC 7,606 MW; LI – 3,365 MW) - Assumptions consistent with New York Installed Capacity Requirements for May 2019 through April 2020 - ~ 186 MW of units deactivated 	<ul style="list-style-type: none"> - Extended Maintenance in southeastern New York (500 MW) - 600 MW of assumed Cable transmission reduction across HVDC facilities - 4,000 MW of generation assumed unavailable across fleet due to fuel delivery issues.
Ontario	<ul style="list-style-type: none"> - Forecast consistent with the Ontario <i>Reliability Outlook - An adequacy assessment of Ontario's electricity system From October 2019 To March 2021</i> - ~36,989 MW of existing generation resources, ~354 MW of planned resources, and ~924 MW of demand resources modelled - Firm capacity exports modelled 	<ul style="list-style-type: none"> - ~1,300 MW of maintenance extended into the winter period - Hydroelectric capacity and energy 10% lower than the Base Case
Québec	<ul style="list-style-type: none"> - Resources and load forecast are consistent with the Québec 2019 NERC Long-Term Reliability Assessment - including about 1,400 MW of scheduled maintenance and restrictions - 3,776 MW of installed wind capacity (3,668 MW modeled with a 36% peak contribution) and 108 MW with a 30% peak contribution) representing a total peak contribution of 1,353 MW - 1,600 MW of available capacity imports - ~150 MW of firm capacity exports 	<ul style="list-style-type: none"> - ~1,000 MW of capacity assumed to be unavailable for the winter peak period

Table 10: Base Case and Severe Case Assumptions for Neighboring Areas

	Base Case Assumptions	Severe Case Assumptions
<i>PJM-RTO</i>	<ul style="list-style-type: none"> - As-Is System for the 2019/20 winter period – consistent with the PJM 2018 Reserve Requirement Study ⁴⁰ - 2003/04 and 2017/28 Load Shapes adjusted to the 2019 forecast provided by PJM - Load forecast uncertainty based on PJM 2018 Reserve Requirement Study - Operating Reserve 3,400 MW (30-min. 2,765 MW; 10-min. 635 MW) 	<ul style="list-style-type: none"> - Gas-fired only capacity not having firm pipeline transportation, assumed ~6,400 MW unavailable - One percentage point increase in load forecast uncertainty - Ice Storm; ice blocking fuel delivery to all units. Unit outage event ~8,400 MW
<i>MISO</i> ⁴¹	<ul style="list-style-type: none"> - As-Is System for the 2019/20 winter period - based on NERC ES&D database, updated by the MISO, compiled by PJM staff - 2003/04 and 2017/18 Load Shapes adjusted to the most recent monthly forecast provided by PJM - Load Forecast Uncertainty adjusted to the most recent monthly forecast provided by PJM - Operating Reserve 3,906 MW (30-min. 2,670 MW; 10-min. 1,236 MW) 	

⁴⁰ 2018 PJM Reserve Requirement Study (RRS), dated October 10, 2018 - available at this link on PJM Web site: <http://www.pjm.com/-/media/planning/res-adeq/2018-pjm-reserve-requirement-study.ashx>.

⁴¹ Does not include the MISO-South (Entergy region).

4. STUDY RESULTS

4.1 Base Case Scenario

Figure 4 shows the estimated need for the indicated operating procedures in days/period for the November 2019 through March 2020 period for the expected load (probability-weighted average of the seven load levels simulated) for the Base Case. Detailed results from MARS runs are provided in Appendix B.




Figure 4: Estimated Use of Operating Procedure for Winter 2019/20
 Base Case Assumptions - Expected Load Level

Figure 5 shows the corresponding results for the extreme load (representing the second to highest load level, having approximately a 6% chance of occurring) for the Base Case. Detailed results from MARS runs are provided in Appendix B.




Figure 5: Estimated Use of Operating Procedures for Winter 2019/20
 Base Case Assumptions - Extreme Load Level

4.2 Severe Case Scenario

Figure 6 shows the estimated use of operating procedures for the NPCC Areas for the expected load (probability-weighted average of the seven load levels simulated) for the Severe Case. Detailed results from MARS runs are provided in Appendix B.




Figure 6: Estimated Use of Operating Procedure for Winter 2019/20 Severe Case Assumptions - Expected Load Level

Figure 7 shows the estimated use of the indicated operating procedures for the Severe Case for the extreme load level (representing the second to highest load level, having approximately a 6% chance of occurring).




Figure 7: Estimated Use of Operating Procedure for Winter 2019/20 Severe Case Assumptions - Extreme Load Level

5. HISTORICAL REVIEW

Table 11 compares NPCC Area’s actual 2018/19 winter peak demands against the forecast assumptions.

Table 11: Comparison of NPCC 2018-19 Actual and Forecast Winter Peak Loads

Area	Date	Actual (MW)	Forecast (MW)		
			Expected Peak	Extreme Peak	Month
Québec	January 22, 2019	38,364	38,387	41,574	January
Maritimes	January 18, 2019	5,265	5,312	5,801	January
	February 27, 2019	5,410			
New England	January 21, 2019	20,719	20,476 ⁴²	21,355	January
New York	January 21, 2019	24,728	24,269	25,021	January
Ontario	January 21, 2019	21,525	21,328	22,249	January

A summary review of the last winter demand and main operational issues are presented below, while a detailed historical weather review is presented in APPENDIX E.

5.1 Operational Review

Québec

The actual internal winter peak demand of 38,364 MW occurred on Tuesday, January 22, 2019 hour ending 8:00 EST. The corresponding total winter peak demand (including exports) was 39,282 MW. At that time, 997 MW of interruptible industrial load was called for and net exports of 2,303 MW were sustained.

The Quebec area historical internal peak demand of 39,031 MW occurred on Wednesday, January 22, 2014 hour ending 8:00.

⁴² This is the net peak forecast reflecting the reduction from passive demand response resources and the load reduction impact from the Behind-the-Meter PV.

Maritimes

The Maritimes Area load is the mathematical sum of the forecasted or actual peak loads of the sub-areas (New Brunswick, Nova Scotia, Prince Edward Island, and the area served by the Northern Maine Independent System Operator).

Maritimes January 2018/19 winter peak was 5,265 MW on January 18, 2019 at hour ending 7:00 EST. The Maritime Provinces did not experience any unexpected extreme or adverse weather conditions; all major transmission lines were in-service.

New England ⁴³

December 2018 was warmer than the previous December; January 2019 was warmer than previous January – the peak load occurred of 20,719 MW occurred on Monday, January 21, 2019 at hour ending 18:00 EST at 4°F.

New England was affected by a brief cold snap between January 20th and January 22nd. Several major cities in New England had daytime high temperatures that were their coldest on record for Monday January 21st. The eight-city New England mean temperature on January 21st was only 4.4°F, which was 21.2°F below the normal of 25.6°F, resulting in the peak load day of the winter season so far. In addition, on January 20th a severe winter storm produced heavy inland snow, sleet and ice while coastal areas received heavy flooding rains and high winds.

There were no instances during the 2018/19 winter where ISO New England was required to implement Operating Procedure No. 4 (OP#4), Action During a Capacity Deficiency.

New York ⁴⁴

The 2018/19 actual winter Peak of 24,728 MW occurred on Monday, January 21, 2019, hour ending 19:00 EST during the Martin Luther King Holiday Weekend. Forecasted winter storm occurred Saturday night into Sunday followed by arctic cold conditions on Monday and into Tuesday. Minimum temperatures were -3°F in Syracuse, 0°F in Albany and 6°F in New York City.

An Arctic front arrived Wednesday (1/30/19) and stretched into Saturday (2/2/19). Recorded low temperatures were -2°F in Syracuse, -2°F in Albany and 4°F in New York City. Record natural gas consumption was experienced in the United States as well as many New York LDC and pipelines.

⁴³ See: <https://www.iso-ne.com/static-assets/documents/2019/02/2019-02-26-egoc-a2.1-iso-ne-winter-1819-review.pdf>.

⁴⁴ See: http://www.nysrc.org/pdf/MeetingMaterial/ECMeetingMaterial/EC%20Agenda%20240/7.3.1%20Winter%202018%20-%202019%20Cold%20Weather%20Operating%20Conditions_NYSRC-Attachment%207.3.1.pdf

During the 2018-19 Winter Operating Period, the New York ISO did not experience transmission or reactive capability issues, and was not required to utilize firm load shedding or emergency procedures.

The New York all time winter peak load of 25,738 MW occurred on Tuesday, January 7, 2014.

Ontario⁴⁵

December's weather was much milder than normal. Although January started with temperatures above 0°C, it was consistently colder than normal, with temperatures progressively increasing throughout the month. Despite the weather volatility and storms, February's weather was very close to normal.

The actual peak demand was 21,525 MW on January 21, 2019 hour ending 18 EST and was coincident to the NPCC peak. Overall, the 2018-2019 winter weather averaged close to normal. Energy demand for the three months from December to February was up 0.1% compared with the same three months one year prior. After adjusting for the weather, demand for the three months showed an increase of 0.3%.

6. CONCLUSIONS

Under Base Case conditions, only the Maritimes Area estimates a likelihood of using their operating procedures designed to mitigate resource shortages (reducing 30-min reserve and initiating interruptible loads) during the 2019/20 winter period for the expected load forecast (representing the probability weighted average of all seven load levels). The results for the extreme load forecast (representing the second to highest load level, having approximately a 6% chance of occurring) also estimates a need for reducing 10-min reserve, as well. The results are primarily driven by Nova Scotia's forecast load and corresponding reserve margin expectations.

The Maritimes Area estimated use of operating procedures increases assuming Severe Case conditions, especially for the extreme load forecast; again, these results are primarily driven by Nova Scotia's forecast load and corresponding reserve margin expectations. The Hydro-Quebec and Ontario Areas show use of their operating procedures (activation of DR/SCR, reduction of 30-min reserve) for the Severe Case, extreme load forecasts assumptions.

⁴⁵ See: <http://www.ieso.ca/Sector-Participants/IESO-News/2019/03/Reliability-Outlook-published>.

APPENDIX A

OBJECTIVE, SCOPE OF WORK AND SCHEDULE

A.1 Objective

On a consistent basis, evaluate the near term seasonal and long-range adequacy of NPCC Areas' and reflecting neighboring regional plans proposed to meet their respective resource adequacy planning criteria through multi-area probabilistic assessments. Monitor and include the potential effects of proposed market mechanisms in NPCC and neighboring regions expected to provide for future adequacy in the overview.

In meeting this objective, the CP-8 Working Group will use the G.E. Multi-Area Reliability Simulation (MARS) program, incorporating, to the extent possible, a detailed reliability representation for regions bordering NPCC for the 2019 - 2020 time period.

A.2 Scope

The near-term seasonal analyses will use the current CP-8 Working Group's G.E. MARS database to develop a model suitable for the 2019 – 2020 time period to consistently review the resource adequacy of NPCC Areas and reflecting neighboring Regions' assumptions under Base Case (likely available resources and transmission) and Severe Case assumptions for the May to September 2019 summer and November 2019 to March 2020 winter seasonal periods, recognizing:

- uncertainty in forecasted demand;
- scheduled outages of transmission;
- forced and scheduled outages of generation facilities, including fuel supply disruptions;
- the impacts of Sub-Area transmission constraints;
- the impacts of proposed load response programs; and,
- as appropriate, the reliability impacts that the existing and anticipated market rules may have on the assumptions, including the input data.

Reliability for the near-term seasonal analyses (2019 -2020) will be measured by estimating the use of NPCC Area operating procedures used to mitigate resource shortages.

A.3 Schedule

A report incorporating the results of the probabilistic multi-area summer assessment will be approved no later than April 19, 2019.

A report incorporating of the results of the probabilistic multi-area winter assessment will be approved no later than December 3, 2019.

APPENDIX B DETAILED STUDY RESULTS

Table 12: Base Case Assumptions - Expected Need for Indicated Operating Procedures (days/period)

Base Case	Quebec			Maritimes Area			New England			New York			Ontario									
	30-min	VR	10-min /Disc	30-min	IL	10-min	Appeal /Disc	30-min	VR	10-min	Appeal	Disc	30-min	VR	10-min	Appeal	Disc	30-min	VR	10-min	Appeal /Disc	
Expected Load																						
Nov	-	-	-	0.016	0.006	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Dec	-	-	-	0.939	0.515	0.064	0.008	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Jan	-	-	-	0.808	0.454	0.069	0.010	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Feb	-	-	-	0.042	0.017	0.002	0.000	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Mar	-	-	-	0.032	0.013	0.000	0.000	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Nov-Mar	-	-	-	1.836	1.005	0.135	0.018	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Extreme Load																						
Nov	-	-	-	0.145	0.059	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Dec	-	-	-	5.716	3.564	0.601	0.076	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Jan	0.006	-	-	4.766	3.222	0.719	0.139	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0.001
Feb	-	-	-	0.407	0.207	0.023	0.001	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Mar	-	-	-	0.273	0.122	0.001	0.000	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Nov-Mar	0.006	-	-	11.308	7.174	1.345	0.216	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0.001

Notes: "30-min" - reduce 30-minute Reserve Requirement; "VR" - and initiate Voltage Reduction ("IL" - initiate Interruptible Loads for the Maritimes Area); "10-min" - and reduce 10-minute Reserve Requirement; "Appeal" - and initiate General Public Appeals; "Disc" - and disconnect customer load. Occurrences 0.5 or greater are highlighted.

Table 13: Severe Case Scenario - Expected Need for Indicated Operating Procedures (days/period)

Severe Case Results																							
Québec					Maritimes					Area													
					New England					New York					Ontario								
30-min	VR	10-min	Apl	Disc	30-min	VR	10-min	Apl	IL	10-min	Apl	Disc	30-min	VR	10-min	Apl	Disc	30-min	VR	10-min	Apl	Disc	
Expected Load																							
Nov	-	-	-	-	0.016	0.006	-	-	0.006	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Dec	-	-	-	-	6.241	4.394	1.511	0.315	0.315	0.315	0.315	0.315	-	-	-	-	-	-	-	-	-	-	-
Jan	0.061	0.026	0.009	-	4.625	3.490	1.250	0.288	0.288	0.288	0.288	0.288	-	-	-	-	-	0.061	0.013	0.001	-	-	-
Feb	-	-	-	-	0.939	0.622	0.156	0.015	0.015	0.015	0.015	0.015	-	-	-	-	-	-	-	-	-	-	-
Mar	-	-	-	-	0.032	0.013	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Nov-Mar	0.061	0.026	0.009	-	11.852	8.525	2.918	0.618	0.618	0.618	0.618	0.618	0.006	-	-	-	-	0.061	0.013	0.001	-	-	-
Extreme Load																							
Nov	-	-	-	-	0.145	0.059	-	-	-	0.067	0.013	0.008	0.008	0.002	-	-	-	-	-	-	-	-	-
Dec	-	-	-	-	23.789	20.732	10.668	3.155	3.155	3.155	3.155	3.155	-	-	-	-	-	-	-	-	-	-	-
Jan	0.798	0.381	0.129	-	17.713	14.764	7.351	2.492	2.492	2.492	2.492	2.492	-	-	-	-	-	0.755	0.193	0.021	-	-	-
Feb	-	-	-	-	7.672	5.682	1.833	0.210	0.210	0.210	0.210	0.210	-	-	-	-	-	0.005	-	-	-	-	-
Mar	-	-	-	-	0.273	0.122	0.001	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Nov-Mar	0.798	0.381	0.129	-	49.593	41.361	19.853	5.858	5.858	5.858	5.858	5.858	0.067	0.013	0.008	0.008	0.002	0.759	0.193	0.021	-	-	-

Notes: "30-min"-, reduce 30-minute Reserve Requirement; "VR"- and initiate Voltage Reduction ("IL" - initiate Interruptible Loads for the Maritimes Area); "10-min"- and reduce 10-minute Reserve Requirement; "Apl"- and initiate General Public Appeals; "Disc"- and disconnect customer load. Occurrences 0.5 or greater are highlighted.

APPENDIX C

MULTI-AREA RELIABILITY PROGRAM DESCRIPTION

General Electric's Multi-Area Reliability Simulation (MARS) program ⁴⁶ allows assessment of the reliability of a generation system comprised of any number of interconnected areas.

C.1 Modeling Technique

A sequential Monte Carlo simulation forms the basis for MARS. The Monte Carlo method allows for many different types of generation and demand-side options.

In the sequential Monte Carlo simulation, chronological system histories are developed by combining randomly generated operating histories of the generating units with the inter-area transfer limits and the hourly chronological loads. Consequently, the system can be modeled in great detail with accurate recognition of random events, such as equipment failures, as well as deterministic rules and policies that govern system operation.

C.2 Reliability Indices

The following reliability indices are available on both an isolated (zero ties between areas) and interconnected (using the input tie ratings between areas) basis:

- Daily Loss of Load Expectation (LOLE - days/year)
- Hourly LOLE (hours/year)
- Loss of Energy Expectation (LOEE -MWh/year)
- Frequency of outage (outages/year)
- Duration of outage (hours/outage)
- Need for initiating Operating Procedures (days/year or days/period)

The Working Group used both the daily LOLE and Operating Procedure indices for this analysis. The use of Monte Carlo simulation allows for the calculation of probability distributions, in addition to expected values, for all the reliability indices. These values can be calculated both with and without load forecast uncertainty.

The MARS program probabilistically models uncertainty in forecast load and generator unit availability. The program calculates expected values of Loss of Load Expectation (LOLE) and can estimate each Area's expected exposure to their Emergency Operating Procedures. Scenario

⁴⁶ See: <http://ge-energyconsulting.com/practice-area/software-products/mars>

analysis is used to study the impacts of extreme weather conditions, variations in expected unit in-service dates, overruns in planned scheduled maintenance, or transmission limitations.

C.3 Resource Allocation Among Areas

The first step in calculating the reliability indices is to compute the area margins on an isolated basis, for each hour. This is done by subtracting from the total available capacity in the area for the hour the load demand for the hour. If an area has a positive or zero margin, then it has sufficient capacity to meet its load. If the area margin is negative, the load exceeds the capacity available to serve it, and the area is in a loss-of-load situation.

If there are any areas that have a negative margin after the isolated area margins have been adjusted for curtailable contracts, the program will attempt to satisfy those deficiencies with capacity from areas that have positive margins. Two methods are available for determining how the reserves from areas with excess capacity are allocated among the areas that are deficient. In the first approach, the user specifies the order in which an area with excess resources provides assistance to areas that are deficient. The second method shares the available excess reserves among the deficient areas in proportion to the size of their shortfalls. The user can also specify that areas within a pool will have priority over outside areas. In this case, an area must assist all deficient areas within the same pool, regardless of the order of areas in the priority list, before assisting areas outside of the pool. Pool-sharing agreements can also be modeled in which pools provide assistance to other pools according to a specified order.

C.4 Generation

MARS has the capability to model the following different types of resources:

- Thermal
- Energy-limited
- Cogeneration
- Energy-storage
- Demand-side management

An energy-limited unit can be modeled stochastically as a thermal unit with an energy probability distribution (Type 1 energy-limited unit), or deterministically as a load modifier (Type 2 energy-limited unit). Cogeneration units are modeled as thermal units with an associated hourly load demand. Energy-storage and demand-side management impacts are modeled as load modifiers.

For each unit modeled, the installation and retirement dates and planned maintenance requirements are specified. Other data such as maximum rating, available capacity states, state transition rates, and net modification of the hourly loads are input depending on the unit type.

The planned outages for all types of units in MARS can be specified by the user or automatically scheduled by the program on a weekly basis. The program schedules planned maintenance to levelize reserves on an area, pool, or system basis. MARS also has the option of reading a maintenance schedule developed by a previous run and modifying it as specified by the user through any of the maintenance input data. This schedule can then be saved for use by subsequent runs.

Thermal Unit

In addition to the data described previously, thermal units (including Type 1 energy-limited units and cogeneration) require data describing the available capacity states in which the unit can operate. This is input by specifying the maximum rating of each unit and the rating of each capacity state as a per unit of the unit's maximum rating. A maximum of eleven capacity states is allowed for each unit, representing decreasing amounts of available capacity as governed by the outages of various unit components.

Because MARS is based on a sequential Monte Carlo simulation, it uses state transition rates, rather than state probabilities, to describe the random forced outages of the thermal units. State probabilities give the probability of a unit being in a given capacity state at any particular time and can be used if you assume that the unit's capacity state for a given hour is independent of its state at any other hour. Sequential Monte Carlo simulation recognizes the fact that a unit's capacity state in a given hour is dependent on its state in previous hours and influences its state in future hours. It thus requires the additional information that is contained in the transition rate data.

For each unit, a transition rate matrix is input that shows the transition rates to go from each capacity state to each other capacity state. The transition rate from state A to state B is defined as the number of transitions from A to B per unit of time in state A:

$$\text{TR (A to B)} = \frac{\text{Number of Transitions from A to B}}{\text{Total Time in State A}}$$

If detailed transition rate data for the units is not available, MARS can approximate the transition rates from the partial forced outage rates and an assumed number of transitions between pairs of capacity states. Transition rates calculated in this manner will give accurate results for LOLE and LOEE, but it is important to remember that the assumed number of transitions between states will have an impact on the time-correlated indices such as frequency and duration.

Energy-Limited Units

Type 1 energy-limited units are modeled as thermal units whose capacity is limited on a random basis for reasons other than the forced outages on the unit. This unit type can be used to model a

thermal unit whose operation may be restricted due to the unavailability of fuel, or a hydro unit with limited water availability. It can also be used to model technologies such as wind or solar; the capacity may be available, but the energy output is limited by weather conditions.

Type 2 energy-limited units are modeled as deterministic load modifiers. They are typically used to model conventional hydro units for which the available water is assumed to be known with little or no uncertainty. This type can also be used to model certain types of contracts.

A Type 2 energy-limited unit is described by specifying a maximum rating, a minimum rating, and a monthly available energy. This data can be changed on a monthly basis. The unit is scheduled on a monthly basis with the unit's minimum rating dispatched for all of the hours in the month. The remaining capacity and energy can be scheduled in one of two ways. In the first method, it is scheduled deterministically so as to reduce the peak loads as much as possible. In the second approach, the peak-shaving portion of the unit is scheduled only in those hours in which the available thermal capacity is not sufficient to meet the load; if there is sufficient thermal capacity, the energy of the Type 2 energy-limited units will be saved for use in some future hour when it is needed.

Cogeneration

MARS models cogeneration as a thermal unit with an associated load demand. The difference between the unit's available capacity and its load requirements represents the amount of capacity that the unit can contribute to the system. The load demand is input by specifying the hourly loads for a typical week (168 hourly loads for Monday through Sunday). This load profile can be changed on a monthly basis. Two types of cogeneration are modeled in the program, the difference being whether or not the system provides back-up generation when the unit is unable to meet its native load demand.

Energy-Storage and DSM

Energy-storage units and demand-side management impacts are both modeled as deterministic load modifiers. For each such unit, the user specifies a net hourly load modification for a typical week which is subtracted from the hourly loads for the unit's area.

C.5 Transmission System

The transmission system between interconnected areas is modeled through transfer limits on the interfaces between pairs of areas. The transfer limits are specified for each direction of the interface and can be changed on a monthly basis. Random forced outages on the interfaces are modeled in the same manner as the outages on thermal units, through the use of state transition rates.

C.6 Contracts

Contracts are used to model scheduled interchanges of capacity between areas in the system. These interchanges are separate from those that are scheduled by the program as one area with excess capacity in a given hour provides emergency assistance to a deficient area.

Each contract can be identified as either firm or curtailable. Firm contracts will be scheduled regardless of whether the sending area has sufficient resources on an isolated basis, but they will be curtailed because of interface transfer limits. Curtailable contracts will be scheduled only to the extent that the sending Area has the necessary resources on its own or can obtain them as emergency assistance from other areas.

APPENDIX D

MODELING DETAILS

D.1 Resources

Details regarding the NPCC Area's assumptions for resources are described in the respective Area's most recent "*NPCC Comprehensive Review of Resource Adequacy*".⁴⁷ In addition, the following Areas provided the following:

New England

The New England generating unit ratings were consistent with their seasonal capability as reported in the 2019 CELT report.⁴⁸ Active Demand Capacity Resources and capacity imports are based on their Capacity Supply Obligations of the 3rd annual Reconfiguration Auction of Capacity Commitment Period of 2019-2020.

New York

The Base Case assumes that the New York City and Long Island localities will meet their locational installed capacity requirements as described in the New York ISO Technical Study Report "*Locational Minimum Installed Capacity Requirements Study covering the New York Control Area for the 2019 – 2020 Capability Year - January 17, 2019*"⁴⁹ and the "*New York Control Area Installed Capacity Requirement for the Period May 2019 to April 2020*" New York State Reliability Council, December 7, 2018 report.⁵⁰

Existing Resources

All in-service New York generation resources were modeled. The New York unit ratings were based on the Dependable Maximum Net Capability (DMNC) values from the "*2019 Load & Capacity Data of the NYISO*" (Gold Book).⁵¹

⁴⁷ See: <https://www.npcc.org/Library/Resource%20Adequacy/Forms/Public%20List.aspx>.

⁴⁸ See: <https://www.iso-ne.com/system-planning/system-plans-studies/celt/>.

⁴⁹ See: <https://www.nyiso.com/documents/20142/3679493/LCR2019-Report2-clean.pdf/d6ffe9be-a058-7cde-4bd3-725cce0105ef>.

⁵⁰ See: [http://www.nysrc.org/pdf/Reports/2019%20IRM%20Study%20Body-Final%20Report\[6815\].pdf](http://www.nysrc.org/pdf/Reports/2019%20IRM%20Study%20Body-Final%20Report[6815].pdf).

⁵¹ See: <https://www.nyiso.com/documents/20142/2226333/2019-Gold-Book-Final-Public.pdf/>.

Ontario

For the purposes of this study, the Base Case assumptions for Ontario are consistent with the normal weather, planned scenario in the Ontario “*Reliability Outlook - An adequacy assessment of Ontario’s electricity system From October 2019 To March 2021*” (September 19, 2019).⁵² The Base Case assumes the availability of the existing installed resources and resources that are scheduled to come into service over the assessment period. The generator planned shutdowns or retirements that have high certainty of occurring in the future are also considered in the scenario. Non-Utility generators (NUG) whose contracts expire during the outlook period are included only up to their contract expiry date. Those NUGs that continue to provide forecast data after contract expiry are also included in the planned scenario for the rest of the outlook period.

Québec

The Planned resources are consistent with the “*NERC 2019 Long-Term Reliability Assessment*.”⁵³

Maritimes

Resources in the Maritimes Area are modeled with winter DMNC ratings.

D.2 Resource Availability

New England

This probabilistic assessment reflects New England generating unit availability assumptions based upon historical performance over the prior five-year period. Unit availability modeled reflects the projected scheduled maintenance and forced outages. Individual generating unit maintenance assumptions are based upon the approved maintenance schedules. Individual generating unit forced outage assumptions were based on the unit’s historical data and North American Reliability Corporation (NERC) average data for the same class of unit.

New York

Detailed availability assumptions used for the New York units can be found in the New York ISO Technical Study Report “*Locational Minimum Installed Capacity Requirements Study covering the New York Control Area for the 2019 – 2020 Capability Year - January 17, 2019*”⁵⁴ and the “*New York Control Area Installed Capacity Requirement for the Period May 2019 to April 2020*” New York State Reliability Council, December 7, 2018 report.⁵⁵

⁵² See: http://www.ieso.ca/en/Sector-Participants/Planning-and-Forecasting/Reliability-Outlookhttp://www.ieso.ca/-/media/Files/IESO/Document-Library/planning-forecasts/reliability_outlook/ReliabilityOutlook2019Sep.pdf?la=en.

⁵³ See: <https://www.nerc.com/pa/RAPA/ra/Pages/default.aspx>.

⁵⁴ See: <https://www.nyiso.com/documents/20142/3679493/LCR2019-Report2-clean.pdf/d6ffe9be-a058-7cde-4bd3-725cce0105ef>.

⁵⁵ See: [http://www.nysrc.org/pdf/Reports/2019%20IRM%20Study%20Body-Final%20Report\[6815\].pdf](http://www.nysrc.org/pdf/Reports/2019%20IRM%20Study%20Body-Final%20Report[6815].pdf).

Ontario

For the purposes of this study, the Base Case assumptions for Ontario are consistent with the normal weather, planned scenario in the Ontario “*Reliability Outlook - An adequacy assessment of Ontario’s electricity system From October 2019 To March 2021*” (September 19, 2019).⁵⁶

Québec

The planned outages for the winter period are reflected in this assessment. The number of planned outages is consistent with historical values.

Maritimes

Individual generating unit maintenance assumptions are based on approved maintenance schedules for the study period.

⁵⁶ See: <http://www.ieso.ca/-/media/Files/IESO/Document-Library/planning-forecasts/reliability-outlook/ReliabilityOutlook2019Sep.pdf?la=en>.

D.3 Thermal

New England

The Seasonal Claimed Capability as established through the Claimed Capability Audit, is used to represent the non-intermittent thermal resources. The Seasonal Claimed Capability for intermittent thermal resources is based on their historical median net real power output during Reliability Hours.

New York

Installed capacity values for thermal units are based on seasonal Dependable Maximum Net Capability (DMNC) test results. Generator availability is derived from the most recent calendar five-year period forced outage data. Units are modeled in the MARS Program using a multi-state representation that represents an equivalent forced outage rate on demand (EFORD). Planned and scheduled maintenance outages are modeled based upon schedules received by the New York ISO and adjusted for historical maintenance. A nominal MW value for the summer assessment representing historical maintenance during the summer peak period is also modeled.

Ontario

The capacity values and planned outage schedules for thermal units are based on monthly maximum continuous ratings and planned outage information contained in market participant submissions. The available capacity states and state transition rates for each existing thermal unit are derived based on analysis of a rolling five-year history of actual forced outage data. For existing units with insufficient historical data, and for new units, capacity states and state transition rate data of existing units with similar size and technical characteristics are applied.

Quebec

For thermal units, Maximum Capacity is defined as the net output a unit can sustain over a two-consecutive hour period.

Maritimes

Combustion turbine capacity for the Maritimes Area is winter Dependable Maximum Net Capability (DMNC). During summer, these values are de-rated accordingly.

D.4 Hydro

New England

New England uses the Seasonal Claimed Capability as established through the Claimed Capability Audit to represent the hydro resources. The Seasonal Claimed Capability for intermittent hydro resources is based on their historical median net real power output during Reliability Hours (14:00 – 18:00).

New York

Large hydro units are modeled as thermal units with a corresponding multi-state representation that represents an Equivalent Forced Outage rate on Demand (EFORd). For run of river units, New York provides 8760 hours of historical unit profiles for each year of the most recent five-year calendar period for each facility based on production data. Run of river unit seasonality is captured by using GE-MARS functionality to randomly select an annual shape for each run of river unit in each draw. Each shape is equally weighted.

Ontario

Hydroelectric resources are modelled in the MARS Program as capacity-limited and energy-limited resources. Minimum capacity, maximum capacity and monthly energy values are determined on an aggregated basis for each zone based on historical data since market opening (2002).

Quebec

For hydro resources, maximum capacity is set equal to the power that each plant can generate at its maximum rating during two full hours, while expected on-peak capacity is set equal to maximum capacity minus scheduled maintenance outages and restrictions.

Maritimes

Hydro in the Maritimes is predominantly run of the river, but enough storage is available for full rated capability during daily peak load periods.

D.5 Solar

New England

The majority of solar resource development in New England is the state-sponsored distributed Behind-the-Meter (BTM) Photovoltaic (PV) resources that does not participate in wholesale markets but reduces the system load observed by ISO. The BTM PV are modeled as a load modifier on an hourly basis, based on the 2002 historical hourly weather profile.

New York

New York provides 8,760 hours of historical solar profiles for each year of the most recent five-year calendar period for each solar plant based on production data. Solar seasonality is captured

by using GE-MARS functionality to randomly select an annual solar shape for each solar unit in each draw. Each solar shape is equally weighted.

Summer capacity values for solar units are based on average production during hours 14:00 to 18:00 for the months of June, July, and August. Winter capacity values for solar units are based on average production during hours 16:00 to 20:00 for the months of December, January, and February.

Ontario

Historical hourly profiles are used to model solar generation.

Québec

In the Québec area, the peak contribution of behind-the-meter generation (solar and wind) is estimated at less than 1 MW for winter 2019-20 and doesn't affect the load monitored from a network perspective.

Maritimes

At this time, solar capacity in the Maritimes is behind the meter and netted against load forecasts. It does not currently count as capacity.

D.6 Wind

New England

New England models the wind resources using the Seasonal Claimed Capability as determined based on their historical median net real power output during Reliability Hours (14:00 – 18:00).

New York

New York provides 8,760 hours of historical wind profiles for each year of the most recent five-year calendar period for each wind plant based on production data. Wind seasonality is captured by using the-MARS functionality to randomly select an annual wind shape for each wind unit in each draw. Each wind shape is equally weighted.

Summer capacity values for wind units are based on average production during hours 14:00 to 18:00 for the months of June, July, and August. Winter capacity values for wind units are based on average production during hours 16:00 to 20:00 for the months of December, January, and February.

Ontario

Historical hourly profiles are used to model wind generation.

Québec

The expected capacity at winter peak is 36% of the Installed (Nameplate) capacity, except for a small amount (roughly 3%) which is derated for all years of the study. For the summer period, wind power generation is derated by 100%.

Maritimes

The Maritimes Area used a probabilistic selection of two wind shapes for 2011/12 and 2017; each sub-area's actual MW wind output was normalized by the total installed capacity in the sub-area during that fiscal year. The data is considered typical having had substantially all of the existing Maritimes Area wind resources by that time and no major outages due to icing or other abnormal weather or operating problems. These profiles, when multiplied by current sub-area total installed wind capacities yield an annual wind forecast for each sub-area. The sum of these four sub-area forecasts is the Maritimes Area's hourly wind forecast.

D.7 Demand Response

New England

The passive non-dispatchable demand resources, On-Peak and Seasonal-Peak, are expected to provide ~2,668 MW of load relief during the peak hours. Starting on June 1, 2018, price-responsive Demand Response (DR) was fully integrated into New England's Energy and Reserve Markets. These resources are treated similarly to generating resources. That is, they are dispatchable and participate in both the daily energy and reserves markets. About 497 MW of Active Demand Capacity Resources are expected to be available to offer to sell demand-reductions in the energy market.

New York

The Installed Capacity (ICAP) Special Case Resource program allows demand resources that meet certification requirements to offer Unforced Capacity ("UCAP") to Load Serving Entities. The load reduction capability of Special Case Resources ("SCRs") may be sold in the ICAP Market just like any other ICAP Resource; however, SCRs participate through Responsible Interface Parties (RIPs), which serve as the interface between the New York ISO and the resources. RIPs also act as aggregators of SCRs. SCRs that have sold ICAP are obligated to reduce their system load when called upon by the New York ISO with two or more hours notice, provided the NYISO notifies the Responsible Interface Party a day ahead of the possibility of such a call. In addition, enrolled SCRs are subject to testing each Capability Period to verify their capability to achieve the amount of enrolled load reduction. Failure of an SCR to reduce load during an event or test results in a reduction in the amount of UCAP that can be sold in future periods and could result in penalties assessed to the applicable RIP in accordance with the ICAP/SCR program rules and procedures. Curtailments are called by the NYISO when reserve shortages are anticipated or during other emergency operating conditions. Resources may register for either the Emergency Demand

Response Program (EDRP) or ICAP/SCR but not both. In addition to capacity payments, RIPs are eligible for an energy payment during an event, using the same calculation methodology as EDRP resources.

The EDRP provides demand resources an opportunity to earn the greater of \$500/MWh or the prevailing locational-based marginal price for energy consumption curtailments provided when the New York ISO calls on the resource. Resources must be enrolled through Curtailment Service Providers, which serve as the interface between the New York ISO and resources, in order to participate in EDRP. There are no obligations for enrolled EDRP resources to curtail their load during an EDRP event.

SCRs and EDRPs are modeled as an operating procedure step activated to minimize the probability of customer load disconnection. The MARS Program models the New York ISO operations practice of only activating operating procedures in zones from which are capable of being delivered.

For this study, 1,309 MW of SCRs were modeled. At the time of the winter peak, this amount was discounted to 610 MW based on historical availability.

EDRPs were modeled as a 16 MW operating procedure step and are also limited to a maximum of five EDRP calls per month. This value was discounted based on actual experience from the forecast registered amount to 8 MW.

Ontario

The demand measures assumed a total of 924 MW for the winter period.

Québec

Demand Response (DR) programs in the Québec Area specifically designed for peak-load reduction during winter operating periods are mainly interruptible load programs, totaling 2,284 MW for the 2019-20 winter period. DR also includes 250 MW of voltage reduction.

Maritimes

Demand Response in the Maritimes Area is currently comprised of contracted interruptible loads.

APPENDIX E

PREVIOUS WINTER REVIEW

E.1 Weather

Highlights - (December 2018 - March 2019) ⁵⁷

The year-to-date (January-March) average contiguous U.S. temperature was 35.0°F, 0.1°F below average, ranking among the middle third of the record. This was the coldest start to a year since 2014 for the nation.

Above-average temperatures were primarily observed across the Southeast and Atlantic Coast. Florida had an average January–March temperature that ranked among its 10 warmest on record. Near-average conditions stretched from the southern Plains to the Northeast and across much of the West. Below-average temperatures were present across the northern and central Plains and parts of the West.

The contiguous U.S. average maximum (daytime) temperature during January-March was 45.3°F, 0.8°F below the 20th century average, ranking in the middle third of the historical record. Above-average conditions were observed across much of the Southeast and Atlantic Coast. Below-average maximum temperature dominated the Great Plains and parts of the West.

The contiguous U.S. average minimum (nighttime) temperature during January-March was 24.7°F, 0.5°F above the 20th century average, ranking in the middle third of the record. Above-average conditions were observed across the South, Southeast and Atlantic Coast. Below-average conditions were observed in the Northwest and northern Plains.

The Alaska January-March temperature was 16.6°F, 10.7°F above the long-term average, the third warmest on record for the state. Record temperatures were observed across most of the state with much-above-average temperatures occurring across the Aleutians and the panhandle.

Based on [REDTI](#), the contiguous U.S. temperature-related energy demand during January-March was 10% below average and was the 49th lowest value on record.

⁵⁷ NOAA National Centers for Environmental Information, State of the Climate: National Climate Report for March 2019, published online April 2019, retrieved on November 3, 2019 from <https://www.ncdc.noaa.gov/sotc/national/201903>.

Northeast Region

December ⁵⁸

The Northeast's average temperature for December was 29.3 degrees F (-1.5 degrees C), 0.8 degrees F (0.4 degrees C) warmer than normal. Nine of the region's twelve states were warmer than normal, with average temperatures for all states ranging from 1.6 degrees F (0.9 degrees C) below normal in Maine to 3.3 degrees F (1.8 degrees C) above normal in Delaware.

December precipitation was 3.98 inches (101.09 mm), 143 percent of normal, for the Northeast. Six states were wetter than normal, with precipitation for all twelve ranged from 88% of normal in New Hampshire to 150% of normal in New Jersey.

Abnormally dry conditions in northern New York, northern Vermont, and northern Maine remained unchanged during most of December, with the December 4 U.S. Drought Monitor and the December 25 U.S. Drought Monitor both showing 4% of the Northeast as abnormally dry. Precipitation deficits, streamflow, and groundwater levels improved enough in a few spots to warrant some easing of abnormal dryness by early January, with the January 1 U.S. Drought Monitor showing 3% of the Northeast as abnormally dry.

January ⁵⁹

January's average temperature of 23.3°F (-4.8°C) was 0.1°F (0.1°C) warmer than normal for the Northeast. Ten of the region's twelve states experienced an above-normal January average temperature, with departures for all states ranging from 1.2°F (0.7°C) below normal in New York to 1.4°F (0.8°C) above normal in Massachusetts and West Virginia.

The first month of 2019 brought above-normal precipitation to the Northeast. The region's 4.39 inches (111.51 mm) of precipitation, 141% of normal, made it the 16th wettest January since records began in 1895. All states were wetter than normal, with seven ranking this January among their 20 wettest on record: Rhode Island and Vermont, eighth wettest; New Hampshire and New York, 11th wettest; Maine, 13th wettest; Connecticut, 14th wettest; and Massachusetts, 17th wettest. Precipitation ranged from 107% of normal in Maryland to 168% of normal in Rhode Island. Caribou, Maine, had its wettest January on record.

The January 1st U.S. Drought Monitor showed 3% of the Northeast as abnormally dry. Above-normal precipitation allowed abnormally dry conditions to ease in northern New York in early January and in northern Vermont and northern Maine later in the month. The January 22 U.S.

⁵⁸ NOAA National Centers for Environmental Information, State of the Climate: National Climate Report for December 2018, published online January 2019, retrieved on November 3, 2019 from <https://www.ncdc.noaa.gov/sotc/national/201812>.

⁵⁹ NOAA National Centers for Environmental Information, State of the Climate: National Climate Report for January 2019, published online February 2019, retrieved on November 3, 2019 from <https://www.ncdc.noaa.gov/sotc/national/201901>.

Drought Monitor showed the Northeast was free of drought and abnormal dryness for the first time since June 6, 2017. The region remained free of dryness for the rest of the month.

Mercer County, Pennsylvania, had its first January tornado on record (since 1950) when an EF-1 tornado snapped and uprooted trees on January 8th. A major storm moved through the region from January 19 to 21. Storm snow totals were up to 24 inches (61 cm), with the greatest amounts in New York and northern New England. The storm also produced ice accumulations of up to 0.60 inches (1.5 cm), with the greatest amounts in Connecticut, and rain totals of up to 4 inches (102 mm), with the greatest amounts in eastern Massachusetts and Rhode Island. The precipitation and wind gusts of up to 61 mph (27 m/s) contributed to downed trees, power outages, travel disruptions, and flooding. An Arctic front produced intense snow squalls that led to a few multi-vehicle accidents on January 30th. Behind the front, cold air poured into the region and strong winds created subzero wind chills. A multi-day lake-effect event unfolded east of Lakes Erie and Ontario in New York, with snow totals up to 37.6 inches (95.5 cm) south of Watertown and up to 21 inches (53.3 cm) in Buffalo from January 29th through February 1st. Whiteout and blizzard conditions led to extremely difficult travel, with travel bans enacted and some road closures. Caribou, Maine, recorded its snowiest January on record with 59.8 inches (151.9 cm) of snow. This was just 0.1 inches (0.25 cm) short of tying its all-time snowiest month, December 1972 with 59.9 inches (152.1 cm).

February⁶⁰

The Northeast's average temperature for February was 27.4 degrees F (-2.6 degrees C), 1.2 degrees F (0.7 degrees C) warmer than normal. Nine of the region's twelve states experienced a warmer-than-normal February. Average temperature departures for all states ranged from 0.8 degrees F (0.4 degrees C) below normal in Maine to 4.5 degrees F (2.5 degrees C) above normal in West Virginia, making it the state's 13th warmest February since recordkeeping began. With above-normal temperatures in December and February and a near-normal January, the winter season also wrapped up on the warm side of normal for the Northeast. The region's average temperature of 26.9 degrees F (-2.8 degrees C) was 1.0 degree F (0.6 degrees C) above normal. All but two states were warmer than normal for the season, with average temperature departures ranging from 0.5 degrees F (0.3 degrees C) below normal in Maine to 2.8 degrees F (1.6 degrees C) above normal in West Virginia, the state's 15th warmest winter on record.

For the ninth consecutive month, the Northeast was wetter than normal. The region received 3.33 inches (84.58 mm) of precipitation in February, 123 percent of normal. Eight states were wetter than normal, with precipitation for all states ranging from 92 percent of normal in Connecticut to 178 percent of normal in West Virginia, the state's seventh wettest February. All three winter months (December, January, and February) featured above-normal precipitation for the Northeast.

⁶⁰ NOAA National Centers for Environmental Information, State of the Climate: National Climate Report for February 2019, published online March 2019, retrieved on November 3, 2019 from <https://www.ncdc.noaa.gov/sotc/national/201902>.

With that, the region had its 11th wettest winter since 1895, receiving 11.91 inches (302.51 mm) of precipitation, 129 percent of normal. All states experienced a wetter-than-normal winter, with seven ranking this winter among their 20 wettest on record: West Virginia, sixth wettest; Pennsylvania, 10th wettest; Vermont, 12th wettest; New Jersey, 13th wettest; Rhode Island, 15th wettest; Maryland, 18th wettest; and Connecticut, 20th wettest. Precipitation ranged from 114% of normal in Massachusetts to 146% of normal in West Virginia.

February kicked off with the coldest air of the winter season entrenched in the region. High temperatures were as much as 30 degrees F (17 degrees C) colder than normal, and low temperatures were subzero or in the single digits (degrees F) for most areas. Strong winds created dangerously low wind chills, causing some schools to close. A sudden and dramatic warm up occurred a few days later. From February 3rd to 8th, temperatures up to 75 degrees F (24 degrees C) set daily high temperature records at several major climate sites. Snow melt, rain, and ice jams caused flooding in western Pennsylvania and parts of New York. A winter storm brought a messy mix of precipitation to the Northeast from February 11th to 13th. The greatest precipitation totals included up to 12 inches (30 cm) of snow in northern New England, up to 0.50 inches (13 mm) of ice accretion in parts of Maryland and eastern West Virginia, and up to 1.60 inches (40.64 mm) of rain in western Pennsylvania and northern West Virginia. Strong winds accompanied the storm. Travel was difficult in some areas, with numerous crashes and cancelled flights. Ice accumulation led to several roads being closed in New Jersey and downed tree branches in Maryland. Power outages were also reported. On February 20th, a winter storm brought a mix of snow, sleet, freezing rain, and rain to southern and eastern parts of the region.

The greatest accumulations were up to 10 inches (25 cm) of snow in south-central Pennsylvania and western Maryland and up to 0.25 inches (0.64 cm) of ice in the eastern half of Pennsylvania, northern New Jersey, and southeastern New York. Lightning and thunder were reported in parts of western Maryland and the Eastern Panhandle of West Virginia. Impacts from the storm included difficult travel conditions, thousands of power outages, and schools and government offices being closed. On February 24th and 25th, wind gusts of up to 88 mph (39 m/s) caused damage across the Northeast.

The National Weather Service noted that the Pittsburgh International Airport in Pennsylvania had a wind gust of 61 mph (27 m/s), which was the site's highest non-thunderstorm-related wind gust since the airport was built in 1952. Numerous trees, branches, and wires were downed, leading to road closures and more than 450,000 power outages across the region. Roofs, shingles, and siding were blown off buildings, and poles and signs were knocked down. In some areas, schools were closed. Significant blowing and drifting of snow, with some drifts as high as 10 feet (3 m), made numerous roads impassable in northern Maine. Near Buffalo, New York, lake ice was shoved on shore close to several houses, leading to voluntary evacuations. Lake ice also breached the ice boom at the mouth of the Niagara River, allowing ice to flow down the river and causing some ice jam flooding. Wind-whipped waves contributed to some flooding along Lake Ontario's shoreline. In addition, lake-effect snow and strong winds created blizzard conditions east of Lake Ontario.

March ⁶¹

March was a colder-than-normal month in the Northeast. The region's average temperature of 32.6 degrees F (0.3 degrees C) was 1.9 degrees F (1.1 degrees C) below normal. All twelve states were colder than normal, with departures ranging from 2.6 degrees F (1.4 degrees C) below normal in Vermont to 1.1 degrees F (0.6 degrees C) below normal in New Jersey.

After nine consecutive wetter-than-normal months (June 2018 through February 2019), the Northeast averaged out to be drier than normal. The region's 2.48 inches (63.0 mm) of precipitation was 7% of normal. Eleven states received below-normal precipitation, with departures for those states ranging from 46% of normal in New Hampshire to 95% of normal in New Jersey. Four states ranked this March among their 20 driest on record, with New Hampshire its 13th driest, New York and Vermont having their 17th driest, and West Virginia having its 19th driest. Maryland was a tad wet at 104 percent of normal.

A storm moved up the East Coast from March 3rd to 4th, bringing snow to much of the Northeast. The greatest snow totals of over 12 inches (30 cm) were found mainly in northern New Jersey, southeastern New York, and southern New England. Another storm moved up the coast from March 21st to 23rd, bringing a mix of precipitation types to the region. Some areas, particularly higher elevations, received snow, with the greatest totals of up to 26 inches (66 cm) in Vermont. Other areas received heavy rain, with the greatest totals of up to 3.90 inches (99.1 mm) in southern Pennsylvania and Maryland. Dulles Airport, Virginia, received 2.69 inches (68.3 mm) of rain on March 21st, making it the site's wettest March day on record (since 1960). The previous record was 2.30 inches (58.4 mm) on March 6, 2011. Parts of southern Pennsylvania and Maryland experienced flooding from the heavy rain, with some closed roads and stranded vehicles. In addition, coastal flooding closed several roads in New Jersey.

⁶¹ NOAA National Centers for Environmental Information, State of the Climate: National Climate Report for March 2019, published online April 2019, retrieved on November 3, 2019 from <https://www.ncdc.noaa.gov/sotc/national/201903> .