

1 Q. **Reference: *Engineering Support Services for: Avalon Capacity Study*, TransGrid Solutions, May**  
2 **23, 2019, Section 1.1 – Conclusions.**

3 Please provide (i) the capacity limit of the 230 kV transmission corridor between Bay d’Espoir  
4 and Soldiers Pond under normal operation of Hydro’s transmission planning criteria, and (ii) the  
5 equivalent amount of load served by the 230 kV transmission corridor between Bay d’Espoir and  
6 Soldiers Pond at this capacity limit.

7

8

9 A. If normal transmission planning criteria were applied in the event of a Labrador-Island Link  
10 bipole outage, the capacity limit of the 230 kV transmission corridor between Bay d’Espoir and  
11 Soldiers Pond would be as per Table 4-3 in the study report. Under this scenario, maximum  
12 power flow eastward from Bay d’Espoir would be limited to approximately 673 MW. This  
13 limiting condition is due to transient undervoltages in the event of a three-phase fault at  
14 Sunnyside Terminal Station and reflects the most onerous restriction on the transmission  
15 system in this case.<sup>1</sup>

16 The equivalent amount of load served by the 230 kV transmission corridor between Bay d’Espoir  
17 and Soldiers Pond at this capacity limit is approximately 828 MW. It is noted that this load is  
18 supported by a combination of capacity from the 230 kV transmission corridor between Bay  
19 d’Espoir and Soldiers Pond as well as generation in the eastern portion of the Island  
20 Interconnected System. Equivalent Island load is 1,265 MW, assuming load curtailment at  
21 Corner Brook Pulp and Paper Limited is in effect.

---

<sup>1</sup> Three-phase faults at Bay d’Espoir are not considered as part of Transmission Planning Criteria.