

1 **Q. Reference: Schedule 1, Section 2**

2 What is the source of the non-firm transmission capacity identified in Table 1? Why was it not
3 identified earlier?

4

5

6 A. As explained in Section 2.1 of Schedule 1¹ and Section 3.1 of Schedule 1, Attachment 1,² the
7 projected non-firm capacity identified in Table 1 reflects that 100% of firm load is not being used
8 in all hours of the year. The non-firm capacity amounts indicated are expected to be available
9 most of the time but the analysis assumes non-firm customers would be subject to frequent
10 interruptions in each season as firm load requirements increase.

¹ "Application for a Non-Firm Rate for Labrador," Newfoundland and Labrador Hydro, September 15, 2022, sch. 1, sec. 2.1, p. 3.

² "Application for a Non-Firm Rate for Labrador," Newfoundland and Labrador Hydro, September 15, 2022, sch. 1, att. 1, sec. 3.1, p. 5 of 24.