

1 Q. Does BlockLab currently meet the requirements for connection that are proposed in the Revised
2 Application?

3

4

5 A. In general, BlockLAB¹ meets the requirements to be served by the proposed non-firm rate in
6 Labrador West. However, additional infrastructure may be required depending upon whether
7 BlockLAB is requesting to increase its load requirements under the non-firm rate.

8 At this time, BlockLAB has no infrastructure in place to receive non-firm service in Labrador East.
9 Studies are still required to determine system impacts and interconnection requirements. Please
10 refer to Newfoundland and Labrador Hydro's response to PUB-NLH-002 of this proceeding for
11 more information.

¹ Blockchain Labrador Corporation ("BlockLAB").