

1 Q. **Reference: Application, Schedule 1: Upgrade Report – Penstock 1 Life Extension – Bay**  
2 **d'Espoir, Page 18, Table 5.**

3 Is the capital risk assessment for Option 3 summarized in Table 5 only for the 17-foot diameter  
4 section of Penstock 1, or does it also include the capital risk assessment for the 13.5-foot and  
5 15-foot diameter sections of penstock? If the 13.5-foot and 15-foot diameter sections of  
6 penstock are included, please explain how the weld refurbishment and recoating reduces the  
7 likelihood of post-execution failure to the extent indicated.

8

9

10 A. The full length of Penstock 1 is included in the risk assessment. The weld refurbishment and  
11 protective coating application to the 13.5- and 15-foot diameter sections are necessary to  
12 ensure reliable operation and extend the life of the penstock. As these sections of the penstock  
13 have never experienced a rupture, their inclusion does not figure prominently in the reduction  
14 of the “Likelihood” from a 4 to a 1. This reduction in probability is predominantly driven by the  
15 replacement of the repeatedly failed 17-foot diameter section.