

1 Q. Please confirm whether the reliability criteria provided in the November 15, 2023 Near-Term
2 Reliability Report are based on available capacity assistance from Corner Brook Pulp and Paper
3 of 105 MW or 90 MW.

4

5

6 A. Newfoundland and Labrador Hydro's "2023 Near-Term Reliability Report – November Report"¹
7 modelled 90 MW of Corner Brook Pulp and Paper Limited's capacity assistance.

¹"Reliability and Resource Adequacy Study Review – 2023 Near-Term Reliability Report – November Report," Newfoundland and Labrador Hydro, November 15, 2023.