

1 Q. **Reference: Program 3 - Terminal Station Renewal Program (2023-2024)**

2 Hydro states on page 14, lines 24-26, that it is recommending the installation of an online oil
3 dehydrator to address an issue with excessive moisture content within a transformer located at
4 the Wabush Terminal Station.

5 a) Is this oil dehydrator a permanent or temporary installation?

6 b) If temporary can it be reused on another transformer should the need arise?

7

8

9 A. a) This oil dehydrator installation is intended to be a permanent installation.

10 b) While it is intended as a permanent installation, it can be removed and redeployed to
11 another transformer and this may occur if the oil dehydrator is eventually no longer needed
12 on Wabush Terminal Station Transformer T12.