

1 Q. Please confirm that Unit 2065 is a 320 kW, 1800 rpm diesel genset that was installed in 2002.

2

3

4 A. Newfoundland and Labrador Hydro confirms that Unit 2065 is a 320 kW, 1,800 rpm diesel
5 genset that was installed in 2002.¹

¹ Page 1 of Schedule 1 to the application contained an error in noting that the genset was installed in 2022.