

1 Q. **Reference: Application, Schedule 3 - Holyrood Thermal Generating Station Overview**

2 Is Holyrood expected to be fully available for the winter of 2024/25?

3

4

5 A. Newfoundland and Labrador Hydro (“Hydro”) currently expects the three units at the Holyrood  
6 Thermal Generating Station to be available for the majority of the 2024–2025 winter season.  
7 Units 2 and 3 are expected to be fully available; however, the ongoing 2024 project to refurbish  
8 the Unit 1 steam turbine rotor has been extended for approximately two months due to  
9 unexpected findings. The unit is currently scheduled to return to service in mid-December 2024.  
10 As such, a minor impact on the winter readiness season for 2024–2025 can be expected, and  
11 further delays beyond the middle of December are possible. To date, the work is tracking on  
12 schedule for mid-December, and Hydro is working with the vendor to minimize or eliminate this  
13 winter impact.