

1 Q. **Reference: Application, Schedule 3, Holyrood Thermal Generating Station Overview.**

2 In the 2024 CBA, it was stated (Schedule 3 relating to Holyrood TGS, page 11) *“There will be one*
3 *Holyrood TGS unit online in mid-October through November; two Holyrood TGS units online from*
4 *December to February; and one unit online in March.”* Has this operating pattern changed?

5

6

7 A. The operating schedule of the Holyrood Thermal Generating Station (“Holyrood TGS”) is an
8 assumption used for planning purposes, provided the Labrador-Island Link remains available and
9 operating with a minimum capacity of 700 MW.

10 Annually, as part of winter readiness activities, the status of the system is reviewed and the
11 startup time for each unit at the Holyrood TGS is scheduled to meet the anticipated system
12 requirements at that time. Similarly, towards the end of the winter season, the timing of placing
13 each unit at the Holyrood TGS in standby is assessed and units are removed from service as
14 system conditions allow.