

- 1 **Q. Reference: “2022/2023 General Rate Application,” Newfoundland Power, May 27,**  
 2 **2021, Volume 1, Section 3**  
 3  
 4 **Please provide native peak demand of Newfoundland Power’s customers for the**  
 5 **period 2012 to 2020 and forecast for 2021, 2022, and 2023.**  
 6  
 7 **A. Table 1 provides the requested data.<sup>1</sup>**

**Table 1:  
Native Peak Demand<sup>2</sup>  
2012 to 2023 Forecast**

Year	Actual Peak Demand (MW)	Weather Normalized Peak Demand (MW)
2012	1,281.0	1,350.5
2013	1,398.5	1,343.3
2014	1,358.7	1,382.2
2015	1,367.0	1,381.2
2016	1,422.9	1,445.9
2017	1,362.0	1,384.9
2018	1,458.0	1,439.8
2019	1,355.7	1,367.3
2020	1,251.1	1,299.8
2021F	-	1,350.8
2022F	-	1,350.3
2023F	-	1,341.4

---

<sup>1</sup> Forecast for 2021 to 2023 as proposed in the *2022/2023 General Rate Application*. See *Volume 2, Tab 3, Customer Energy and Demand Forecast, Appendix C*, page 1 of 1.

<sup>2</sup> Native peak is the maximum demand served by Newfoundland Power. The year presented is based on the start of the winter period. For example, the 2012 native peak reflects the winter period of December 2012 to March 2013.