

1 **Rules and Regulations**

2

3 **Q. (Rules and Regulations, para. 5(g)) It is stated “Any Customer having a connected**

4 **load or a normal operating demand of more than 25 kilowatts, in areas served by**

5 **underground wiring or where space limitations or aesthetic reasons make it**

6 **impractical to use a pole mounted transformer bank or pad transformer, shall, on**

7 **request of the Company, provide at its expense a suitable vault or enclosure on the**

8 **Serviced Premises for exclusive use by the Company for its equipment necessary to**

9 **supply and maintain service to the Customer.” Please file all documentation and**

10 **invoices between Newfoundland Power and Memorial University relating to the**

11 **installation of vaults or enclosures, and any additional equipment, at the MUN and**

12 **Long Pond Substations for Newfoundland Power’s equipment used to supply and**

13 **maintain service to Memorial University.**

14

15 **A.** Newfoundland Power does not require access to any vaults or enclosures at Memorial

16 University. Newfoundland Power provides service to Memorial University’s St. John’s

17 campus from the Memorial (“MUN”) and Long Pond (“LPD”) Substations. Memorial

18 University provides the Company with sufficient space within the MUN and LPD

19 Substations for Newfoundland Power to operate and maintain its equipment.¹

¹ See the response to Request for Information CA-NP-124 for additional information.