

- 1 **Q. (Reference CA-NP-129) Are there any distribution facilities owned by**  
2 **Newfoundland Power between MUN-T1/MUN-T2 and the point of supply at**  
3 **Memorial Substation?**  
4
- 5 A. Yes, the secondary side of the 66 kV to 12.5 kV MUN-T1 and MUN-T2 transformers  
6 supplying Memorial University connect to Newfoundland Power 12.5 kV breakers before  
7 connecting to Memorial University’s distribution system at Memorial (“MUN”)  
8 Substation.