

1 **Q. (Reference CA-NP-165) Please reconcile the following. Newfoundland Power is**
2 **asked to confirm that “*The MUN Substation serves 1 customer (Memorial***
3 ***University’s St. John’s campus) via two transformers, MUN-T1 and MUN-T2. There***
4 ***are two transmission lines supplying the MUN substation, 12L and 14L.” The***
5 **response states “*It is not confirmed.*” However, the response appears to confirm that**
6 **the MUN Substation does indeed serve only one customer, Memorial University’s**
7 **St. John’s campus (Table 1), and that lines 12L and 14L supply the MUN**
8 **Substation.**

9
10 A. Memorial (“MUN”) Substation provides service to Memorial University. MUN
11 Substation also forms part of the integrated 66 kV transmission system serving customers
12 in the St. John’s area. This was clearly stated in the response to Request for Information
13 CA-NP-165.

14
15 The role of MUN Substation as a part of the integrated 66 kV transmission system
16 serving customers in the St. John’s area was considered by the Board as part of
17 Newfoundland Power’s *2024 Capital Budget Application*. In its order approving
18 expenditures at MUN Substation, the Board stated:

19
20 *“The Memorial Substation serves buildings on the MUN campus and the Health*
21 *Sciences Centre. It is an integral part of the looped 66 kV transmission network*
22 *which supplies approximately 103,000 customers in St. John’s and surrounding*
23 *areas.”¹*

¹ See Order No. P.U. 2 (2024), Reasons for Decision, page 12, lines 19-21.