

- 1 **Q.** (Reference report 2.2, Appendices A to D; CA-NP-044(d)-(h); NLH-NP-003;
2 **NLH-NP-012; PUB-NP-002) Spare transformers may serve LAU-T1, HAR-T1**
3 **and RRD-T3 temporarily; LBK-T1 would rely on portable P1.**
- 4 **a) For each unit, file the analysis comparing monitoring, repair,**
5 **replacement, a spare and a portable. Provide cost, outage, expected**
6 **life, and NPV, or identify the evidence used where no quantitative**
7 **comparison exists.**
- 8 **b) Explain why an emergency arrangement acceptable for HAR-T1 cannot**
9 **bridge LBK-T1 to a later date, addressing technical limits, duration,**
10 **opportunity cost and reliability.**
- 11 **c) For an LBK-T1 failure before replacement, quantify cases where P1 is:**
12 **(i) available throughout; (ii) later released; and (iii) unavailable. Show**
13 **duration, outage days, lost MWh, replacement cost and customer**
14 **interruption.**
- 15
- 16 **A.** a) See Newfoundland Power's *2027 Capital Budget Application*, report 2.2
17 *Substation Power Transformer Strategy*. The requested information is contained
18 in section 4.0 of each of Appendices A, B, C, and D, where Newfoundland Power
19 identifies and assesses viable alternatives to address the deteriorating condition
20 of the above-referenced transformers.
- 21
- 22 b) LBK-T1 and HAR-T1 are not interchangeable units. They have different
23 applications requiring them to operate at different voltages and have different
24 low voltage winding configurations. The specifications of HAR-T1 are such that it
25 can be backed up by portable substations P3, P4 and P5, as well as spare power
26 transformers 200220 and 200385. LBK-T1 is capable of being backed up by
27 portable substation P1 only. The availability of emergency response resources for
28 HAR-T1 does not affect the need to replace LBK-T1 because the transformers
29 serve two completely separate functions and present different operational risks.
- 30
- 31 c) Newfoundland Power has not completed the analysis requested. To complete the
32 requested analysis, Newfoundland Power would need to make numerous
33 assumptions regarding the timing and nature of a hypothetical LBK-T1 failure,
34 the availability and duration of deployment of portable substation P1,
35 hydrological conditions, generation requirements at the Lookout Brook Hydro
36 Plant, repair requirements, and power transformer procurement and installation
37 timelines at the time of the failure.
- 38
- 39 Given the number of assumptions required, the results of such an analysis would
40 be highly speculative. Newfoundland Power's evaluation of the LBK-T1
41 replacement is based on the transformer's condition assessment, operating
42 requirements, consequences of failure, assessment of viable alternatives, and the
43 availability of emergency response resources, as described in the *Substation*
44 *Power Transformer Strategy*.