

Q. Reference: "2027 Capital Budget Application," Newfoundland Power Inc., May 29, 2026, Supporting Materials, Distribution: 1.1, Distribution Reliability Initiative, pp. 8-14.

Newfoundland Power states that the 2027 Distribution Reliability Initiative targets two deteriorated off-road sections of distribution feeder GLV-02, and that the likely causes of poor reliability performance are: (i) deteriorated conductor; (ii) danger tree contacts; (iii) deteriorated poles, crossarms and insulators; and (iv) inaccessibility of line.

- a) For each of the two affected sections of distribution feeder GLV-02, please provide a breakdown of all outages over the last 10 years by cause, including vegetation, conductor failure, pole/crossarm/insulator failure, wildlife, weather, lightning, planned outages, unknown/other, and any other outage cause categories tracked by Newfoundland Power.**
- b) For each outage identified in part (a), please provide the date, cause, duration, number of customers interrupted, customer minutes of interruption, and whether the outage was attributable primarily to vegetation, asset condition, access constraints, or another cause.**

A. a) As stated on page 2 of the referenced report, Newfoundland Power's Outage Management System ("OMS") was implemented in 2019, with complete year-end data first available in 2020. As a result, granular outage data on specific sections of distribution feeders is unavailable for years prior to 2020.

Table 1 provides a breakdown of outages experienced by customers along and downstream of the two sections of distribution feeder GLV-02 targeted in the proposed 2027 *Distribution Reliability Initiative*, as of June 2026.

Table 1 GLV-02 Outage Statistics by Section (2020-2026)		
Cause	5 km Section	12 km Section
Danger Trees	48%	84%
Unknown/Other	30%	6%
Equipment Failure	11%	10%
Freezing Rain	5%	-
Emergency Repairs	6%	-

1 Table 1 illustrates that the majority of outages have been related to danger tree
2 contacts, which is reflective of restrictive vegetation management capabilities
3 within the boundary of the Terra Nova National Park. These outage causes
4 further illustrate the need to rebuild and relocate these sections into road-side
5 corridors.
6

7 With respect to specific equipment failures, see the response to part b).
8

- 9 b) Newfoundland Power's OMS provides summary statistics on individual sections of
10 distribution feeders, including SAIDI and SAIFI metrics, as well as a breakdown
11 of outage causes as provided in Table 1 in the response to part a). However,
12 descriptive outage data for each individual outage is not available for specific
13 sections of line. Complete outage data for distribution feeder GLV-02 is provided
14 in Attachment A. Of the 570 outage incidents that have occurred over the 2020
15 to 2026 period, as of June 2026, 82 have been to customers along or
16 downstream of the 12-kilometre section of line, and 408 have been to customers
17 along or downstream of the 5-kilometre section of line.
18

19 Furthermore, Newfoundland Power is required to file *Power Outage and Incident*
20 *Advisory* reports to the Board when outage incidents exceed 300,000 customer
21 outage minutes. Since 2017, the Company has filed 11 of these reports for
22 distribution feeder GLV-02, which is more than any other distribution feeder in
23 the Company's service territory. See the response to Request for Information
24 CA-NP-027 for more information.



ATTACHMENT A:

Historical GLV-02 Outage Data

Table 1 shows historical outages on GLV-02 for the 2020 to 2026 period.

Table 1 Historical Outages on GLV-02 (2020 – 2026)									
Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
118190	1	1/6/2020 1:12:30 PM	1/6/2020 2:06:00 PM	53.5	53.5	Unplanned	Equipment Failure	Connecting Devices	Compression Connector
119905	1	1/17/2020 11:33:39 PM	1/18/2020 12:17:23 PM	763.75	763.75	Unplanned	Falling Tree	Conductors	Primary Conductor
119905	6	1/17/2020 11:39:42 PM	1/18/2020 12:17:23 PM	757.68	4546.08	Unplanned	Falling Tree	Conductors	Primary Conductor
119905	1	1/17/2020 11:41:41 PM	1/18/2020 12:17:23 PM	755.7	755.7	Unplanned	Falling Tree	Conductors	Primary Conductor
119905	1	1/17/2020 11:42:22 PM	1/18/2020 12:17:23 PM	755.03	755.03	Unplanned	Falling Tree	Conductors	Primary Conductor
119905	105	1/17/2020 11:49:26 PM	1/18/2020 12:17:23 PM	747.95	78534.75	Unplanned	Falling Tree	Conductors	Primary Conductor
122809	1	1/20/2020 7:39:26 AM	1/20/2020 9:00:00 AM	80.57	80.57	Unplanned	Extreme Wind	Uncategorized	Unknown
122809	1	1/20/2020 9:09:27 AM	1/20/2020 10:05:23 AM	55.93	55.93	Unplanned	Extreme Wind	Uncategorized	Unknown
122931	465	1/20/2020 11:23:27 AM	1/20/2020 12:33:38 PM	70.18	32633.7	Unplanned	Freezing Rain	Uncategorized	Unknown
122931	146	1/20/2020 12:33:38 PM	1/20/2020 3:09:39 PM	156.02	22778.92	Unplanned	Freezing Rain	Uncategorized	Unknown
122931	910	1/20/2020 2:22:03 PM	1/20/2020 3:11:30 PM	49.45	44999.5	Unplanned	Freezing Rain	Uncategorized	Unknown
122931	1516	1/20/2020 3:11:03 PM	1/20/2020 3:12:15 PM	1.22	1849.52	Unplanned	Freezing Rain	Uncategorized	Unknown
135946	1	1/20/2020 3:22:28 PM	1/20/2020 4:32:00 PM	69.53	69.53	Unplanned	Salt Spray/Contamination	Uncategorized	Unknown
136606	611	1/23/2020 11:29:36 AM	1/23/2020 1:13:18 PM	103.7	63360.7	Unplanned	Electrical Failure	Conductors	Primary Conductor
136606	910	1/23/2020 1:08:24 PM	1/23/2020 2:19:11 PM	70.78	64409.8	Unplanned	Electrical Failure	Conductors	Primary Conductor

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
136606	1516	1/23/2020 2:18:25 PM	1/23/2020 2:19:41 PM	1.28	1940.48	Unplanned	Electrical Failure	Conductors	Primary Conductor
136639	1	1/23/2020 3:05:24 PM	1/23/2020 3:15:07 PM	9.72	9.72	Unplanned	Unknown	Uncategorized	No Trouble Found
137156	1	2/2/2020 8:25:20 AM	2/2/2020 9:48:00 AM	82.67	82.67	Unplanned	Salt Spray/Contamination	Uncategorized	Unknown
137279	142	2/3/2020 12:27:27 PM	2/3/2020 2:25:50 PM	118.38	16809.96	Unplanned	Falling Tree	Conductors	Primary Conductor
137492	7	2/6/2020 10:43:35 AM	2/6/2020 11:20:59 AM	37.4	261.8	Unplanned	Extreme Wind	Support Structure	Pole
138846	1	2/24/2020 12:22:43 PM	2/24/2020 12:47:25 PM	24.7	24.7	Unplanned	Unknown	Uncategorized	Unknown
138848	1	2/24/2020 12:24:49 PM	2/24/2020 12:46:48 PM	21.98	21.98	Unplanned	Unknown	Uncategorized	Unknown
138849	1	2/24/2020 12:24:53 PM	2/24/2020 12:46:23 PM	21.52	21.52	Unplanned	Unknown	Uncategorized	Unknown
138847	1516	2/24/2020 12:25:06 PM	2/24/2020 12:32:31 PM	7.42	11248.72	Unplanned	Unknown	Uncategorized	Unknown
138850	1	2/24/2020 12:25:36 PM	2/24/2020 12:46:01 PM	20.43	20.43	Unplanned	Unknown	Uncategorized	Unknown
141633	1	3/31/2020 4:28:59 PM	3/31/2020 7:58:00 PM	209.02	209.02	Unplanned	Electrical Failure	Protection Equipment	Fuse
142165	1	4/13/2020 11:34:17 AM	4/13/2020 2:09:00 PM	154.72	154.72	Unplanned	Corrosion	Uncategorized	Unknown
142664	1	4/20/2020 8:20:56 AM	4/20/2020 9:21:12 AM	60.27	60.27	Unplanned	Wildlife (Bird/Animal)	Transformer Equipment	Polemount Transformer
142900	1	4/22/2020 7:09:38 PM	4/22/2020 9:14:00 PM	124.37	124.37	Unplanned	Electrical Failure	Uncategorized	Unknown
142919	1	4/23/2020 5:44:57 AM	4/23/2020 7:20:00 AM	95.07	95.07	Unplanned	Electrical Failure	Protection Equipment	Fuse
143006	1	4/23/2020 2:55:51 PM	4/23/2020 5:39:34 PM	163.72	163.72	Unplanned	Equipment Failure	Line Hardware	Suspension Insulator
143006	6	4/23/2020 5:10:07 PM	4/23/2020 5:39:34 PM	29.47	176.82	Unplanned	Equipment Failure	Line Hardware	Suspension Insulator

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
143377	11	5/1/2020 10:57:29 AM	5/1/2020 11:32:55 AM	35.45	389.95	Unplanned	Tree Growth/Untrimmed Tree	Conductors	Primary Conductor
143429	1	5/2/2020 12:03:59 PM	5/2/2020 3:05:00 PM	181.03	181.03	Unplanned	Improper Spacing/Sag	Uncategorized	Unknown
143452	9	5/3/2020 6:26:52 PM	5/3/2020 9:44:54 PM	198.03	1782.27	Unplanned	Electrical Failure	Uncategorized	Unknown
145323	3	6/8/2020 7:52:41 AM	6/8/2020 1:41:00 PM	348.32	1044.96	Unplanned	Equipment Failure	Transformer Equipment	Polemount Transformer
146395	11	6/29/2020 12:00:54 PM	6/29/2020 1:22:39 PM	81.75	899.25	Unplanned	Wildlife (Bird/Animal)	Uncategorized	Unknown
146416	1	6/29/2020 3:54:29 PM	6/29/2020 5:30:00 PM	95.52	95.52	Unplanned	Wildlife (Bird/Animal)	Uncategorized	Unknown
147039	1	7/15/2020 5:03:05 AM	7/15/2020 8:36:00 AM	212.93	212.93	Unplanned	Equipment Failure	Protection Equipment	Fuse
147039	12	7/15/2020 7:37:10 AM	7/15/2020 8:36:00 AM	58.85	706.2	Unplanned	Equipment Failure	Protection Equipment	Fuse
147101	13	7/16/2020 8:06:54 AM	7/16/2020 11:53:34 AM	226.68	2946.84	Unplanned	Equipment Failure	Transformer Equipment	Polemount Transformer
147927	1	7/26/2020 1:51:57 AM	7/26/2020 8:17:00 AM	385.07	385.07	Unplanned	Equipment Failure	Protection Equipment	Fuse
148000	3	7/27/2020 10:54:58 AM	7/27/2020 1:20:08 PM	145.17	435.51	Unplanned	Equipment Failure	Transformer Equipment	Polemount Transformer
148612	29	8/7/2020 7:44:17 AM	8/7/2020 9:25:00 AM	100.72	2920.88	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
150311	8	9/8/2020 8:45:55 AM	9/8/2020 9:37:07 AM	51.22	409.76	Planned	Planned Outage	Uncategorized	Unknown
150793	1	9/17/2020 12:05:16 PM	9/17/2020 1:08:00 PM	62.75	62.75	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
150930	7	9/21/2020 10:03:42 AM	9/21/2020 11:08:09 AM	64.45	451.15	Unplanned	Equipment Failure	Uncategorized	Unknown
151447	113	10/1/2020 1:24:30 PM	10/1/2020 5:37:53 PM	253.4	28634.2	Unplanned	Emergency Repairs	Line Hardware	Pin Insulator
152287	3	10/20/2020 10:15:00 AM	10/20/2020 11:05:00 AM	50	150	Planned	Maintenance Work	Transformer Equipment	Polemount Transformer

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
153425	66	11/4/2020 4:07:34 AM	11/4/2020 10:15:55 AM	368.35	24311.1	Unplanned	Tree Contacts	Protection Equipment	Fuse
153549	199	11/4/2020 7:45:38 AM	11/4/2020 8:59:21 AM	73.72	14670.28	Unplanned	Tree Contacts	Conductors	Primary Conductor
153549	200	11/4/2020 8:59:22 AM	11/4/2020 9:16:25 AM	17.07	3414	Unplanned	Tree Contacts	Conductors	Primary Conductor
153549	1060	11/4/2020 9:00:58 AM	11/4/2020 9:45:37 AM	44.65	47329	Unplanned	Tree Contacts	Conductors	Primary Conductor
153549	199	11/4/2020 9:01:21 AM	11/4/2020 9:04:59 AM	3.65	726.35	Unplanned	Tree Contacts	Conductors	Primary Conductor
153549	1	11/4/2020 9:48:43 AM	11/4/2020 11:03:34 AM	74.85	74.85	Unplanned	Tree Contacts	Conductors	Primary Conductor
153549	1056	11/4/2020 9:50:31 AM	11/4/2020 11:03:34 AM	73.05	77140.8	Unplanned	Tree Contacts	Conductors	Primary Conductor
153549	3	11/4/2020 10:59:39 AM	11/4/2020 11:01:47 AM	2.15	6.45	Unplanned	Tree Contacts	Conductors	Primary Conductor
153751	11	11/5/2020 12:13:25 AM	11/5/2020 2:40:00 AM	146.58	1612.38	Unplanned	Tree Contacts	Protection Equipment	Fuse
153831	9	11/5/2020 9:35:45 PM	11/6/2020 1:48:45 AM	253.02	2277.18	Unplanned	Tree Contacts	Uncategorized	Unknown
153831	1	11/6/2020 12:30:32 AM	11/6/2020 1:48:45 AM	78.22	78.22	Unplanned	Tree Contacts	Uncategorized	Unknown
153946	3	11/7/2020 6:34:35 AM	11/7/2020 7:06:59 AM	32.4	97.2	Unplanned	Equipment Failure	Conductors	Primary Conductor
154374	9	11/16/2020 5:13:57 AM	11/16/2020 6:43:44 AM	89.78	808.02	Unplanned	No Trouble Found	Uncategorized	No Trouble Found
154374	37	11/16/2020 5:52:45 AM	11/16/2020 6:43:44 AM	50.98	1886.26	Unplanned	No Trouble Found	Uncategorized	No Trouble Found
154375	1	11/16/2020 6:52:38 AM	11/16/2020 7:49:00 AM	56.37	56.37	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
155729	146	12/8/2020 12:23:18 PM	12/8/2020 4:01:32 PM	218.23	31861.58	Unplanned	Equipment Failure	Protection Equipment	Fuse
157434	1	12/27/2020 1:55:04 AM	12/27/2020 2:23:27 AM	28.38	28.38	Unplanned	Tree Contacts	Conductors	Primary Conductor

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
157443	1	12/28/2020 1:27:13 PM	12/28/2020 1:39:57 PM	12.73	12.73	Unplanned	Equipment Failure	Uncategorized	Unknown
157498	1	12/28/2020 1:37:21 PM	12/28/2020 5:19:00 PM	221.65	221.65	Unplanned	Customer Owned Equipment	Uncategorized	Unknown
158141	1	1/12/2021 3:19:58 PM	1/13/2021 10:56:00 AM	1176.03	1176.03	Unplanned	Tree Contacts	Conductors	Service Wire
158756	1	1/26/2021 3:10:02 PM	1/27/2021 10:05:44 AM	1135.7	1135.7	Unplanned	Tree Contacts	Conductors	Primary Conductor
158837	5	1/28/2021 1:50:00 PM	1/28/2021 2:30:00 PM	40	200	Planned	Maintenance Work	Transformer Equipment	Polemount Transformer
158838	5	1/28/2021 1:55:00 PM	1/28/2021 2:30:00 PM	35.02	175.1	Planned	Maintenance Work	Transformer Equipment	Polemount Transformer
158867	2	1/29/2021 12:59:00 PM	1/29/2021 1:17:00 PM	18	36	Planned	Maintenance Work	Transformer Equipment	Polemount Transformer
158892	7	1/30/2021 5:34:57 PM	1/30/2021 7:44:39 PM	129.7	907.9	Unplanned	Equipment Failure	Protection Equipment	Fuse
159763	3	2/11/2021 10:00:53 AM	2/11/2021 11:06:51 AM	65.97	197.91	Planned	Planned Outage	Uncategorized	No Trouble Found
159805	1	2/11/2021 3:29:56 PM	2/11/2021 4:53:00 PM	83.07	83.07	Unplanned	Equipment Failure	Transformer Equipment	Polemount Transformer
159830	10	2/12/2021 10:48:11 AM	2/12/2021 12:00:10 PM	72	720	Unplanned	Emergency Repairs	Transformer Equipment	Polemount Transformer
160008	6	2/17/2021 10:29:38 AM	2/17/2021 10:48:00 AM	18.38	110.28	Planned	Maintenance Work	Protection Equipment	Cutout
160011	10	2/17/2021 11:00:00 AM	2/17/2021 11:25:00 AM	25	250	Planned	Maintenance Work	Transformer Equipment	Polemount Transformer
160012	7	2/17/2021 11:25:00 AM	2/17/2021 11:55:00 AM	30	210	Planned	Maintenance Work	Transformer Equipment	Polemount Transformer
161170	7	3/16/2021 11:03:00 AM	3/16/2021 12:34:42 PM	91.7	641.9	Planned	Planned Outage	Support Structure	Pole
161229	2	3/17/2021 10:38:59 AM	3/17/2021 11:51:14 AM	72.25	144.5	Planned	Planned Outage	Line Hardware	Suspension Insulator
161539	6	3/22/2021 4:39:49 PM	3/22/2021 9:49:01 PM	309.2	1855.2	Unplanned	Equipment Failure	Transformer Equipment	Polemount Transformer

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
162053	2	3/29/2021 3:26:45 PM	3/29/2021 3:51:39 PM	24.92	49.84	Unplanned	Emergency Repairs	Line Hardware	Deadend Insulator
162310	1	3/31/2021 4:18:51 PM	4/1/2021 2:21:00 PM	1322.15	1322.15	Unplanned	Equipment Failure	Protection Equipment	Lightning Arrestor
162725	1	4/10/2021 12:22:53 PM	4/10/2021 2:16:13 PM	113.33	113.33	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
162725	1	4/10/2021 12:23:05 PM	4/10/2021 2:16:13 PM	113.13	113.13	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
162725	1	4/10/2021 12:35:49 PM	4/10/2021 2:16:13 PM	100.42	100.42	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
162725	26	4/10/2021 12:35:52 PM	4/10/2021 2:16:13 PM	100.35	2609.1	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
163286	1	4/19/2021 9:12:33 AM	4/26/2021 10:32:15 AM	10159.7	10159.7	Unplanned	Customer Owned Equipment	Uncategorized	Unknown
163406	3	4/21/2021 10:24:08 AM	4/21/2021 10:40:54 AM	16.77	50.31	Planned	Planned Outage	Protection Equipment	Cutout
163463	1	4/22/2021 9:27:54 AM	4/22/2021 4:11:00 PM	403.1	403.1	Unplanned	Equipment Failure	Connecting Devices	Compression Connector
164075	1	5/3/2021 2:39:23 PM	5/3/2021 3:26:10 PM	46.78	46.78	Unplanned	Customer Owned Equipment	Underground Distribution Devices	Primary Underground Cable
164251	1	5/7/2021 12:56:44 PM	5/7/2021 2:33:00 PM	96.27	96.27	Unplanned	Equipment Failure	Protection Equipment	Fuse
164950	10	5/25/2021 1:22:45 PM	5/25/2021 1:57:15 PM	34.52	345.2	Unplanned	Equipment Failure	Line Hardware	Post Insulator
165029	146	5/26/2021 5:16:17 PM	5/26/2021 7:42:41 PM	146.4	21374.4	Unplanned	Equipment Failure	Protection Equipment	Fuse
165180	1526	5/30/2021 8:41:16 AM	5/30/2021 8:51:04 AM	9.8	14954.8	Unplanned	Unknown	Uncategorized	Unknown
165333	1527	6/2/2021 4:06:04 PM	6/2/2021 4:14:49 PM	8.75	13361.25	Unplanned	Lightning	Uncategorized	No Trouble Found
165627	75	6/9/2021 6:48:45 AM	6/9/2021 9:24:05 AM	155.33	11649.75	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
166717	2	6/10/2021 10:55:29 AM	6/10/2021 1:16:06 PM	140.62	281.24	Planned	Maintenance Work	Conductors	Primary Conductor

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
166827	66	6/12/2021 7:14:07 AM	6/12/2021 8:46:33 AM	92.43	6100.38	Planned	Maintenance Work	Protection Equipment	Fuse
166865	1	6/13/2021 10:28:54 AM	6/13/2021 11:43:58 AM	75.07	75.07	Unplanned	Equipment Failure	Protection Equipment	Fuse
197506	20	6/24/2021 11:25:52 AM	6/24/2021 12:41:14 PM	75.37	1507.4	Planned	Planned Outage	Conductors	Primary Conductor
203108	146	7/19/2021 5:02:54 AM	7/19/2021 7:02:00 AM	119.1	17388.6	Unplanned	No Trouble Found	Protection Equipment	Fuse
203197	1	7/20/2021 9:31:03 AM	7/30/2021 9:58:57 AM	14427.92	14427.92	Planned	Planned Outage	Underground Distribution Devices	Primary Underground Cable
203824	1522	8/1/2021 4:44:00 PM	8/1/2021 4:50:29 PM	6.5	9893	Unplanned	Unknown	Uncategorized	Unknown
203870	1522	8/1/2021 9:28:25 PM	8/2/2021 12:27:35 AM	179.17	272696.74	Unplanned	Emergency Repairs	Support Structure	Other Support Structure
204439	66	8/9/2021 6:20:59 PM	8/9/2021 8:58:44 PM	157.75	10411.5	Unplanned	Emergency Repairs	Protection Equipment	Fuse
204470	8	8/10/2021 9:14:36 AM	8/10/2021 10:52:49 AM	98.23	785.84	Planned	Planned Outage	Uncategorized	Other Utilities Equipment
205740	6	9/1/2021 9:41:39 AM	9/1/2021 11:17:04 AM	95.42	572.52	Unplanned	Equipment Failure	Protection Equipment	Fuse
205740	1	9/1/2021 11:13:45 AM	9/1/2021 11:17:04 AM	3.32	3.32	Unplanned	Equipment Failure	Protection Equipment	Fuse
205746	4	9/1/2021 11:18:49 AM	9/1/2021 11:58:18 AM	39.48	157.92	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
206066	1	9/8/2021 6:58:29 PM	9/9/2021 12:17:34 AM	319.08	319.08	Unplanned	Customer Owned Equipment	Support Structure	Other Support Structure
210984	1	9/13/2021 1:18:13 PM	9/13/2021 3:37:00 PM	138.78	138.78	Unplanned	Emergency Repairs	Transformer Equipment	Polemount Transformer
213192	11	9/28/2021 11:01:29 AM	9/28/2021 12:28:44 PM	87.27	959.97	Planned	Planned Outage	Conductors	Primary Conductor
213626	1	10/1/2021 10:43:00 AM	10/1/2021 1:09:15 PM	146.25	146.25	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
213571	11	10/3/2021 7:55:11 AM	10/3/2021 10:42:07 AM	166.93	1836.23	Unplanned	Emergency Repairs	Protection Equipment	Fuse
213987	238	10/8/2021 7:48:39 PM	10/8/2021 8:47:07 PM	58.47	13915.86	Unplanned	Emergency Repairs	Conductors	Primary Conductor
214651	1	10/12/2021 2:15:19 PM	10/12/2021 3:30:00 PM	74.68	74.68	Unplanned	Tree Contacts	Conductors	Primary Conductor
215391	1	10/22/2021 1:20:17 PM	12/13/2021 10:15:44 AM	74695.45	74695.45	Planned	Customer Requested Outage	Underground Distribution Devices	Primary Underground Cable
215547	145	10/24/2021 9:42:09 AM	10/24/2021 12:04:52 PM	142.72	20694.4	Unplanned	Equipment Failure	Protection Equipment	Fuse
216098	1517	11/2/2021 10:30:45 AM	11/2/2021 10:36:35 AM	5.83	8844.11	Planned	Switching Order	Transmission Line	124L (CLV - GLV)
216106	1	11/2/2021 11:35:03 AM	11/16/2021 2:02:48 PM	20307.75	20307.75	Planned	Customer Requested Outage	Conductors	Primary Conductor
216233	160	11/5/2021 9:22:00 AM	11/5/2021 11:31:00 AM	129	20640	Planned	Planned Outage	Uncategorized	Unknown
216233	7	11/5/2021 9:22:00 AM	11/5/2021 11:33:00 AM	131	917	Planned	Planned Outage	Uncategorized	Unknown
216990	431	11/19/2021 10:00:51 AM	11/19/2021 10:01:58 AM	1.13	487.03	Planned	Planned Outage	Conductors	Primary Conductor
216989	1086	11/19/2021 10:01:05 AM	11/19/2021 10:58:59 AM	57.9	62879.4	Planned	Planned Outage	Conductors	Primary Conductor
216990	1517	11/19/2021 10:58:42 AM	11/19/2021 11:00:35 AM	1.9	2882.3	Planned	Planned Outage	Conductors	Primary Conductor
217316	1	11/25/2021 10:48:53 AM	11/25/2021 12:38:00 PM	109.12	109.12	Unplanned	Public Overhead Line Contact	Service Metering Equipment	Service Meter
217578	160	11/30/2021 10:18:58 AM	11/30/2021 2:09:03 PM	230.1	36816	Unplanned	Tree Contacts	Conductors	Primary Conductor
217762	1517	12/1/2021 10:53:51 AM	12/1/2021 11:06:51 AM	13	19721	Planned	Switching Order	Switching Devices	Motorized Switch
217775	1517	12/1/2021 12:10:03 PM	12/1/2021 12:17:22 PM	7.33	11119.61	Planned	Switching Order	Switching Devices	Motorized Switch
218730	6	12/9/2021 6:36:43 PM	12/10/2021 1:00:03 AM	383.33	2299.98	Unplanned	Unknown	Uncategorized	Unknown

Requests for Information
NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
218713	1	12/9/2021 6:46:43 PM	12/10/2021 1:00:41 AM	373.97	373.97	Unplanned	Unknown	Uncategorized	Unknown
218715	1	12/9/2021 6:48:27 PM	12/10/2021 1:00:34 AM	372.13	372.13	Unplanned	Unknown	Uncategorized	Unknown
218723	1	12/9/2021 6:54:22 PM	12/10/2021 1:00:54 AM	366.53	366.53	Unplanned	Unknown	Uncategorized	Unknown
218870	1	12/9/2021 8:50:24 PM	12/10/2021 1:00:27 AM	250.05	250.05	Unplanned	Unknown	Uncategorized	Unknown
219494	1516	12/11/2021 11:07:34 AM	12/11/2021 11:26:29 AM	18.93	28697.88	Planned	Planned Outage	Transmission Line	124L (CLV - GLV)
219508	1516	12/11/2021 1:02:16 PM	12/11/2021 1:11:59 PM	9.73	14750.68	Planned	Planned Outage	Transmission Line	124L (CLV - GLV)
221362	1331	1/6/2022 7:05:53 AM	1/6/2022 8:34:09 AM	88.28	117500.68	Unplanned	Equipment Failure	Line Hardware	Post Insulator
221362	187	1/6/2022 7:05:53 AM	1/6/2022 12:55:04 PM	349.2	65300.4	Unplanned	Equipment Failure	Line Hardware	Post Insulator
221362	1331	1/6/2022 9:31:07 AM	1/6/2022 9:32:34 AM	1.47	1956.57	Unplanned	Equipment Failure	Line Hardware	Post Insulator
221698	1330	1/8/2022 4:11:29 PM	1/8/2022 7:15:10 PM	183.68	244294.4	Unplanned	No Trouble Found	Uncategorized	No Trouble Found
221698	187	1/8/2022 4:11:29 PM	1/8/2022 7:33:45 PM	202.27	37824.49	Unplanned	No Trouble Found	Uncategorized	No Trouble Found
221698	2	1/8/2022 4:11:29 PM	1/9/2022 1:16:41 PM	1265.2	2530.4	Unplanned	No Trouble Found	Uncategorized	No Trouble Found
221799	1329	1/8/2022 7:14:37 PM	1/8/2022 7:15:58 PM	1.37	1820.73	Unplanned	Unknown	Uncategorized	Unknown
221808	1	1/8/2022 7:24:12 PM	1/8/2022 9:28:00 PM	123.8	123.8	Unplanned	Equipment Failure	Protection Equipment	Fuse
221818	265	1/8/2022 7:24:12 PM	1/8/2022 9:05:20 PM	101.13	26799.45	Unplanned	Equipment Failure	Protection Equipment	Fuse
221830	1	1/8/2022 8:12:24 PM	1/8/2022 9:32:00 PM	79.6	79.6	Unplanned	Equipment Failure	Uncategorized	Unknown
222256	1	1/14/2022 8:42:09 AM	1/14/2022 11:09:00 AM	146.85	146.85	Unplanned	Equipment Failure	Connecting Devices	Compression Connector

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
222657	160	1/16/2022 2:10:30 AM	1/16/2022 11:32:28 AM	561.97	89915.2	Unplanned	Tree Contacts	Conductors	Primary Conductor
222673	1	1/16/2022 6:52:08 AM	1/16/2022 3:23:00 PM	510.87	510.87	Unplanned	Unknown	Uncategorized	Unknown
222682	1	1/16/2022 7:24:41 AM	1/16/2022 3:32:00 PM	487.32	487.32	Unplanned	Tree Contacts	Conductors	Service Wire
222744	1	1/16/2022 10:05:54 AM	1/16/2022 3:30:00 PM	324.1	324.1	Unplanned	Tree Contacts	Conductors	Service Wire
223300	431	1/18/2022 3:31:14 PM	1/18/2022 4:54:39 PM	83.43	35958.33	Unplanned	Tree Contacts	Conductors	Primary Conductor
223300	1088	1/18/2022 3:31:14 PM	1/18/2022 6:04:13 PM	153	166464	Unplanned	Tree Contacts	Conductors	Primary Conductor
223300	1519	1/18/2022 6:03:57 PM	1/18/2022 6:05:00 PM	1.07	1625.33	Unplanned	Tree Contacts	Conductors	Primary Conductor
223808	1	1/20/2022 11:34:52 AM	1/20/2022 12:06:39 PM	31.78	31.78	Unplanned	Tree Contacts	Conductors	Primary Conductor
223860	1	1/21/2022 10:07:13 AM	1/21/2022 12:57:00 PM	169.78	169.78	Unplanned	Tree Contacts	Conductors	Primary Conductor
224783	1	2/2/2022 9:45:38 AM	2/2/2022 3:01:27 PM	315.83	315.83	Planned	Planned Outage	Underground Distribution Devices	Primary Underground Cable
225692	187	2/10/2022 10:21:59 AM	2/10/2022 11:48:48 AM	86.83	16237.21	Unplanned	No Trouble Found	Conductors	Primary Conductor
225692	268	2/10/2022 10:21:59 AM	2/10/2022 12:03:32 PM	101.57	27220.76	Unplanned	No Trouble Found	Conductors	Primary Conductor
225692	149	2/10/2022 10:21:59 AM	2/10/2022 12:28:50 PM	126.87	18903.63	Unplanned	No Trouble Found	Conductors	Primary Conductor
225692	37	2/10/2022 10:21:59 AM	2/10/2022 1:05:27 PM	163.48	6048.76	Unplanned	No Trouble Found	Conductors	Primary Conductor
225692	880	2/10/2022 10:21:59 AM	2/10/2022 1:11:38 PM	169.67	149309.6	Unplanned	No Trouble Found	Conductors	Primary Conductor
225692	455	2/10/2022 12:03:04 PM	2/10/2022 12:05:35 PM	2.52	1146.6	Unplanned	No Trouble Found	Conductors	Primary Conductor
225696	1	2/10/2022 12:10:22 PM	2/10/2022 2:48:00 PM	157.63	157.63	Unplanned	No Trouble Found	Uncategorized	No Trouble Found

Requests for Information
NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
225692	149	2/10/2022 1:03:47 PM	2/10/2022 1:05:27 PM	1.67	248.83	Unplanned	No Trouble Found	Conductors	Primary Conductor
225692	1066	2/10/2022 1:11:17 PM	2/10/2022 1:12:24 PM	1.13	1204.58	Unplanned	No Trouble Found	Conductors	Primary Conductor
227705	1	2/22/2022 10:18:02 AM	2/22/2022 2:48:00 PM	269.97	269.97	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
229047	208	3/13/2022 8:40:52 AM	3/13/2022 9:59:20 AM	78.48	16323.84	Unplanned	Tree Contacts	Conductors	Primary Conductor
229047	1313	3/13/2022 8:40:52 AM	3/13/2022 10:26:40 AM	105.82	138941.66	Unplanned	Tree Contacts	Conductors	Primary Conductor
229047	1521	3/13/2022 10:25:57 AM	3/13/2022 10:30:39 AM	4.72	7179.12	Unplanned	Tree Contacts	Conductors	Primary Conductor
229047	455	3/13/2022 10:30:40 AM	3/13/2022 10:31:53 AM	1.22	555.1	Unplanned	Tree Contacts	Conductors	Primary Conductor
229047	1066	3/13/2022 10:30:40 AM	3/13/2022 10:45:02 AM	14.37	15318.42	Unplanned	Tree Contacts	Conductors	Primary Conductor
229136	3	3/13/2022 10:45:38 AM	3/13/2022 11:02:45 AM	17.12	51.36	Unplanned	Tree Contacts	Conductors	Primary Conductor
229136	1063	3/13/2022 10:45:38 AM	3/13/2022 6:44:24 PM	478.77	508932.51	Unplanned	Tree Contacts	Conductors	Primary Conductor
229145	1	3/13/2022 10:46:45 AM	3/13/2022 9:35:00 PM	648.27	648.27	Unplanned	No Trouble Found	Uncategorized	No Trouble Found
229047	457	3/13/2022 11:02:45 AM	3/13/2022 11:04:11 AM	1.43	653.51	Unplanned	Tree Contacts	Conductors	Primary Conductor
229136	3	3/13/2022 11:04:33 AM	3/13/2022 6:44:24 PM	459.87	1379.61	Unplanned	Tree Contacts	Conductors	Primary Conductor
229136	1	3/13/2022 1:54:21 PM	3/13/2022 6:46:48 PM	292.45	292.45	Unplanned	Tree Contacts	Conductors	Primary Conductor
230639	116	3/28/2022 12:37:42 PM	3/28/2022 3:27:45 PM	170.05	19725.8	Unplanned	Emergency Repairs	Line Hardware	Suspension Insulator
230717	98	3/29/2022 11:10:03 PM	3/30/2022 2:38:42 AM	208.67	20449.66	Unplanned	Emergency Repairs	Protection Equipment	Fuse
230749	1	3/30/2022 8:12:08 AM	3/30/2022 9:22:08 AM	70	70	Unplanned	Tree Contacts	Transmission Line	102L (RBK - GAN)

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
231903	1	4/21/2022 10:48:37 AM	4/21/2022 1:14:46 PM	146.15	146.15	Unplanned	No Trouble Found	Uncategorized	No Trouble Found
231939	6	4/22/2022 7:17:32 AM	4/22/2022 10:01:59 AM	164.45	986.7	Unplanned	Wildlife (Bird/Animal)	Uncategorized	Unknown
232004	12	4/24/2022 5:41:22 PM	4/24/2022 8:45:07 PM	183.75	2205	Unplanned	Tree Contacts	Conductors	Primary Conductor
232286	7	4/29/2022 10:44:14 AM	4/29/2022 11:26:00 AM	41.77	292.39	Planned	Planned Outage	Conductors	Primary Conductor
232306	1	4/29/2022 4:17:37 PM	4/29/2022 5:03:00 PM	45.38	45.38	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
232531	1521	5/6/2022 7:05:56 AM	5/6/2022 7:12:56 AM	7.02	10677.42	Planned	Switching Order	Transmission Line	124L (CLV - GLV)
232563	1521	5/6/2022 3:22:56 PM	5/6/2022 3:30:40 PM	7.75	11787.75	Planned	Switching Order	Transmission Line	124L (CLV - GLV)
232610	1518	5/9/2022 7:09:57 AM	5/9/2022 7:18:35 AM	8.65	13130.7	Planned	Switching Order	Transmission Line	124L (CLV - GLV)
232859	1	5/13/2022 7:41:20 AM	5/13/2022 8:24:02 AM	42.7	42.7	Unplanned	No Trouble Found	Uncategorized	No Trouble Found
232871	1521	5/13/2022 10:25:05 AM	5/13/2022 10:32:34 AM	7.5	11407.5	Unplanned	Unknown	Uncategorized	Unknown
232873	1	5/13/2022 10:34:05 AM	5/13/2022 10:35:33 AM	1.47	1.47	Unplanned	No Trouble Found	Uncategorized	No Trouble Found
233657	1	6/1/2022 11:49:44 AM	6/1/2022 12:52:00 PM	62.27	62.27	Unplanned	Unknown	Transformer Equipment	Polemount Transformer
233950	1	6/9/2022 9:46:12 AM	6/9/2022 4:01:02 PM	374.83	374.83	Planned	Planned Outage	Underground Distribution Devices	Primary Underground Cable
234851	1	6/28/2022 11:55:55 AM	6/28/2022 2:11:00 PM	135.08	135.08	Unplanned	No Trouble Found	Uncategorized	No Trouble Found
234854	9	6/28/2022 12:12:13 PM	6/28/2022 2:03:26 PM	111.22	1000.98	Unplanned	Unknown	Uncategorized	Unknown
234896	4	6/29/2022 7:20:36 AM	6/29/2022 9:21:45 AM	121.15	484.6	Unplanned	Tree Contacts	Conductors	Primary Conductor
235172	1	7/4/2022 2:02:08 PM	7/4/2022 4:30:00 PM	147.87	147.87	Unplanned	Lightning	Protection Equipment	Recloser (Electronic)

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
235173	1	7/4/2022 2:06:20 PM	7/4/2022 9:05:00 PM	418.67	418.67	Unplanned	Lightning	Transformer Equipment	Polemount Transformer
235663	2	7/14/2022 10:02:00 AM	7/14/2022 1:17:39 PM	195.63	391.26	Planned	Planned Outage	Conductors	Primary Conductor
235978	4	7/19/2022 9:18:17 AM	7/19/2022 10:11:21 AM	53.07	212.28	Planned	Planned Outage	Conductors	Primary Conductor
236067	1	7/20/2022 9:27:06 AM	7/20/2022 11:44:32 AM	137.43	137.43	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
236067	65	7/20/2022 9:33:45 AM	7/20/2022 11:44:32 AM	130.78	8500.7	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
236347	1	7/24/2022 6:15:08 PM	7/24/2022 7:59:00 PM	103.88	103.88	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
236712	1518	7/28/2022 5:08:26 PM	7/28/2022 5:47:31 PM	39.1	59353.8	Planned	Planned Outage	Transmission Line	121L (GLV - GAM)
237093	4	8/5/2022 6:53:06 AM	8/5/2022 8:39:29 AM	106.4	425.6	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
238092	1	8/25/2022 3:45:57 PM	8/25/2022 5:22:52 PM	96.92	96.92	Unplanned	Tree Contacts	Conductors	Primary Conductor
238092	9	8/25/2022 4:44:24 PM	8/25/2022 5:22:52 PM	38.47	346.23	Unplanned	Tree Contacts	Conductors	Primary Conductor
238191	6	8/27/2022 6:26:49 AM	8/27/2022 8:27:12 AM	120.38	722.28	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
238260	1	8/29/2022 6:45:35 AM	8/29/2022 9:13:00 AM	147.42	147.42	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
238745	1	9/6/2022 3:34:59 PM	9/6/2022 5:25:00 PM	110.02	110.02	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
239649	28	9/19/2022 10:26:58 AM	9/19/2022 12:39:52 PM	132.92	3721.76	Unplanned	Wildlife (Bird/Animal)	Switching Devices	Other Switching Devices
244288	51	11/22/2022 11:24:37 AM	11/22/2022 11:36:29 AM	11.87	605.37	Unplanned	Emergency Repairs	Conductors	Primary Conductor
244804	159	11/24/2022 11:03:56 PM	11/25/2022 6:48:30 AM	464.58	73868.22	Unplanned	Tree Contacts	Conductors	Primary Conductor
244804	3	11/25/2022 3:38:03 AM	11/25/2022 6:29:37 AM	171.57	514.71	Unplanned	Tree Contacts	Conductors	Primary Conductor

Requests for Information
NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
245543	5	12/6/2022 11:12:11 AM	12/6/2022 12:10:55 PM	58.73	293.65	Planned	Planned Outage	Conductors	Primary Conductor
246000	1	12/15/2022 9:29:52 AM	12/15/2022 11:10:00 AM	100.13	100.13	Unplanned	Customer Owned Equipment	Uncategorized	Other Utilities Equipment
246050	1	12/15/2022 2:15:35 PM	12/15/2022 5:10:55 PM	175.33	175.33	Unplanned	Tree Contacts	Conductors	Primary Conductor
246050	1	12/15/2022 2:17:24 PM	12/15/2022 5:10:55 PM	173.52	173.52	Unplanned	Tree Contacts	Conductors	Primary Conductor
246050	1	12/15/2022 2:19:12 PM	12/15/2022 5:10:55 PM	171.72	171.72	Unplanned	Tree Contacts	Conductors	Primary Conductor
246050	1	12/15/2022 2:21:13 PM	12/15/2022 5:10:55 PM	169.7	169.7	Unplanned	Tree Contacts	Conductors	Primary Conductor
246050	3	12/15/2022 2:26:22 PM	12/15/2022 5:10:55 PM	164.55	493.65	Unplanned	Tree Contacts	Conductors	Primary Conductor
246050	2	12/15/2022 2:26:48 PM	12/15/2022 5:10:55 PM	164.12	328.24	Unplanned	Tree Contacts	Conductors	Primary Conductor
246050	1	12/15/2022 2:27:18 PM	12/15/2022 5:10:55 PM	163.62	163.62	Unplanned	Tree Contacts	Conductors	Primary Conductor
246050	1	12/15/2022 2:47:02 PM	12/15/2022 5:10:55 PM	143.88	143.88	Unplanned	Tree Contacts	Conductors	Primary Conductor
246050	1	12/15/2022 2:48:39 PM	12/15/2022 5:10:55 PM	142.28	142.28	Unplanned	Tree Contacts	Conductors	Primary Conductor
246050	150	12/15/2022 2:57:09 PM	12/15/2022 5:10:55 PM	133.77	20065.5	Unplanned	Tree Contacts	Conductors	Primary Conductor
246074	1	12/15/2022 6:40:22 PM	12/15/2022 10:38:00 PM	237.63	237.63	Unplanned	Tree Contacts	Uncategorized	Unknown
236712	1525	12/20/2022 9:34:48 PM	12/21/2022 7:26:09 AM	591.33	901778.25	Planned	Planned Outage	Transmission Line	121L (GLV - GAM)
246459	9	12/22/2022 8:27:21 AM	12/22/2022 9:37:55 AM	70.57	635.13	Unplanned	No Trouble Found	Protection Equipment	Fuse
246628	12	12/26/2022 8:16:27 AM	12/26/2022 11:00:13 AM	163.77	1965.24	Unplanned	Emergency Repairs	Transformer Equipment	Polemount Transformer
246628	2	12/26/2022 11:15:25 AM	12/26/2022 2:53:40 PM	218.25	436.5	Unplanned	Emergency Repairs	Transformer Equipment	Polemount Transformer

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
246633	10	12/26/2022 1:11:55 PM	12/26/2022 2:53:23 PM	101.47	1014.7	Unplanned	Emergency Repairs	Transformer Equipment	Polemount Transformer
246774	1	12/30/2022 1:58:03 PM	12/30/2022 8:07:45 PM	369.72	369.72	Unplanned	Transmission Unplanned	Transmission Line	124L (CLV - GLV)
246805	1530	12/30/2022 1:58:03 PM	12/30/2022 8:08:29 PM	370.45	566788.5	Unplanned	Transmission Unplanned	Transmission Line	124L (CLV - GLV)
246805	3	12/30/2022 8:01:28 PM	12/30/2022 8:08:29 PM	7.03	21.09	Unplanned	Transmission Unplanned	Transmission Line	124L (CLV - GLV)
247152	1533	1/8/2023 11:04:15 AM	1/8/2023 11:14:35 AM	10.33	15835.89	Unplanned	Transmission Unplanned	Transmission Line	146L (GAN - GAM)
247661	98	1/16/2023 4:27:41 AM	1/16/2023 9:53:42 AM	326.02	31949.96	Unplanned	Tree Contacts	Conductors	Primary Conductor
247831	456	1/17/2023 1:42:33 AM	1/17/2023 2:12:29 AM	29.95	13657.2	Unplanned	Equipment Failure	Transformer Equipment	Voltage Regulator
247832	3	1/17/2023 1:42:33 AM	1/17/2023 3:43:38 AM	121.1	363.3	Unplanned	Equipment Failure	Transformer Equipment	Voltage Regulator
247832	4	1/17/2023 1:42:33 AM	1/17/2023 6:42:44 AM	300.2	1200.8	Unplanned	Equipment Failure	Transformer Equipment	Voltage Regulator
247832	1070	1/17/2023 1:42:33 AM	1/17/2023 6:42:45 AM	300.2	321214	Unplanned	Equipment Failure	Transformer Equipment	Voltage Regulator
247831	456	1/17/2023 2:13:36 AM	1/17/2023 2:14:43 AM	1.13	515.28	Unplanned	Equipment Failure	Transformer Equipment	Voltage Regulator
247832	3	1/17/2023 3:45:06 AM	1/17/2023 6:42:44 AM	177.63	532.89	Unplanned	Equipment Failure	Transformer Equipment	Voltage Regulator
247831	456	1/17/2023 4:55:26 AM	1/17/2023 4:56:50 AM	1.42	647.52	Unplanned	Equipment Failure	Transformer Equipment	Voltage Regulator
247831	456	1/17/2023 5:46:54 AM	1/17/2023 5:47:56 AM	1.05	478.8	Unplanned	Equipment Failure	Transformer Equipment	Voltage Regulator
248291	1533	1/21/2023 7:22:40 PM	1/21/2023 7:38:13 PM	15.55	23838.15	Unplanned	Unknown	Uncategorized	Unknown
248561	1533	1/21/2023 7:38:27 PM	1/22/2023 1:25:41 AM	347.25	532334.25	Unplanned	Transmission Unplanned	Transmission Line	124L (CLV - GLV)
249391	1	1/25/2023 12:39:46 PM	1/25/2023 2:19:00 PM	99.23	99.23	Unplanned	Equipment Failure	Protection Equipment	Cutout

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
249914	9	1/28/2023 12:18:44 PM	1/28/2023 2:26:05 PM	127.35	1146.15	Unplanned	Equipment Failure	Protection Equipment	Fuse
251993	2	2/25/2023 10:05:02 PM	2/26/2023 12:46:03 AM	161.03	322.06	Unplanned	Emergency Repairs	Conductors	Primary Conductor
251993	7	2/25/2023 10:05:02 PM	2/26/2023 1:22:54 AM	197.88	1385.16	Unplanned	Emergency Repairs	Conductors	Primary Conductor
251993	25	2/25/2023 10:14:04 PM	2/26/2023 12:46:03 AM	152	3800	Unplanned	Emergency Repairs	Conductors	Primary Conductor
252411	1	3/6/2023 8:43:31 AM	3/6/2023 9:24:00 AM	40.48	40.48	Unplanned	No Trouble Found	Uncategorized	Unknown
253640	1	3/24/2023 12:27:03 PM	3/24/2023 1:59:03 PM	92	92	Unplanned	Unknown	Uncategorized	Unknown
254165	1	4/6/2023 7:16:54 AM	4/6/2023 11:17:00 AM	240.1	240.1	Unplanned	Customer Owned Equipment	Service Metering Equipment	Service Meter
254184	1	4/6/2023 12:07:49 PM	4/6/2023 12:28:00 PM	20.18	20.18	Planned	Planned Outage	Transformer Equipment	Polemount Transformer
254185	1	4/6/2023 12:53:57 PM	4/6/2023 1:09:02 PM	15.1	15.1	Planned	Planned Outage	Transformer Equipment	Polemount Transformer
255784	11	5/12/2023 7:35:07 AM	5/12/2023 9:15:05 AM	99.98	1099.78	Unplanned	Equipment Failure	Protection Equipment	Fuse
255814	11	5/12/2023 11:10:26 AM	5/12/2023 12:40:56 PM	90.52	995.72	Unplanned	Equipment Failure	Protection Equipment	Fuse
255814	13	5/12/2023 11:14:59 AM	5/12/2023 12:40:56 PM	85.97	1117.61	Unplanned	Equipment Failure	Protection Equipment	Fuse
255814	1	5/12/2023 11:21:22 AM	5/12/2023 12:40:56 PM	79.57	79.57	Unplanned	Equipment Failure	Protection Equipment	Fuse
255814	11	5/12/2023 12:24:14 PM	5/12/2023 12:40:56 PM	16.72	183.92	Unplanned	Equipment Failure	Protection Equipment	Fuse
255935	1	5/16/2023 11:13:31 AM	5/18/2023 3:30:59 PM	3137.47	3137.47	Planned	Customer Requested Outage	Underground Distribution Devices	Primary Underground Cable
256197	1	5/21/2023 3:28:59 PM	5/21/2023 5:41:00 PM	132.03	132.03	Unplanned	Tree Contacts	Conductors	Primary Conductor
256453	12	5/25/2023 10:38:24 AM	5/25/2023 12:37:18 PM	118.9	1426.8	Planned	Maintenance Work	Conductors	Primary Conductor

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
256464	2	5/25/2023 1:25:52 PM	5/25/2023 2:44:52 PM	79	158	Planned	Planned Outage	Conductors	Primary Conductor
256492	4	5/26/2023 6:01:47 AM	5/26/2023 8:06:55 AM	125.13	500.52	Unplanned	Equipment Failure	Protection Equipment	Fuse
256674	1	5/30/2023 10:17:01 AM	5/30/2023 10:48:00 AM	31	31	Unplanned	Customer Owned Equipment	Uncategorized	No Trouble Found
257354	7	6/15/2023 7:56:36 AM	6/15/2023 11:04:57 AM	188.35	1318.45	Unplanned	Equipment Failure	Protection Equipment	Fuse
257368	1	6/15/2023 1:33:26 PM	6/15/2023 4:07:00 PM	153.58	153.58	Unplanned	Wildlife (Bird/Animal)	Transformer Equipment	Polemount Transformer
258126	1	6/27/2023 2:33:55 PM	6/27/2023 3:58:00 PM	84.08	84.08	Unplanned	Equipment Failure	Protection Equipment	Fuse
258846	1	7/8/2023 12:21:57 PM	7/8/2023 5:21:00 PM	299.05	299.05	Unplanned	Emergency Repairs	Uncategorized	Unknown
258964	1	7/12/2023 9:10:23 AM	7/12/2023 10:10:00 AM	59.62	59.62	Unplanned	Unknown	Connecting Devices	Other Connecting Devices
259113	1	7/15/2023 6:12:16 AM	7/15/2023 8:29:00 AM	136.75	136.75	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
259363	51	7/20/2023 5:23:00 PM	7/20/2023 6:46:32 PM	83.53	4260.03	Unplanned	Emergency Repairs	Protection Equipment	Fuse
259390	1	7/21/2023 11:57:34 AM	7/21/2023 2:54:00 PM	176.43	176.43	Unplanned	Equipment Failure	Protection Equipment	Fuse
259976	66	8/3/2023 7:49:55 AM	8/3/2023 8:36:00 AM	46.08	3041.28	Unplanned	No Trouble Found	Protection Equipment	Fuse
260274	456	8/9/2023 3:31:55 AM	8/9/2023 3:38:46 AM	6.85	3123.6	Unplanned	Unknown	Uncategorized	Unknown
260275	1087	8/9/2023 3:31:55 AM	8/9/2023 6:09:08 AM	157.22	170898.14	Unplanned	Tree Contacts	No Equipment Damaged	No Equipment failure
260406	66	8/11/2023 7:20:21 AM	8/11/2023 8:54:53 AM	94.53	6238.98	Unplanned	No Trouble Found	Protection Equipment	Fuse
260982	1	8/23/2023 12:13:41 PM	8/23/2023 3:29:00 PM	195.32	195.32	Unplanned	No Trouble Found	Uncategorized	No Trouble Found

Requests for Information
NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
261376	1	9/1/2023 8:17:43 AM	9/1/2023 9:27:00 AM	69.28	69.28	Unplanned	Tree Contacts	Protection Equipment	Fuse
261969	2	9/15/2023 11:04:01 AM	9/15/2023 12:33:24 PM	89.38	178.76	Planned	Planned Outage	Conductors	Primary Conductor
263001	1	10/11/2023 11:09:09 PM	10/12/2023 9:22:00 AM	612.87	612.87	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
264478	1	10/21/2023 6:23:52 PM	10/21/2023 8:25:00 PM	121.13	121.13	Unplanned	No Trouble Found	Uncategorized	No Trouble Found
266908	1	11/29/2023 5:43:08 PM	11/30/2023 1:18:48 PM	1175.67	1175.67	Unplanned	Tree Contacts	Conductors	Primary Conductor
266908	1	11/29/2023 5:44:06 PM	11/30/2023 8:31:44 AM	887.65	887.65	Unplanned	Tree Contacts	Conductors	Primary Conductor
266908	3	11/29/2023 5:45:05 PM	11/29/2023 11:02:16 PM	317.2	951.6	Unplanned	Tree Contacts	Conductors	Primary Conductor
266908	19	11/29/2023 5:45:05 PM	11/30/2023 6:27:29 AM	762.42	14485.98	Unplanned	Tree Contacts	Conductors	Primary Conductor
266908	62	11/29/2023 5:45:05 PM	11/30/2023 8:31:44 AM	886.67	54973.54	Unplanned	Tree Contacts	Conductors	Primary Conductor
266908	66	11/29/2023 5:45:05 PM	11/30/2023 1:18:48 PM	1173.73	77466.18	Unplanned	Tree Contacts	Conductors	Primary Conductor
266908	13	11/29/2023 5:45:05 PM	11/30/2023 1:49:18 PM	1204.23	15654.99	Unplanned	Tree Contacts	Conductors	Primary Conductor
267143	1	11/30/2023 9:49:36 AM	11/30/2023 5:49:41 PM	480.1	480.1	Unplanned	Tree Contacts	Conductors	Primary Conductor
270719	1	1/4/2024 9:29:06 AM	1/4/2024 12:48:00 PM	198.9	198.9	Unplanned	Customer Owned Equipment	Uncategorized	No Trouble Found
271718	1	1/18/2024 4:57:56 PM	1/18/2024 9:32:43 PM	274.78	274.78	Unplanned	Tree Contacts	Conductors	Primary Conductor
271718	1	1/18/2024 4:59:24 PM	1/18/2024 9:32:43 PM	273.33	273.33	Unplanned	Tree Contacts	Conductors	Primary Conductor
271718	160	1/18/2024 4:59:51 PM	1/18/2024 9:32:43 PM	272.87	43659.2	Unplanned	Tree Contacts	Conductors	Primary Conductor
273319	11	2/13/2024 11:19:46 AM	2/13/2024 12:50:04 PM	90.32	993.52	Unplanned	Emergency Repairs	Support Structure	Pole

Requests for Information
NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
273788	36	2/19/2024 11:25:26 AM	2/19/2024 1:04:18 PM	98.88	3559.68	Planned	Maintenance Work	Conductors	Primary Conductor
274703	1	3/4/2024 11:35:18 AM	3/4/2024 11:40:00 AM	4.72	4.72	Planned	Maintenance Work	Transformer Equipment	Polemount Transformer
275604	9	3/15/2024 10:16:57 AM	3/15/2024 12:06:00 PM	109.07	981.63	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
275747	9	3/19/2024 2:26:44 PM	3/19/2024 3:35:00 PM	68.28	614.52	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
276360	1	4/1/2024 10:17:45 AM	4/1/2024 2:13:00 PM	235.25	235.25	Unplanned	Equipment Failure	Protection Equipment	Lightning Arrestor
277132	160	4/18/2024 5:28:15 PM	4/19/2024 1:09:31 AM	461.27	73803.2	Unplanned	Tree Contacts	Conductors	Primary Conductor
277132	3	4/18/2024 6:42:07 PM	4/18/2024 8:09:26 PM	87.32	261.96	Unplanned	Tree Contacts	Conductors	Primary Conductor
277132	1093	4/18/2024 6:42:07 PM	4/18/2024 8:26:21 PM	104.23	113923.39	Unplanned	Tree Contacts	Conductors	Primary Conductor
277132	3	4/18/2024 8:18:04 PM	4/18/2024 8:26:21 PM	8.28	24.84	Unplanned	Tree Contacts	Conductors	Primary Conductor
277132	3	4/18/2024 8:39:31 PM	4/19/2024 1:09:47 AM	270.28	810.84	Unplanned	Tree Contacts	Conductors	Primary Conductor
278085	2	5/9/2024 3:36:06 PM	5/9/2024 4:42:31 PM	66.42	132.84	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
278094	1	5/9/2024 7:55:19 PM	5/9/2024 10:14:00 PM	138.68	138.68	Unplanned	Equipment Failure	Protection Equipment	Lightning Arrestor
278209	12	5/13/2024 5:46:13 PM	5/13/2024 9:06:16 PM	200.05	2400.6	Unplanned	Equipment Failure	Support Structure	Pole
280696	2	6/20/2024 3:19:01 PM	6/20/2024 8:13:19 PM	294.3	588.6	Unplanned	Equipment Failure	Protection Equipment	Fuse
280704	94	6/20/2024 5:11:42 PM	6/20/2024 6:15:03 PM	63.37	5956.78	Unplanned	Emergency Repairs	Line Hardware	Suspension Insulator
280707	1	6/20/2024 5:39:53 PM	6/20/2024 6:23:33 PM	43.68	43.68	Unplanned	Emergency Repairs	Line Hardware	Deadend Insulator
280707	119	6/20/2024 5:40:07 PM	6/20/2024 6:23:33 PM	43.43	5168.17	Unplanned	Emergency Repairs	Line Hardware	Deadend Insulator

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
280707	2	6/20/2024 5:45:40 PM	6/20/2024 6:23:42 PM	38.03	76.06	Unplanned	Emergency Repairs	Line Hardware	Deadend Insulator
280822	1097	6/24/2024 5:27:13 AM	6/24/2024 1:15:54 PM	468.7	514163.9	Unplanned	Tree Contacts	Conductors	Primary Conductor
280938	9	6/26/2024 9:39:35 AM	6/26/2024 10:55:58 AM	76.4	687.6	Unplanned	Equipment Failure	Protection Equipment	Fuse
280967	9	6/26/2024 8:19:08 PM	6/26/2024 10:43:51 PM	144.73	1302.57	Unplanned	Equipment Failure	Protection Equipment	Lightning Arrestor
281138	2	6/28/2024 8:21:49 PM	6/28/2024 11:23:40 PM	181.87	363.74	Unplanned	Equipment Failure	Protection Equipment	Fuse
281450	1	7/5/2024 9:20:26 AM	7/5/2024 12:58:32 PM	218.1	218.1	Unplanned	Emergency Repairs	Protection Equipment	Fuse
281450	12	7/5/2024 9:26:39 AM	7/5/2024 12:58:32 PM	211.88	2542.56	Unplanned	Emergency Repairs	Protection Equipment	Fuse
281450	1	7/5/2024 9:47:43 AM	7/5/2024 12:58:32 PM	190.83	190.83	Unplanned	Emergency Repairs	Protection Equipment	Fuse
281450	1	7/5/2024 9:48:00 AM	7/5/2024 12:58:32 PM	190.55	190.55	Unplanned	Emergency Repairs	Protection Equipment	Fuse
281450	6	7/5/2024 10:03:30 AM	7/5/2024 1:32:10 PM	208.67	1252.02	Unplanned	Emergency Repairs	Protection Equipment	Fuse
281450	1	7/5/2024 10:04:59 AM	7/5/2024 12:58:32 PM	173.55	173.55	Unplanned	Emergency Repairs	Protection Equipment	Fuse
281450	44	7/5/2024 10:25:56 AM	7/5/2024 12:58:32 PM	152.6	6714.4	Unplanned	Emergency Repairs	Protection Equipment	Fuse
281933	2	7/10/2024 4:28:56 PM	7/10/2024 7:51:26 PM	202.52	405.04	Unplanned	Tree Contacts	Conductors	Primary Conductor
282415	1	7/18/2024 6:36:04 PM	7/18/2024 7:58:00 PM	81.93	81.93	Unplanned	Wildlife (Bird/Animal)	Transformer Equipment	Polemount Transformer
282547	1	7/21/2024 7:15:22 AM	7/21/2024 1:15:00 PM	359.63	359.63	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
282580	1	7/21/2024 10:06:08 AM	7/21/2024 1:14:00 PM	187.87	187.87	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
282864	1	7/26/2024 7:29:11 AM	7/26/2024 9:33:00 AM	123.82	123.82	Unplanned	Wildlife (Bird/Animal)	Transformer Equipment	Polemount Transformer

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
282949	1550	7/28/2024 1:50:53 PM	7/28/2024 2:14:46 PM	23.9	37045	Unplanned	NLH Underfrequency	Uncategorized	Other Utilities Equipment
284066	54	8/13/2024 4:36:45 PM	8/13/2024 6:19:04 PM	102.33	5525.82	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
285368	7	9/10/2024 11:09:54 AM	9/10/2024 2:00:17 PM	170.38	1192.66	Planned	Planned Outage	Support Structure	Other Support Structure
286211	1	9/27/2024 3:15:18 PM	9/27/2024 4:29:00 PM	73.7	73.7	Unplanned	Wildlife (Bird/Animal)	Transformer Equipment	Polemount Transformer
286695	1	10/11/2024 4:37:42 PM	10/11/2024 6:46:00 PM	128.3	128.3	Unplanned	Wildlife (Bird/Animal)	Transformer Equipment	Polemount Transformer
286915	1554	10/18/2024 11:33:14 AM	10/18/2024 11:37:02 AM	3.82	5936.28	Unplanned	NLH Underfrequency	Uncategorized	Other Utilities Equipment
289634	24	12/6/2024 5:11:28 AM	12/6/2024 7:08:36 AM	117.15	2811.6	Unplanned	Tree Contacts	Conductors	Primary Conductor
289634	179	12/6/2024 5:11:28 AM	12/6/2024 7:10:11 AM	118.73	21252.67	Unplanned	Tree Contacts	Conductors	Primary Conductor
289634	252	12/6/2024 5:11:28 AM	12/6/2024 8:56:26 AM	224.98	56694.96	Unplanned	Tree Contacts	Conductors	Primary Conductor
289634	1098	12/6/2024 5:11:28 AM	12/6/2024 8:56:58 AM	225.52	247620.96	Unplanned	Tree Contacts	Conductors	Primary Conductor
289634	203	12/6/2024 8:54:02 AM	12/6/2024 8:56:26 AM	2.42	491.26	Unplanned	Tree Contacts	Conductors	Primary Conductor
291017	1097	12/22/2024 12:42:56 AM	12/22/2024 5:19:25 AM	276.48	303298.56	Unplanned	Tree Contacts	Conductors	Primary Conductor
291083	67	12/22/2024 7:00:07 AM	12/22/2024 11:59:50 AM	299.73	20081.91	Unplanned	Tree Contacts	Conductors	Primary Conductor
291204	1	12/22/2024 1:06:08 PM	12/22/2024 6:27:00 PM	320.87	320.87	Unplanned	Wildlife (Bird/Animal)	No Equipment Damaged	No Equipment failure
291352	5	12/25/2024 11:53:58 AM	12/25/2024 1:08:07 PM	74.15	370.75	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
291356	1	12/25/2024 2:25:33 PM	12/25/2024 5:39:00 PM	193.45	193.45	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
291852	1096	1/5/2025 6:15:53 AM	1/5/2025 5:49:32 PM	693.67	760262.32	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 7:35:23 AM	1/6/2025 6:36:52 PM	2101.48	2101.48	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 7:35:41 AM	1/6/2025 6:36:52 PM	2101.2	2101.2	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 7:53:44 AM	1/6/2025 6:36:52 PM	2083.15	2083.15	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 8:11:04 AM	1/6/2025 6:36:52 PM	2065.82	2065.82	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 8:32:45 AM	1/6/2025 6:36:52 PM	2044.13	2044.13	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	26	1/5/2025 8:33:53 AM	1/5/2025 12:32:00 PM	238.13	6191.38	Unplanned	Tree Contacts	Conductors	Primary Conductor
292057	2	1/5/2025 8:33:53 AM	1/5/2025 9:34:17 AM	60.42	120.84	Unplanned	Unknown	Uncategorized	Unknown
292057	422	1/5/2025 8:33:53 AM	1/5/2025 10:06:41 AM	92.82	39170.04	Unplanned	Unknown	Uncategorized	Unknown
292057	2	1/5/2025 9:37:07 AM	1/5/2025 10:06:41 AM	29.57	59.14	Unplanned	Unknown	Uncategorized	Unknown
291852	1	1/5/2025 10:17:18 AM	1/6/2025 6:36:52 PM	1939.57	1939.57	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 10:18:35 AM	1/6/2025 6:36:52 PM	1938.3	1938.3	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 10:19:49 AM	1/6/2025 6:36:52 PM	1937.05	1937.05	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 10:26:47 AM	1/6/2025 6:36:52 PM	1930.1	1930.1	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 10:36:11 AM	1/6/2025 6:36:52 PM	1920.68	1920.68	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 10:36:34 AM	1/6/2025 6:36:52 PM	1920.32	1920.32	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 10:51:46 AM	1/6/2025 6:36:52 PM	1905.1	1905.1	Unplanned	Tree Contacts	Conductors	Primary Conductor

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
291852	1	1/5/2025 11:01:17 AM	1/6/2025 6:36:52 PM	1895.6	1895.6	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 11:03:05 AM	1/6/2025 6:36:52 PM	1893.78	1893.78	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 11:15:41 AM	1/6/2025 6:36:52 PM	1881.2	1881.2	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 11:32:46 AM	1/6/2025 6:36:52 PM	1864.12	1864.12	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 11:57:35 AM	1/6/2025 6:36:52 PM	1839.3	1839.3	Unplanned	Tree Contacts	Conductors	Primary Conductor
292638	1	1/5/2025 12:00:32 PM	1/6/2025 9:42:00 PM	2021.47	2021.47	Unplanned	Tree Contacts	Conductors	Service Wire
292057	403	1/5/2025 12:30:57 PM	1/5/2025 12:32:22 PM	1.43	576.29	Unplanned	Unknown	Uncategorized	Unknown
291852	1	1/5/2025 1:03:10 PM	1/6/2025 6:36:52 PM	1773.72	1773.72	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 1:17:52 PM	1/6/2025 6:36:52 PM	1759.02	1759.02	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 2:02:13 PM	1/6/2025 6:36:52 PM	1714.65	1714.65	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	1	1/5/2025 2:10:17 PM	1/6/2025 6:36:52 PM	1706.58	1706.58	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	17	1/5/2025 2:25:55 PM	1/6/2025 4:50:15 PM	1584.35	26933.95	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	122	1/5/2025 2:25:55 PM	1/6/2025 6:36:52 PM	1690.97	206298.34	Unplanned	Tree Contacts	Conductors	Primary Conductor
293164	1	1/5/2025 5:07:58 PM	1/6/2025 12:54:59 AM	467.02	467.02	Unplanned	Tree Contacts	Conductors	Primary Conductor
291852	19	1/5/2025 5:33:42 PM	1/6/2025 6:36:52 PM	1503.18	28560.42	Unplanned	Tree Contacts	Conductors	Primary Conductor
293049	810	1/5/2025 5:50:16 PM	1/5/2025 8:02:13 PM	131.95	106879.5	Unplanned	Tree Contacts	Uncategorized	Unknown
293164	90	1/5/2025 8:14:18 PM	1/6/2025 12:54:59 AM	280.68	25261.2	Unplanned	Tree Contacts	Conductors	Primary Conductor

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
293164	147	1/5/2025 8:14:18 PM	1/6/2025 3:46:36 PM	1172.3	172328.1	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 8:22:29 PM	1/6/2025 1:38:57 PM	1036.47	1036.47	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 8:24:30 PM	1/6/2025 1:38:57 PM	1034.45	1034.45	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 8:26:33 PM	1/6/2025 1:38:57 PM	1032.42	1032.42	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 8:34:12 PM	1/6/2025 1:38:57 PM	1024.75	1024.75	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 8:40:55 PM	1/6/2025 1:38:57 PM	1018.05	1018.05	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 8:44:59 PM	1/6/2025 1:38:57 PM	1013.98	1013.98	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 8:45:31 PM	1/6/2025 1:38:57 PM	1013.45	1013.45	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 8:54:19 PM	1/6/2025 12:15:42 PM	921.4	921.4	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 8:54:41 PM	1/6/2025 12:15:42 PM	921.02	921.02	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 8:56:44 PM	1/6/2025 12:15:42 PM	918.97	918.97	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 9:01:34 PM	1/6/2025 12:15:42 PM	914.13	914.13	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 9:02:24 PM	1/6/2025 12:15:42 PM	913.3	913.3	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 9:03:32 PM	1/6/2025 1:38:57 PM	995.42	995.42	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 9:07:02 PM	1/6/2025 12:15:42 PM	908.67	908.67	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 9:15:51 PM	1/6/2025 12:15:42 PM	899.85	899.85	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 9:19:17 PM	1/6/2025 12:15:42 PM	896.42	896.42	Unplanned	Tree Contacts	Conductors	Primary Conductor

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
293049	368	1/5/2025 9:34:54 PM	1/5/2025 9:42:53 PM	7.98	2936.64	Unplanned	Tree Contacts	Uncategorized	Unknown
293145	1	1/5/2025 9:51:33 PM	1/6/2025 12:15:42 PM	864.17	864.17	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/5/2025 10:02:43 PM	1/6/2025 1:38:57 PM	936.25	936.25	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/6/2025 2:33:30 AM	1/6/2025 12:15:42 PM	582.22	582.22	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/6/2025 6:25:19 AM	1/6/2025 12:15:42 PM	350.4	350.4	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	214	1/6/2025 9:14:58 AM	1/6/2025 12:15:42 PM	180.73	38676.22	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/6/2025 10:45:00 AM	1/6/2025 1:38:57 PM	173.95	173.95	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/6/2025 11:04:36 AM	1/6/2025 1:38:57 PM	154.35	154.35	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/6/2025 11:32:06 AM	1/6/2025 1:38:57 PM	126.87	126.87	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	1	1/6/2025 11:42:12 AM	1/6/2025 1:38:57 PM	116.75	116.75	Unplanned	Tree Contacts	Conductors	Primary Conductor
293145	132	1/6/2025 12:04:29 PM	1/6/2025 1:38:57 PM	94.47	12470.04	Unplanned	Tree Contacts	Conductors	Primary Conductor
293338	1	1/6/2025 12:45:22 PM	1/6/2025 2:22:00 PM	96.63	96.63	Unplanned	Tree Contacts	Conductors	Primary Conductor
293362	1	1/6/2025 2:25:16 PM	1/6/2025 5:14:00 PM	168.73	168.73	Unplanned	Tree Contacts	Conductors	Service Wire
293696	3	1/10/2025 10:30:47 AM	1/10/2025 12:34:42 PM	123.92	371.76	Planned	Planned Outage	No Equipment Damaged	No Equipment failure
293736	1	1/10/2025 4:07:05 PM	1/11/2025 10:25:57 AM	1098.87	1098.87	Unplanned	Tree Contacts	Conductors	Primary Conductor
293736	1	1/10/2025 4:07:05 PM	1/11/2025 10:48:23 AM	1121.3	1121.3	Unplanned	Tree Contacts	Conductors	Primary Conductor

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
294345	1	1/21/2025 8:49:58 PM	1/21/2025 11:01:00 PM	131.05	131.05	Unplanned	No Trouble Found	No Equipment Damaged	No Equipment failure
294360	1547	1/22/2025 3:23:49 AM	1/22/2025 3:32:41 AM	8.88	13737.36	Unplanned	NLH Underfrequency	Protection Equipment	Circuit Breaker
296737	1	2/26/2025 11:03:14 PM	2/27/2025 1:42:00 AM	158.78	158.78	Planned	Customer Requested Outage	No Equipment Damaged	No Equipment failure
296939	1371	2/28/2025 4:34:00 PM	2/28/2025 6:27:30 PM	113.5	155608.5	Unplanned	Emergency Repairs	Line Hardware	Pin Insulator
296939	179	2/28/2025 4:34:00 PM	2/28/2025 7:22:00 PM	168	30072	Unplanned	Emergency Repairs	Line Hardware	Pin Insulator
296939	1369	2/28/2025 6:28:42 PM	2/28/2025 7:22:00 PM	53.3	72967.7	Unplanned	Emergency Repairs	Line Hardware	Pin Insulator
296939	2	2/28/2025 6:28:42 PM	2/28/2025 10:19:37 PM	230.92	461.84	Unplanned	Emergency Repairs	Line Hardware	Pin Insulator
297384	1	3/9/2025 10:08:34 AM	3/9/2025 12:55:00 PM	166.43	166.43	Unplanned	Wildlife (Bird/Animal)	No Equipment Damaged	No Equipment failure
297385	5	3/9/2025 10:31:15 AM	3/9/2025 12:13:42 PM	102.45	512.25	Unplanned	Equipment Failure	Protection Equipment	Cutout
298445	98	4/2/2025 12:02:39 PM	4/2/2025 5:24:13 PM	321.58	31514.84	Unplanned	Tree Contacts	Conductors	Primary Conductor
299225	5	4/20/2025 7:26:04 AM	4/20/2025 10:52:15 AM	206.18	1030.9	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
299697	8	4/22/2025 12:05:00 PM	4/22/2025 12:11:34 PM	6.57	52.56	Unplanned	Tree Contacts	Protection Equipment	Fuse
300137	2	4/30/2025 8:09:21 PM	4/30/2025 8:30:29 PM	21.15	42.3	Unplanned	Equipment Failure	Conductors	Service Wire
300900	9	5/17/2025 10:17:16 AM	5/17/2025 12:40:00 PM	142.73	1284.57	Unplanned	Equipment Failure	Protection Equipment	Fuse
302223	159	6/18/2025 5:38:27 PM	6/18/2025 6:10:20 PM	31.9	5072.1	Unplanned	Tree Contacts	Conductors	Primary Conductor
303002	1	7/4/2025 8:43:11 AM	7/4/2025 9:51:00 AM	67.82	67.82	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
304208	12	7/16/2025 7:16:24 PM	7/16/2025 10:10:22 PM	173.97	2087.64	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
304437	561	7/20/2025 5:16:08 AM	7/20/2025 5:23:33 AM	7.43	4168.23	Unplanned	Unknown	Uncategorized	Unknown
304437	819	7/20/2025 5:16:08 AM	7/20/2025 5:24:07 AM	8	6552	Unplanned	Unknown	Uncategorized	Unknown
304437	180	7/20/2025 5:16:08 AM	7/20/2025 5:24:21 AM	8.23	1481.4	Unplanned	Unknown	Uncategorized	Unknown
304437	5	7/20/2025 5:16:16 AM	7/20/2025 5:21:12 AM	4.93	24.65	Unplanned	Unknown	Uncategorized	Unknown
306436	27	8/9/2025 7:38:02 AM	8/9/2025 9:51:10 AM	133.13	3594.51	Unplanned	Emergency Repairs	Protection Equipment	Fuse
306494	66	8/10/2025 8:30:53 AM	8/10/2025 11:23:37 AM	172.73	11400.18	Unplanned	Emergency Repairs	Protection Equipment	Fuse
307674	66	8/13/2025 7:10:19 AM	8/13/2025 8:52:05 AM	101.77	6716.82	Unplanned	Equipment Failure	Protection Equipment	Fuse
308086	1	8/20/2025 8:52:01 PM	8/21/2025 11:00:00 AM	847.98	847.98	Unplanned	Equipment Failure	Transformer Equipment	Polemount Transformer
308502	1	8/29/2025 5:35:30 PM	8/29/2025 6:21:00 PM	45.52	45.52	Planned	Non-Outage	Uncategorized	No Trouble Found
308511	28	8/29/2025 7:06:46 PM	8/29/2025 8:03:19 PM	56.55	1583.4	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
309033	1	9/9/2025 11:54:41 AM	9/9/2025 2:42:00 PM	167.32	167.32	Unplanned	Equipment Failure	Connecting Devices	Compression Connector
309208	66	9/13/2025 5:29:30 PM	9/13/2025 7:20:17 PM	110.8	7312.8	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
309552	1561	9/20/2025 4:04:07 AM	9/20/2025 4:48:51 AM	44.73	69823.53	Unplanned	NLH Underfrequency	Uncategorized	Other Utilities Equipment
310062	11	9/29/2025 1:57:22 PM	9/29/2025 3:18:43 PM	81.35	894.85	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
310437	1	10/7/2025 6:57:24 PM	10/7/2025 9:10:00 PM	132.6	132.6	Unplanned	Emergency Repairs	Protection Equipment	Fuse
310453	1560	10/7/2025 7:46:33 PM	10/7/2025 8:01:45 PM	15.22	23743.2	Unplanned	NLH Underfrequency	Uncategorized	Unknown

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
310453	4	10/7/2025 7:46:33 PM	10/7/2025 7:54:55 PM	8.37	33.48	Unplanned	NLH Underfrequency	Uncategorized	Unknown
311753	1104	11/3/2025 1:30:50 PM	11/3/2025 1:55:13 PM	24.38	26915.52	Unplanned	Tree Contacts	Conductors	Primary Conductor
311965	204	11/4/2025 4:50:11 PM	11/4/2025 8:26:39 PM	216.47	44159.88	Unplanned	Unknown	Uncategorized	Unknown
311965	537	11/4/2025 4:50:11 PM	11/4/2025 8:45:07 PM	234.93	126157.41	Unplanned	Unknown	Uncategorized	Unknown
312267	819	11/4/2025 4:50:11 PM	11/4/2025 8:49:12 PM	239.02	195757.38	Unplanned	Unknown	Uncategorized	Unknown
311965	741	11/4/2025 8:44:51 PM	11/4/2025 8:48:29 PM	3.65	2704.65	Unplanned	Unknown	Uncategorized	Unknown
312350	1	11/4/2025 9:00:19 PM	11/4/2025 11:47:17 PM	166.97	166.97	Unplanned	Unknown	Uncategorized	Unknown
312350	91	11/4/2025 9:03:38 PM	11/4/2025 11:47:17 PM	163.65	14892.15	Unplanned	Unknown	Uncategorized	Unknown
312350	147	11/4/2025 9:03:38 PM	11/5/2025 12:04:34 AM	180.93	26596.71	Unplanned	Unknown	Uncategorized	Unknown
312380	98	11/5/2025 12:16:11 AM	11/5/2025 2:53:30 AM	157.32	15417.36	Unplanned	Unknown	Uncategorized	Unknown
312417	1104	11/5/2025 3:26:36 AM	11/5/2025 12:13:41 PM	527.08	581896.32	Unplanned	Tree Contacts	Conductors	Primary Conductor
312546	66	11/5/2025 3:53:45 AM	11/5/2025 2:47:00 PM	653.25	43114.5	Unplanned	Tree Contacts	Conductors	Primary Conductor
312546	96	11/5/2025 6:15:38 AM	11/5/2025 2:47:00 PM	511.38	49092.48	Unplanned	Tree Contacts	Conductors	Primary Conductor
312848	1	11/5/2025 12:16:28 PM	11/5/2025 2:38:00 PM	141.55	141.55	Planned	Non-Outage	Uncategorized	No Trouble Found
312860	1	11/5/2025 12:29:18 PM	11/5/2025 1:54:00 PM	84.7	84.7	Unplanned	Tree Contacts	Conductors	Neutral Wire
312878	28	11/5/2025 12:31:47 PM	11/5/2025 1:52:52 PM	81.08	2270.24	Unplanned	Tree Contacts	Conductors	Neutral Wire
312871	1	11/5/2025 12:37:17 PM	11/5/2025 1:59:00 PM	81.72	81.72	Unplanned	Tree Contacts	Conductors	Neutral Wire

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
312885	1	11/5/2025 12:55:22 PM	11/5/2025 2:00:00 PM	64.65	64.65	Unplanned	Tree Contacts	Conductors	Neutral Wire
313729	1	11/9/2025 8:33:26 AM	11/9/2025 10:39:00 AM	125.58	125.58	Unplanned	Customer Owned Equipment	No Equipment Damaged	No Equipment failure
313888	2	11/11/2025 6:07:31 PM	11/11/2025 8:21:50 PM	134.33	268.66	Unplanned	Equipment Failure	Protection Equipment	Fuse
314452	3	11/17/2025 3:52:09 PM	11/17/2025 4:14:07 PM	21.97	65.91	Unplanned	Tree Contacts	Conductors	Primary Conductor
315464	1104	12/3/2025 9:11:43 PM	12/4/2025 2:27:53 AM	316.17	349051.68	Unplanned	Tree Contacts	Conductors	Primary Conductor
315467	456	12/3/2025 9:53:48 PM	12/3/2025 9:54:49 PM	1.03	469.68	Unplanned	Unknown	Uncategorized	Unknown
315532	2	12/4/2025 2:50:42 AM	12/4/2025 5:00:12 AM	129.52	259.04	Unplanned	Salt Spray/Contamination	Transformer Equipment	Polemount Transformer
315603	7	12/4/2025 4:57:03 AM	12/4/2025 1:20:00 PM	502.95	3520.65	Unplanned	Emergency Repairs	Transformer Equipment	Polemount Transformer
316113	3	12/5/2025 9:03:18 PM	12/5/2025 11:18:22 PM	135.08	405.24	Planned	Non-Outage	Uncategorized	No Trouble Found
316113	282	12/5/2025 9:03:18 PM	12/5/2025 11:55:34 PM	172.28	48582.96	Planned	Non-Outage	Uncategorized	No Trouble Found
316330	819	12/5/2025 9:03:18 PM	12/6/2025 1:01:27 AM	238.17	195061.23	Unplanned	Tree Contacts	Conductors	Primary Conductor
316405	1	12/5/2025 9:40:06 PM	12/6/2025 3:12:55 AM	332.82	332.82	Unplanned	Unknown	Uncategorized	Unknown
316405	1	12/5/2025 9:46:35 PM	12/6/2025 3:12:55 AM	326.35	326.35	Unplanned	Unknown	Uncategorized	Unknown
316405	1	12/5/2025 9:59:34 PM	12/6/2025 3:12:55 AM	313.37	313.37	Unplanned	Unknown	Uncategorized	Unknown
316405	9	12/5/2025 10:02:39 PM	12/6/2025 3:12:55 AM	310.27	2792.43	Unplanned	Unknown	Uncategorized	Unknown
316405	1	12/5/2025 10:29:21 PM	12/6/2025 3:12:55 AM	283.57	283.57	Unplanned	Unknown	Uncategorized	Unknown
316854	1	12/5/2025 10:51:12 PM	12/6/2025 9:03:39 PM	1332.45	1332.45	Unplanned	Tree Contacts	Conductors	Service Wire

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
316113	3	12/5/2025 11:53:14 PM	12/5/2025 11:55:26 PM	2.2	6.6	Planned	Non-Outage	Uncategorized	No Trouble Found
316405	1	12/6/2025 12:58:27 AM	12/6/2025 3:12:55 AM	134.48	134.48	Unplanned	Unknown	Uncategorized	Unknown
316405	1	12/6/2025 1:04:58 AM	12/6/2025 3:12:55 AM	127.95	127.95	Unplanned	Unknown	Uncategorized	Unknown
316405	147	12/6/2025 2:26:38 AM	12/6/2025 3:12:55 AM	46.3	6806.1	Unplanned	Unknown	Uncategorized	Unknown
316405	18	12/6/2025 3:05:09 AM	12/6/2025 3:12:55 AM	7.77	139.86	Unplanned	Unknown	Uncategorized	Unknown
316386	3	12/6/2025 3:20:44 AM	12/6/2025 4:05:51 AM	45.12	135.36	Unplanned	Tree Contacts	Conductors	Primary Conductor
316386	159	12/6/2025 3:20:44 AM	12/6/2025 4:08:12 PM	767.47	122027.73	Unplanned	Tree Contacts	Conductors	Primary Conductor
316854	3	12/6/2025 11:42:34 AM	12/6/2025 9:03:39 PM	561.08	1683.24	Unplanned	Tree Contacts	Conductors	Service Wire
317990	11	12/13/2025 3:45:02 PM	12/13/2025 6:17:06 PM	152.08	1672.88	Unplanned	Wildlife (Bird/Animal)	Conductors	Primary Conductor
318301	1	12/15/2025 9:47:40 PM	12/17/2025 1:51:00 PM	2403.35	2403.35	Unplanned	No Trouble Found	Conductors	Service Wire
319361	1	12/15/2025 10:55:12 PM	12/16/2025 3:56:21 PM	1021.15	1021.15	Unplanned	Tree Contacts	Conductors	Primary Conductor
319361	1	12/15/2025 10:59:38 PM	12/16/2025 3:56:21 PM	1016.72	1016.72	Unplanned	Tree Contacts	Conductors	Primary Conductor
319361	1	12/15/2025 11:06:29 PM	12/16/2025 3:56:21 PM	1009.87	1009.87	Unplanned	Tree Contacts	Conductors	Primary Conductor
319361	9	12/15/2025 11:07:37 PM	12/16/2025 3:56:21 PM	1008.73	9078.57	Unplanned	Tree Contacts	Conductors	Primary Conductor
319361	1	12/15/2025 11:18:36 PM	12/16/2025 3:56:21 PM	997.75	997.75	Unplanned	Tree Contacts	Conductors	Primary Conductor
319361	1	12/15/2025 11:37:24 PM	12/16/2025 3:56:21 PM	978.95	978.95	Unplanned	Tree Contacts	Conductors	Primary Conductor
319361	1	12/15/2025 11:56:37 PM	12/16/2025 3:56:21 PM	959.75	959.75	Unplanned	Tree Contacts	Conductors	Primary Conductor

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
318436	1103	12/15/2025 11:56:57 PM	12/16/2025 10:51:35 AM	654.65	722078.95	Unplanned	Tree Contacts	Conductors	Primary Conductor
319361	1	12/16/2025 12:01:21 AM	12/16/2025 3:56:21 PM	955.02	955.02	Unplanned	Tree Contacts	Conductors	Primary Conductor
319361	1	12/16/2025 1:59:02 AM	12/16/2025 3:56:21 PM	837.33	837.33	Unplanned	Tree Contacts	Conductors	Primary Conductor
319361	1	12/16/2025 2:00:17 AM	12/16/2025 3:56:21 PM	836.07	836.07	Unplanned	Tree Contacts	Conductors	Primary Conductor
319361	141	12/16/2025 2:47:33 AM	12/16/2025 3:56:21 PM	788.82	111223.62	Unplanned	Tree Contacts	Conductors	Primary Conductor
319695	98	12/16/2025 11:04:25 AM	12/16/2025 8:45:36 PM	581.18	56955.64	Unplanned	Unknown	Uncategorized	Unknown
319695	49	12/16/2025 11:15:05 AM	12/16/2025 8:45:36 PM	570.53	27955.97	Unplanned	Unknown	Uncategorized	Unknown
319362	24	12/16/2025 11:56:03 AM	12/16/2025 5:10:15 PM	314.22	7541.28	Unplanned	Tree Contacts	Conductors	Primary Conductor
319361	3	12/16/2025 12:24:47 PM	12/16/2025 3:56:21 PM	211.58	634.74	Unplanned	Tree Contacts	Conductors	Primary Conductor
319361	9	12/16/2025 12:57:59 PM	12/16/2025 1:35:15 PM	37.28	335.52	Unplanned	Tree Contacts	Conductors	Primary Conductor
319504	1	12/16/2025 4:12:30 PM	12/17/2025 3:56:00 PM	1423.5	1423.5	Unplanned	Emergency Repairs	Conductors	Service Wire
319547	1	12/16/2025 4:22:03 PM	12/17/2025 1:02:00 PM	1239.95	1239.95	Unplanned	No Trouble Found	Conductors	Service Wire
319695	49	12/16/2025 8:03:42 PM	12/16/2025 8:45:36 PM	41.92	2054.08	Unplanned	Unknown	Uncategorized	Unknown
319734	196	12/16/2025 9:29:10 PM	12/16/2025 10:42:05 PM	72.92	14292.32	Unplanned	Unknown	Uncategorized	Unknown
320729	1	12/20/2025 10:29:28 AM	12/20/2025 4:13:00 PM	343.55	343.55	Unplanned	No Trouble Found	No Equipment Damaged	No Equipment failure
321477	26	12/25/2025 2:37:49 PM	12/25/2025 3:16:56 PM	39.12	1017.12	Unplanned	Tree Contacts	Protection Equipment	Fuse
321477	129	12/25/2025 2:37:49 PM	12/26/2025 11:48:15 AM	1270.45	163888.05	Unplanned	Tree Contacts	Protection Equipment	Fuse

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
321477	148	12/25/2025 2:37:49 PM	12/26/2025 12:55:49 PM	1338.02	198026.96	Unplanned	Tree Contacts	Protection Equipment	Fuse
321553	98	12/25/2025 6:49:30 PM	12/26/2025 5:09:27 PM	1339.97	131317.06	Unplanned	Tree Contacts	Protection Equipment	Fuse
321615	1	12/26/2025 10:01:57 AM	12/26/2025 6:56:00 PM	534.05	534.05	Unplanned	Equipment Failure	Protection Equipment	Fuse
323931	1	1/12/2026 3:43:08 PM	1/12/2026 9:35:00 PM	351.87	351.87	Unplanned	Equipment Failure	Protection Equipment	Fuse
323396	1	1/12/2026 4:51:41 PM	1/12/2026 8:14:07 PM	202.45	202.45	Unplanned	Tree Contacts	Conductors	Primary Conductor
323396	1	1/12/2026 4:54:39 PM	1/12/2026 8:14:07 PM	199.47	199.47	Unplanned	Tree Contacts	Conductors	Primary Conductor
323396	1	1/12/2026 4:57:15 PM	1/12/2026 8:14:07 PM	196.87	196.87	Unplanned	Tree Contacts	Conductors	Primary Conductor
323396	1	1/12/2026 4:59:46 PM	1/12/2026 8:14:07 PM	194.35	194.35	Unplanned	Tree Contacts	Conductors	Primary Conductor
323396	1	1/12/2026 5:00:41 PM	1/12/2026 8:14:07 PM	193.45	193.45	Unplanned	Tree Contacts	Conductors	Primary Conductor
323396	142	1/12/2026 5:01:45 PM	1/12/2026 8:14:07 PM	192.38	27317.96	Unplanned	Tree Contacts	Conductors	Primary Conductor
323931	276	1/12/2026 7:34:11 PM	1/12/2026 9:35:00 PM	120.82	33346.32	Unplanned	Equipment Failure	Protection Equipment	Fuse
324245	1	1/12/2026 7:51:10 PM	1/13/2026 3:59:45 AM	488.6	488.6	Unplanned	Equipment Failure	Conductors	Primary Conductor
323661	179	1/12/2026 7:55:50 PM	1/12/2026 10:38:43 PM	162.88	29155.52	Unplanned	Unknown	Uncategorized	Unknown
324245	3	1/12/2026 10:43:48 PM	1/13/2026 2:37:18 AM	233.52	700.56	Unplanned	Equipment Failure	Conductors	Primary Conductor
324245	158	1/12/2026 10:43:48 PM	1/13/2026 3:59:45 AM	315.97	49923.26	Unplanned	Equipment Failure	Conductors	Primary Conductor
324291	1	1/12/2026 11:21:54 PM	1/13/2026 5:25:00 PM	1083.1	1083.1	Unplanned	Equipment Failure	Protection Equipment	Fuse
325781	1	1/14/2026 11:35:35 AM	1/14/2026 2:17:00 PM	161.42	161.42	Unplanned	Salt Spray/Contamination	Protection Equipment	Fuse

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
327700	2	1/19/2026 8:52:38 AM	1/19/2026 3:40:32 PM	407.9	815.8	Unplanned	Tree Contacts	Conductors	Primary Conductor
327710	1	1/19/2026 9:33:43 AM	1/19/2026 5:02:26 PM	448.72	448.72	Unplanned	Tree Contacts	Conductors	Primary Conductor
327920	2	1/19/2026 6:34:06 PM	1/20/2026 1:01:47 AM	387.68	775.36	Unplanned	Tree Contacts	Conductors	Primary Conductor
328015	4	1/20/2026 11:55:50 AM	1/20/2026 3:07:41 PM	191.85	767.4	Unplanned	Tree Contacts	Conductors	Primary Conductor
328491	1	1/25/2026 9:49:51 AM	1/25/2026 11:42:00 AM	112.15	112.15	Unplanned	No Trouble Found	Uncategorized	No Trouble Found
331864	37	2/22/2026 10:58:21 AM	2/22/2026 2:13:15 PM	194.92	7212.04	Unplanned	Tree Contacts	Conductors	Primary Conductor
332940	1561	2/27/2026 11:20:35 AM	2/27/2026 11:48:37 AM	28.05	43786.05	Unplanned	NLH Underfrequency	Uncategorized	Unknown
335340	1	4/7/2026 10:09:24 AM	4/7/2026 1:09:55 PM	180.53	180.53	Planned	Planned Outage	No Equipment Damaged	No Equipment failure
335951	1	4/20/2026 5:22:38 PM	4/20/2026 7:52:00 PM	149.38	149.38	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
336020	1559	4/22/2026 1:11:20 PM	4/22/2026 1:15:02 PM	3.72	5799.48	Unplanned	Unknown	Uncategorized	Unknown
336029	1	4/22/2026 1:17:19 PM	4/22/2026 4:08:22 PM	171.05	171.05	Unplanned	Tree Contacts	Conductors	Primary Conductor
336029	1	4/22/2026 1:20:42 PM	4/22/2026 4:08:22 PM	167.67	167.67	Unplanned	Tree Contacts	Conductors	Primary Conductor
336029	1	4/22/2026 1:32:25 PM	4/22/2026 4:08:22 PM	155.95	155.95	Unplanned	Tree Contacts	Conductors	Primary Conductor
336029	1	4/22/2026 1:33:49 PM	4/22/2026 4:08:22 PM	154.57	154.57	Unplanned	Tree Contacts	Conductors	Primary Conductor
336029	26	4/22/2026 1:38:28 PM	4/22/2026 2:39:33 PM	61.07	1587.82	Unplanned	Tree Contacts	Conductors	Primary Conductor
336029	96	4/22/2026 1:38:28 PM	4/22/2026 4:08:22 PM	149.9	14390.4	Unplanned	Tree Contacts	Conductors	Primary Conductor
336708	1	5/4/2026 9:16:35 AM	5/4/2026 10:57:00 AM	100.42	100.42	Unplanned	Equipment Failure	Protection Equipment	Fuse

Requests for Information

NP 2027 Capital Budget Application

Incident ID	Customers Affected	Outage Time	Restored Time	Duration Minutes	Total Customer Minutes	Planned Outage	Cause	Equipment Category	Equipment
336793	1	5/4/2026 9:29:18 PM	5/4/2026 11:03:00 PM	93.7	93.7	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
336978	123	5/6/2026 3:50:12 PM	5/6/2026 6:21:55 PM	151.72	18661.56	Unplanned	Tree Contacts	Conductors	Primary Conductor
336978	23	5/6/2026 3:58:37 PM	5/6/2026 6:21:55 PM	143.3	3295.9	Unplanned	Tree Contacts	Conductors	Primary Conductor
336978	2	5/6/2026 5:36:58 PM	5/6/2026 6:21:55 PM	44.95	89.9	Unplanned	Tree Contacts	Conductors	Primary Conductor
338206	4	5/31/2026 11:11:54 AM	5/31/2026 1:11:13 PM	119.32	477.28	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
338288	3	6/2/2026 10:07:10 AM	6/2/2026 2:05:28 PM	238.32	714.96	Planned	Planned Outage	Transformer Equipment	Polemount Transformer
338375	4	6/4/2026 7:11:54 AM	6/4/2026 8:45:00 AM	93.12	372.48	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
338626	4	6/7/2026 9:27:00 AM	6/7/2026 10:47:43 AM	80.73	322.92	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
338681	1	6/8/2026 10:46:27 AM	6/8/2026 12:07:00 PM	80.55	80.55	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
339307	1	6/21/2026 9:23:45 AM	6/21/2026 2:03:00 PM	279.25	279.25	Unplanned	Lightning	Protection Equipment	Fuse
339370	1	6/23/2026 8:42:44 AM	6/23/2026 10:01:00 AM	78.27	78.27	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
339595	1	6/26/2026 2:25:23 PM	6/26/2026 10:14:04 PM	468.68	468.68	Unplanned	Equipment Failure	Transformer Equipment	Polemount Transformer
339697	16	6/28/2026 8:14:20 PM	6/28/2026 9:48:20 PM	94.02	1504.32	Unplanned	Wildlife (Bird/Animal)	Protection Equipment	Fuse
339764	567	6/29/2026 2:51:39 PM	6/29/2026 3:46:53 PM	55.23	31315.41	Unplanned	Tree Contacts	Conductors	Primary Conductor
339764	821	6/29/2026 2:51:39 PM	6/29/2026 3:47:32 PM	55.88	45877.48	Unplanned	Tree Contacts	Conductors	Primary Conductor
339764	182	6/29/2026 2:51:39 PM	6/29/2026 3:48:40 PM	57.02	10377.64	Unplanned	Tree Contacts	Conductors	Primary Conductor